



- NOTE:
1. S.P.M.D.D. = STANDARD PROCTOR MAXIMUM DRY DENSITY
 2. ALL VALVE BOXES LOCATED IN THE TRAVELLED PORTION OF THE ROADWAY SHALL BE SCREW TYPE.

GATE VALVE AND VALVE BOX ON PVC WATERMAINS

NO.	REVISIONS	COMMENTS	BY	DATE	APPROVED BY	APPROVED DATE
1	NOTES AND TITLE BLOCK UPDATE		BC	2007/06/27		

CITY OF KAWARTHA LAKES
ENGINEERING AND CORPORATE ASSETS

322 KENT ST. W. Box 900, LINCOLN, ON. N0Y 4T7, (709) 324-8411

ISSUED BY: JN
CHECKED BY: CS
DATE: 2017/08



CONTRACT NO.:
SCALE: 1:25
PAGE 1 OF 1
DRAWING NO.:
CKL - 101