



NOTES:

1. GRANULAR THRUST BLOCKS SHALL BE FULLY EXTENDED AND COMPACTED AGAINST TRENCH WALLS. IF TRENCH WALLS ARE SATURATED OR DISTURBED, SPECIAL DETAILS OF THRUST RESTRAINTS SHALL BE PROVIDED BY THE ENGINEER.
2. MINIMUM RESTRAINING LENGTH (L) AS PER CKL-104.



SUPPORT FOR MECHANICAL JOINTS FOR PVC WATERMAINS-PLUGGED CROSS

CKL-106

SCALE: NOT TO SCALE

DATE: AUGUST 2017

ENGINEERING & CORPORATE
ASSETS

CHECKED: JN

APPROVED: CS

APPROVED DATE: AUGUST 2017

REVISION No. 1