

CERTIFICATE OF WATER TANKER SHUTTLE ACCREDITATION

Presented to

Yavanta Lakes Fire Department

F.S. #15 Kirkfield
F.S. #19 Cobocok
F.S #20 Burnt River
F.S #21 Mariposa
F.S #22 Fenelon Falls

Date Test Passed: October 16th, 23rd & 24th 2021

Residential and Industrial Certification (8)

Flow Achieved: ___415___ I.G.P.M Liters Per Min: ___1900___
Two (2) Hour Test Time

Signed: *Melissa Rose*
Melissa Rose – Principal
This Certificate is valid for 5 years and expires October 24th 2026