

# **Woodville Drinking Water System**

## **2024 Annual Water Report**

Drinking Water System Number: 210001077

Drinking Water System Operating Authorities: City of Kawartha Lakes and Ontario  
Clean Water Agency

Drinking Water System Category: Large Municipal Residential

Reporting Period: January 1 – December 31, 2024



# Table of Contents

2024 Annual Drinking Water System Summary Report.....	3
General Information .....	3
Compliance Summary .....	3
Drinking Water System Description .....	4
Source Water .....	4
Water Treatment Facility .....	4
Distribution System .....	4
Summary of Non-Compliance .....	5
Adverse Water Quality Incidents .....	5
Non-Compliance.....	5
Non-Compliance Identified in a Ministry Inspection .....	5
Flows .....	5
Raw Water Flows .....	5
Treated Water Flows .....	9
Regulatory Sample Results Summary .....	11
Microbiological Testing .....	11
Operational Testing .....	11
Inorganic Parameters .....	11
Schedule 15 Sampling (Lead).....	13
Organic Parameters.....	13
Additional Legislated Samples .....	15
Minor Maintenance .....	17
Major Maintenance Expense (above \$10,000) .....	17
APPENDIX A .....	18
WTR Submission Confirmation .....	18

# 2024 Annual Drinking Water System Summary Report

## General Information

The City of Kawartha Lakes prepares a report summarizing system operation and water quality for every municipal drinking water system annually. This report has been prepared to satisfy the annual reporting requirements in O. Reg. 170/03 Section 11 and Schedule 22. The annual reports will be available to residents at the City of Kawartha Lakes Public Works Administration Office by appointment and the [City's website](#). Notification that the reports are available free of charge will be made on the City of Kawartha Lakes website. The City of Kawartha Lakes Public Works Administration Office is located at 322 Kent Street West in Lindsay, Ontario.

This system does not serve more than 10,000 residences.

**Drinking Water System Number:** 210001077

**Drinking Water System Name:** Woodville Drinking Water System

**Drinking Water System Owner:** City of Kawartha Lakes

**Drinking Water System Category:** Large Municipal Residential

**Reporting Period:** January 1, 2024 – December 31, 2024

## Compliance Summary

**Table 1. Drinking Water Compliance Summary**

	Number of Events	Date	Details
Ministry (MECP) Inspections	2	February 15, 2024	2023/2024 Announced Drinking Water Inspection, Inspection Rating 97.67%
		November 28, 2024	2024/2025 Announced Focused Drinking Water Inspection. Final Report received January 20, 2025, Inspection Rating 100%
Adverse Water Quality Incidents (AWQIs)	0		

	Number of Events	Date	Details
<b>Non-Compliances</b>	1	2023/2024 MECP Inspection	Found during the inspection that the turbidity analyzer calibration was not performed within the 90 days as per the manufacturer requirements.
<b>Boil Water Advisories</b>	0		
<b>Health and Safety</b>	0		

## Drinking Water System Description

The Woodville drinking water system is a large municipal residential drinking water system that serves the Village of Woodville, in the City of Kawartha Lakes. The drinking water system is classified as a Class I Water Treatment and Class I Water Distribution subsystems under O. Reg. 128/04

### Source Water

The water supply for the system comes from two groundwater wells: Well #1 and Well #2. There is an additional well (Well #3) that is a pond makeup well. The wells are designated as GUDI (groundwater under the direct influence of surface water).

### Water Treatment Facility

The treatment system consists of two (2) treatment trains in parallel. Each train consists of two (2) cartridge filter assemblies and a sodium hypochlorite disinfection system. There are on-line turbidimeters on each filter effluent line to monitor filter effluent turbidity. There is a 90 m 600 mm diameter watermain that is located from the pumphouse along County Road 46 that serves as a chlorine contact chamber. A building is located at the end of this pipe that houses a chlorine analyzer to ensure proper disinfection.

A diesel generator is onsite to provide standby power to the water treatment facility in the event of a power failure.

### Distribution System

The distribution system has approximately 8.7 kilometers of watermains and is not rated for fire protection. The watermains in the Woodville Distribution System are all PVC. Water storage is provided in a standpipe with an approximate capacity of 1160 m<sup>3</sup>. The standpipe serves to provide pressure equalization within the distribution system. There are no chlorine boosting or secondary disinfection capabilities within the control of the distribution system.

**Table 2. Treatment Chemicals Used**

Chemical Name	Use	Supplier
Sodium Hypochlorite	Disinfection	Jutzi

## Summary of Non-Compliance

### Adverse Water Quality Incidents

There were no adverse water quality incidents reported during the reporting period.

### Non-Compliance

There were no non-compliances reported during the reporting period.

### Non-Compliance Identified in a Ministry Inspection

**Table 3. Non-Compliance Identified in a Ministry Inspection**

Legislation	Requirement(s) System Failed to Meet	Duration of Failure (Dates)	Corrective Action	Status
O. Reg. 170/03 Section 6-5	Calibration of Equipment	MECP Inspection 2023/2024	Created a turbidity analyzer record sheet, modified the sample calendar to include turbidity analyzer calibration.	Completed


## Flows

The Woodville Drinking Water System is operating on average under half the rated capacity. The rated capacity of the system (treated water flows) is 588 m<sup>3</sup>/day.


### Raw Water Flows

The raw water flows are regulated under the Permit to Take Water. Raw flow data for 2024 was submitted to the Ministry of Environment, Conservation and Parks (MECP) electronically under permit #1207-AHKRXV. The confirmation of the data that was submitted is attached in Appendix A.

## Graph 1. Total Monthly Flows (m³/d) – Well #1 (Max Allowable PTTW)




## Graph 2. Monthly Rated Flows (L/s) – Well #1 (Max Allowable Rate PTTW)




**Note:** The above table shows there were exceedances in instantaneous peak flow rate (L/s) but these exceedances were short in duration. Spikes recorded by on-line instrumentation were a result of air bubbles and various maintenance/calibration activities. The significant spike in August

was due to scheduled flow meter calibration. All spikes are reviewed for compliance with O. Reg. 170/03.

**Graph 3. Total Monthly Flows (m³/d) – Well #2 (Max Allowable PTTW)**




**Graph 4. Monthly Rated Flows (L/s) – Well #2 (Max Allowable Rate PTTW)**




**Note:** The above table shows there were exceedances in instantaneous peak flow rate (L/s) but these exceedances were short in duration. Spikes recorded by on-line instrumentation were a

result of air bubbles and various maintenance/calibration activities. The significant spike in August was due to scheduled flow meter calibration. All spikes are reviewed for compliance with O. Reg. 170/03.

**Graph 5. Total Monthly Flows (m³/d) – Well #3 Pond Makeup Well (Max Allowable PTTW)**




**Graph 6. Monthly Rated Flows (L/s) – Well #3 Pond Makeup Well (Max Allowable Rate PTTW)**





**Note:** The above table shows there were exceedances in instantaneous peak flow rate (L/s) but these exceedances were short in duration. Spikes recorded by on-line instrumentation were a result of air bubbles and various maintenance/calibration activities. The significant spike in August was due to scheduled flow meter calibration. All spikes are reviewed for compliance with O. Reg. 170/03.


**Graph 7. Total Monthly Raw Flows (m³/day) –Max Allowable Rate PTTW**




## Treated Water Flows

The Treated Water flows are regulated under the Municipal Drinking Water Licence 141-115.

**Graph 8. Monthly Rated Flows (m³/d) – Rated Capacity - MDWL**



**Graph 9. Annual Total Flow Comparison (m³)**



# Regulatory Sample Results Summary

## Microbiological Testing

**Table 4. Microbiological Test Results**

	No. of Samples Collected	Range of E. Coli Results	Range of E. Coli Results	Range of Total Coliform Results	Range of Total Coliform Results	Range of HPC Results	Range of HPC Results
		Min	Max	Min	Max	Min	Max
<b>Raw Well 1</b>	52	0	0	0	4	N/A	N/A
<b>Raw Well 2</b>	54	0	1	0	2	N/A	N/A
<b>Treated</b>	54	0	0	0	0	0	3
<b>Distribution</b>	159	0	0	0	0	0	15

OG = Overgrowth

HPC = Heterotrophic Plate Count

## Operational Testing

**Table 5. Operational Test Results**

Parameter	Number of Samples Collected	Range of Results Minimum	Range of Results Maximum
<b>Turbidity Well 1 (NTU)</b>	52	0.17	0.95
<b>Turbidity Well 2 (NTU)</b>	52	0.08	0.89
<b>Turbidity – Filter 1/2 (NTU)</b>	8760	0	2.00
<b>Turbidity – Filter 3/4 (NTU)</b>	8760	0	2.00
<b>Chlorine</b>	8760	0	3.40
<b>Fluoride</b> (If the DWS provides fluoridation)	N/A	N/A	N/A

**Note:** Record the unit of measurement if it is **not** milligrams per litre.

**Note:** For continuous monitors 8760 is used as the number of samples. Spikes recorded by online instrumentation were a result of air bubbles and various maintenance/calibration activities. All spikes are reviewed for compliance with O. Reg. 170/03.

## Inorganic Parameters

These parameters are tested as a requirement under O. Reg. 170/03. Sodium and Fluoride are required to be tested every five years. Nitrate and Nitrate are tested quarterly and the metals are

tested annually as required under O. Reg. 170/03. In the event any of the parameters listed in Schedule 23 or 24 of O. Reg. 170/03 exceed half of the maximum allowable concentration the parameter is required to be samples quarterly. Based on the latest test results no additional testing is required.

**Table 6. Inorganic Parameters Test Results**

	Sample Date (yyyy/mm/dd)	Sample Result	Unit of Measure	MAC	Exceedance
<b>Treated Water</b>					
Antimony	2024 01 08	<MDL 0.6	µg/L	6.0	No
Arsenic	2024 01 08	<MDL 0.2	µg/L	10.0	No
Barium	2024 01 08	42.6	µg/L	1000.0	No
Boron	2024 01 08	11.0	µg/L	5000.0	No
Cadmium	2024 01 08	0.006	µg/L	5.0	No
Chromium	2024 01 08	0.19	µg/L	50.0	No
Mercury	2024 01 08	<MDL 0.01	µg/L	1.0	No
Selenium	2024 01 08	0.21	µg/L	50.0	No
Uranium	2024 01 08	0.663	µg/L	20.0	No
<b>Additional Organics</b>					
Fluoride	2023 01 04	<MDL 0.06	mg/L	1.5	No
Nitrite	2024 01 02	<MDL 0.003	mg/L	1.0	No
Nitrite	2024 04 02	<MDL 0.003	mg/L	1.0	No
Nitrite	2024 07 02	<MDL 0.003	mg/L	1.0	No
Nitrite	2024 10 07	<MDL 0.003	mg/L	1.0	No
Nitrate	2024 01 02	1.77	mg/L	10.0	No
Nitrate	2024 04 02	1.58	mg/L	10.0	No
Nitrate	2024 07 02	1.44	mg/L	10.0	No
Nitrate	2024 10 07	1.57	mg/L	10.0	No
Sodium	2023 01 04	11.0	mg/L	20*	No

MAC = Maximum Allowable Concentration as per O. Reg. 169/03

MDL = Method Detection Limit

\*There is no "MAC" for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. Sodium results exceeding 20 mg/L are to be reported to the Medical Officer of Health as per Schedule 16-3 (8) of O. Reg. 170/03.

## Schedule 15 Sampling (Lead)

The Schedule 15 sampling is required under O. Reg. 170/03. This system is under reduced sampling. Only distribution samples were collected, and no plumbing samples were collected.

**Table 7. Schedule 15 Test Results (Lead)**

	Number of Sampling Points	Number of Samples	Range of Results Minimum	Range of Results Maximum	MAC (µg/L)	Number of Exceedances
<b>Alkalinity (mg/L)</b>	4	4	256	287	N/A	N/A
<b>pH</b>	4	4	7.08	7.34	N/A	N/A
<b>Lead (µg/L)</b>	0	0	N/A	N/A	10	

## Organic Parameters

These parameters are tested as a requirement under O. Reg. 170/03. In the event any of the parameters listed in Schedule 23 or 24 of O. Reg. 170/03 exceed half of the maximum allowable concentration the parameter is required to be samples quarterly. Based on the latest test results no additional testing is required.

**Table 8. Organic Parameters Test Results**

	Sample Date (yyyy/mm/dd)	Sample Result	Unit of Measure	MAC	Exceedance
<b>Treated Water</b>					
Alachlor	2024 01 08	<MDL 0.02	µg/L	5.0	No
Atrazine + N-dealkylated metabolites	2024 01 08	<MDL 0.01	µg/L	5.0	No
Azinphos-methyl	2024 01 08	<MDL 0.05	µg/L	20.0	No
Benzene	2024 01 08	<MDL 0.32	µg/L	1.0	No
Benzo(a)pyrene	2024 01 08	<MDL 0.004	µg/L	0.01	No
Bromoxynil	2024 01 08	<MDL 0.33	µg/L	5.0	No
Carbaryl	2024 01 08	<MDL 0.05	µg/L	90.0	No
Carbofuran	2024 01 08	<MDL 0.01	µg/L	90.0	No
Carbon Tetrachloride	2024 01 08	<MDL 0.17	µg/L	2.0	No

	Sample Date (yyyy/mm/dd)	Sample Result	Unit of Measure	MAC	Exceedance
Chlorpyrifos	2024 01 08	<MDL 0.02	µg/L	90.0	No
Diazinon	2024 01 08	<MDL 0.02	µg/L	20.0	No
Dicamba	2024 01 08	<MDL 0.2	µg/L	120.0	No
1,2-Dichlorobenzene	2024 01 08	<MDL 0.41	µg/L	200.0	No
1,4-Dichlorobenzene	2024 01 08	<MDL 0.36	µg/L	5.0	No
1,2-Dichloroethane	2024 01 08	<MDL 0.35	µg/L	5.0	No
1,1-Dichloroethylene	2024 01 08	<MDL 0.33	µg/L	14.0	No
Dichloromethane (Methylene Chloride)	2024 01 08	<MDL 0.35	µg/L	50.0	No
2,4-Dichlorophenol	2024 01 08	<MDL 0.15	µg/L	900.0	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	2024 01 08	<MDL 0.19	µg/L	100.0	No
Diclofop-methyl	2024 01 08	<MDL 0.4	µg/L	9.0	No
Dimethoate	2024 01 08	<MDL 0.06	µg/L	20.0	No
Diquat	2024 01 08	<MDL 1.0	µg/L	70.0	No
Diuron	2024 01 08	<MDL 0.03	µg/L	150.0	No
Glyphosate	2024 01 08	<MDL 1.0	µg/L	280.0	No
Malathion	2024 01 08	<MDL 0.02	µg/L	190.0	No
2-Methyl- 4chlorophenoxyacetic Acid (MCPA)	2024 01 08	<MDL 0.12	µg/L	100.0	No
Metolachlor	2024 01 08	<MDL 0.01	µg/L	50.0	No
Metribuzin	2024 01 08	<MDL 0.02	µg/L	80.0	No
Monochlorobenzene (Chlorobenzene)	2024 01 08	<MDL 0.3	µg/L	80.0	No
Paraquat	2024 01 08	<MDL 1.0	µg/L	10.0	No
PCB	2024 01 08	<MDL 0.04	µg/L	3.0	No
Pentachlorophenol	2024 01 08	<MDL 0.15	µg/L	60.0	No
Phorate	2024 01 08	<MDL 0.01	µg/L	2.0	No
Picloram	2024 01 08	<MDL 1.0	µg/L	190.0	No
Prometryne	2024 01 08	<MDL 0.03	µg/L	1.0	No
Simazine	2024 01 08	<MDL 0.01	µg/L	10.0	No
Terbufos	2024 01 08	<MDL 0.01	µg/L	1.0	No
Tetrachloroethylene	2024 01 08	<MDL 0.35	µg/L	10.0	No
2,3,4,6- Tetrachlorophenol	2024 01 08	<MDL 0.2	µg/L	100.0	No
Triallate	2024 01 08	<MDL 0.01	µg/L	230.0	No
Trichloroethylene	2024 01 08	<MDL 0.44	µg/L	5.0	No
2,4,6-Trichlorophenol	2024 01 08	<MDL 0.25	µg/L	5.0	No
Trifluralin	2024 01 08	<MDL 0.02	µg/L	45.0	No
Vinyl Chloride	2024 01 08	<MDL 0.17	µg/L	1.0	No
<b>Distribution Water</b>					

	Sample Date (yyyy/mm/dd)	Sample Result	Unit of Measure	MAC	Exceedance
Trihalomethane Total Annual Average Q1	2024 01 02	23.5	µg/L	100.0	No
Trihalomethane Total Annual Average Q2	2024 04 02	23.75	µg/L	100.0	No
Trihalomethane Total Annual Average Q3	2024 07 02	24	µg/L	100.0	No
Trihalomethane Total Annual Average Q4	2024 10 01	24	µg/L	100.0	No
HAA Total Annual Average Q1	2024 01 02	10.78	µg/L	80.0	No
HAA Total Annual Average Q2	2024 04 02	11.23	µg/L	80.0	No
HAA Total Annual Average Q3	2024 07 02	9.5	µg/L	80.0	No
HAA Total Annual Average Q4	2024 10 01	9.5	µg/L	80.0	No

MAC = Maximum Allowable Concentration as O. Reg. 169/03

MDL = Method Detection Limit

### Additional Legislated Samples

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Additional samples are required under Permit to Take Water #1207-AHKRZV

**Table 9. Additional Permit to Take Water Sampling Test Results**

Parameter	Location	No. of Samples Collected	Range of Results Minimum	Range of Results Maximum
Nitrite (mg/L)	Well 1	14	<MDL 0.003	<MDL 0.003
Nitrite (mg/L)	Well 2	14	<MDL 0.003	<MDL 0.003
Nitrate (mg/L)	Well 1	14	1.26	1.84
Nitrate (mg/L)	Well 2	14	1.31	1.78
Nitrites + Nitrates (mg/L)	Well 1	14	1.26	1.84
Nitrites + Nitrates (mg/L)	Well 2	14	1.31	1.78
Calcium (mg/L)	Well 1	2	96.5	102
Calcium (mg/L)	Well 2	2	92.7	103

Parameter	Location	No. of Samples Collected	Range of Results Minimum	Range of Results Maximum
Magnesium (mg/L)	Well 1	2	11.0	11.2
Magnesium (mg/L)	Well 2	2	11.0	11.6
Sodium (mg/L)	Well 1	2	4.78	6.57
Sodium (mg/L)	Well 2	2	6.24	8.27
Potassium (mg/L)	Well 1	2	1.55	1.57
Potassium (mg/L)	Well 2	2	1.72	1.73
Chloride (mg/L)	Well 1	2	7.90	12.0
Chloride (mg/L)	Well 2	2	11.0	56.0
Sulphate (mg/L)	Well 1	2	16	22
Sulphate (mg/L)	Well 2	2	18	24
Alkalinity (mg/L as CaCO <sub>3</sub> )	Well 1	2	261	288
Alkalinity (mg/L as CaCO <sub>3</sub> )	Well 2	2	257	287
pH	Well 1	2	7.73	7.75
pH	Well 2	2	7.63	7.75
Ammonia + Ammonium (N) (mg/L)	Well 1	14	<MDL 0.04	0.06
Ammonia + Ammonium (N) (mg/L)	Well 2	14	<MDL 0.04	0.04
Total Kjeldahl Nitrogen (mg/L)	Well 1	14	<MDL 0.05	0.22
Total Kjeldahl Nitrogen (mg/L)	Well 2	14	<MDL 0.05	0.33
Conductivity (uS/cm)	Well 1	2	521	535
Conductivity (uS/cm)	Well 2	2	526	534
Total Dissolved Solids (mg/L)	Well 1	2	346	366
Total Dissolved Solids (mg/L)	Well 2	2	346	349
Hydrogen Sulphide (mg/L)	Well 1	2	<MDL 0.006	<MDL 0.006



Parameter	Location	No. of Samples Collected	Range of Results Minimum	Range of Results Maximum
Hydrogen Sulphide (mg/L)	Well 2	2	<MDL 0.006	<MDL 0.006
Ion Ratio	Well 1	2	1.13	2.25
Ion Ratio	Well 2	2	0.530	1.87

## Minor Maintenance

- Private well data logger replacement
- Compliance analyzer feedline repair
- Filter to waste valve replacement
- Well #1 datalogger replacement
- Chlorine discharge lines replacement
- Well #1 conduit repair
- Standpipe cell sump pump replacement
- Filter  $\frac{3}{4}$  turbidity analyzer desiccant replacement
- Greywater tank sump pump replacement
- Well #3 interlock issue repair
- UPS replacement
- Outpost panel battery replacement


## Major Maintenance Expense (above \$10,000)


Under Section 11 of O. Reg. 170/03, a description of any major expenses incurred during this reporting period to install, repair or replace required equipment must be included in the annual report. The details of the major expenses for this drinking water system are as follows:

- Woodville Standpipe Improvements - \$967,833

# APPENDIX A

## WTR Submission Confirmation





Ministry of the Environment,  
Conservation and Parks

| [WT DATA](#) | [REPORTS](#) | [SEARCH WT DATA](#) | [ADMINISTRATION](#) | [USER PROFILE](#) | [CONTACT US](#) | [HELP](#) | [HOME](#) | [LOGOUT](#) |

Location: [WTRS](#) / [WT DATA](#) / [Edit Submitted WT Records](#)WTRS-WT-008

**Water Taking Data submitted successfully.**

**Confirmation:**

Thank you for submitting your water taking data online.

Permit Number: 1207-AHKRXV  
Permit Holder: THE CORPORATION OF THE CITY OF KAWARTHA LAKES.  
Received on: Feb 10, 2025 8:48 AM

This confirmation indicates that your data has been received by the Ministry, but should not be construed as acceptance of this data if it differs from that specified on the Permit Number, assigned to the Permit Holder stated above.