

Kinmount Drinking Water System

2024 Annual Water Report

Drinking Water System Number: 260075231

Drinking Water System Operating Authorities: City of Kawartha Lakes and Ontario
Clean Water Agency

Drinking Water System Category: Small Municipal Residential

Reporting Period: January 1 – December 31, 2024



Table of Contents

| | |
|--|----|
| 2024 Annual Drinking Water System Summary Report..... | 3 |
| General Information | 3 |
| Compliance Summary | 3 |
| Drinking Water System Description | 4 |
| Source Water | 4 |
| Water Treatment Facility | 4 |
| Distribution System | 4 |
| Summary of Non-Compliance | 5 |
| Adverse Water Quality Incidents | 5 |
| Non-Compliance..... | 5 |
| Non-Compliance Identified in a Ministry Inspection | 5 |
| Flows | 5 |
| Raw Water Flows | 5 |
| Treated Water Flows | 7 |
| Regulatory Sample Results Summary | 8 |
| Microbiological Testing | 8 |
| Operational Testing | 8 |
| Inorganic Parameters | 8 |
| Schedule 15 Sampling (Lead)..... | 10 |
| Organic Parameters..... | 10 |
| Additional Legislated Samples | 12 |
| Minor Maintenance | 13 |
| Major Maintenance Expense (above \$10,000) | 13 |
| APPENDIX A | 14 |
| WTR Submission Confirmation | 14 |

2024 Annual Drinking Water System Summary Report

General Information

The City of Kawartha Lakes prepares a report summarizing system operation and water quality for every municipal drinking water system annually. This report has been prepared to satisfy the annual reporting requirements in O. Reg. 170/03 Section 11 and Schedule 22. The annual reports will be available to residents at the City of Kawartha Lakes Public Works Administration Office by appointment and the [City's website](#). Notification that the reports are available free of charge will be made on the City of Kawartha Lakes website. The City of Kawartha Lakes Public Works Administration Office is located at 322 Kent Street West in Lindsay, Ontario.

This system does not serve more than 10,000 residences.

Drinking Water System Number: 260075231

Drinking Water System Name: Kinmount Drinking Water System

Drinking Water System Owner: City of Kawartha Lakes

Drinking Water System Category: Small Municipal Residential

Reporting Period: January 1, 2024 – December 31, 2024

Compliance Summary

Table 1. Drinking Water Compliance Summary

| | Number of Events | Date | Details |
|---|------------------|----------------|---|
| Ministry (MECP) Inspections | 1 | April 29, 2024 | 2024/2025 Announced Focused Drinking Water Inspection – Final Inspection Rating of 100% |
| Adverse Water Quality Incidents (AWQIs) | 0 | | |
| Non-Compliances | 0 | | |
| Boil Water Advisories | 0 | | |
| Health and Safety | 0 | | |

Drinking Water System Description

The Kinmount drinking water system is a small municipal residential drinking water system that serves the Village of Kinmount, Ontario. The drinking water system is classified as a Class II Water Treatment and Class I Water Distribution subsystems under O. Reg. 128/04

Source Water

The water supply for the system comes from the Burnt River, which is a surface water source.

Water Treatment Facility

The Kinmount drinking water system consists of a dual train conventional filtration package system. Each train consists of a two stage variable speed flocculator, tube settler clarifier, and one (1) dual media rapid gravity filter. Sodium hypochlorite is used for primary and secondary disinfection. Chlorine contact time is achieved by the use of a twin-cell clearwell. Treated water is directed to the distribution system using four (4) high lift vertical turbine pumps. The backwash wastewater system consists of a concrete settling tank that receives the filter backwash wastewater and clarifier desludging wastes. A composite sampler monitors the supernatant quality before discharging.

A diesel generator is onsite to provide standby power to the water treatment facility in the event of a power failure.

Distribution System

The distribution system has approximately 2.3 kilometers of watermains and is not rated for fire protection. There is no storage, chlorine boosting, secondary disinfection or pressure boosting capabilities within the control of the distribution system. The watermains in the Kinmount Distribution System are all PVC.

Table 2. Treatment Chemicals Used

| Chemical Name | Use | Supplier |
|-----------------------|---------------|------------------------|
| Sodium Hypochlorite | Disinfection | Jutzi Water Technology |
| Polyaluminum Chloride | Flocculation | Univar Solutions |
| Polymer | Flocculation | Basf |
| Sodium Hydroxide | pH Adjustment | Not required in 2024 |

Summary of Non-Compliance

Adverse Water Quality Incidents

There were no adverse water quality incidents reported during the reporting period.

Non-Compliance

There were no non-compliances reported during the reporting period.

Non-Compliance Identified in a Ministry Inspection

There were no non-compliances identified in a Ministry Inspection during this period.


Flows

The Kinmount Drinking Water System is operating on average under half the rated capacity. The rated capacity of the system (treated water flows) is 340 m³/day.


Raw Water Flows

The raw water flows are regulated under the Permit to Take Water. Raw flow data for 2024 was submitted to the Ministry of Environment, Conservation and Parks (MECP) electronically under permit #2447-AWDJEA. The confirmation of the data that was submitted is attached in Appendix A.

Graph 1. Total Monthly Flows (m³/d) – Burnt River (Max Allowable PTTW)




Graph 2. Monthly Rated Flows (L/s) – Burnt River (Max Allowable Rate PTTW)




Treated Water Flows

The Treated Water flows are regulated under the Municipal Drinking Water Licence 141-121.

Graph 3. Monthly Rated Flows (m³/d) – Rated Capacity - MDWL



Graph 4. Annual Total Flow Comparison (m³)



Regulatory Sample Results Summary

Microbiological Testing

Table 3. Microbiological Test Results

| | No. of Samples Collected | Range of E. Coli Results | Range of E. Coli Results | Range of Total Coliform Results | Range of Total Coliform Results | Range of HPC Results | Range of HPC Results |
|---------------------|--------------------------|--------------------------|--------------------------|---------------------------------|---------------------------------|----------------------|----------------------|
| | | Min | Max | Min | Max | Min | Max |
| Raw | 26 | 0 | 23 | 20 | 480 | N/A | N/A |
| Distribution | 53 | 0 | 0 | 0 | 0 | 0 | 1 |

OG = Overgrowth

HPC = Heterotrophic Plate Count

Operational Testing

Table 4. Operational Test Results

| Parameter | Number of Samples Collected | Range of Results Minimum | Range of Results Maximum |
|--|-----------------------------|--------------------------|--------------------------|
| Turbidity Filter 1 (NTU) | 8760 | 0.00 | 1.99 |
| Turbidity Filter 2 (NTU) | 8760 | 0.00 | 1.53 |
| Chlorine | 8760 | 0.00 | 2.39 |
| Fluoride (If the DWS provides fluoridation) | N/A | N/A | N/A |

Note: Record the unit of measurement if it is **not** milligrams per litre.

Note: For continuous monitors 8760 is used as the number of samples. Spikes recorded by online instrumentation were a result of air bubbles and various maintenance/calibration activities. All spikes are reviewed for compliance with O. Reg. 170/03.

Inorganic Parameters

These parameters are tested as a requirement under O. Reg. 170/03. Sodium and Fluoride are required to be tested every five years. Nitrate and Nitrate are tested quarterly and the metals are tested every five years as required under O. Reg. 170/03. In the event any of the parameters listed in Schedule 23 or 24 of O. Reg. 170/03 exceed half of the maximum allowable concentration the parameter is required to be samples quarterly. Based on the latest test results no additional testing is required.

Table 5. Inorganic Parameters Test Results

| | Sample Date (yyyy/mm/dd) | Sample Result | Unit of Measure | MAC | Exceedance |
|------------------------------|-----------------------------|------------------|--------------------|--------|------------|
| Treated Water | | | | | |
| Antimony | 2020 01 06 | <MDL 0.09 | µg/L | 6.0 | No |
| Arsenic | 2020 01 06 | <MDL 0.2 | µg/L | 10.0 | No |
| Barium | 2020 01 06 | 18.5 | µg/L | 1000.0 | No |
| Boron | 2020 01 06 | 5.0 | µg/L | 5000.0 | No |
| Cadmium | 2020 01 06 | <MDL 0.003 | µg/L | 5.0 | No |
| Chromium | 2020 01 06 | 0.28 | µg/L | 50.0 | No |
| Mercury | 2020 01 06 | <MDL 0.01 | µg/L | 1.0 | No |
| Selenium | 2020 01 06 | <MDL 0.04 | µg/L | 50.0 | No |
| Uranium | 2020 01 06 | 0.029 | µg/L | 20.0 | No |
| Additional Inorganics | | | | | |
| Fluoride | 2020 01 06 | <MDL 0.06 | mg/L | 1.5 | No |
| Nitrite | 2024 01 15 | <MDL 0.003 | mg/L | 1.0 | No |
| Nitrite | 2024 04 08 | <MDL 0.003 | mg/L | 1.0 | No |
| Nitrite | 2024 07 02 | <MDL 0.003 | mg/L | 1.0 | No |
| Nitrite | 2024 10 07 | <MDL 0.003 | mg/L | 1.0 | No |
| Nitrate | 2024 01 15 | 0.078 | mg/L | 10.0 | No |
| Nitrate | 2024 04 08 | 0.078 | mg/L | 10.0 | No |
| Nitrate | 2024 07 02 | 0.068 | mg/L | 10.0 | No |
| Nitrate | 2024 10 07 | 0.037 | mg/L | 10.0 | No |
| Sodium | 2020 01 06 | 9.01 | mg/L | 20* | No |

MAC = Maximum Allowable Concentration as per O. Reg. 169/03

MDL = Method Detection Limit

*There is no "MAC" for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. Sodium results exceeding 20 mg/L are to be reported to the Medical Officer of Health as per Schedule 16-3 (8) of O. Reg. 170/03.

Schedule 15 Sampling (Lead)

The Schedule 15 sampling is required under O. Reg. 170/03. This system is under reduced sampling. Only distribution samples were collected, and no plumbing samples were collected.

Table 6. Schedule 15 Test Results (Lead)

| | Number of Sampling Points | Number of Samples | Range of Results Minimum | Range of Results Maximum | MAC (µg/L) | Number of Exceedances |
|-------------------|---------------------------|-------------------|--------------------------|--------------------------|------------|-----------------------|
| Alkalinity (mg/L) | 1 | 2 | 30 | 33 | N/A | N/A |
| pH | 1 | 2 | 7.14 | 7.18 | N/A | N/A |
| Lead (µg/L) | 0 | 0 | | | 10.0 | |

Organic Parameters

These parameters are tested as a requirement under O. Reg. 170/03. In the event any of the parameters listed in Schedule 23 or 24 of O. Reg. 170/03 exceed half of the maximum allowable concentration the parameter is required to be samples quarterly. Based on the latest test results no additional testing is required.

Table 7. Organic Parameters Test Results

| | Sample Date (yyyy/mm/dd) | Sample Result | Unit of Measure | MAC | Exceedance |
|--------------------------------------|--------------------------|---------------|-----------------|-------|------------|
| Treated Water | | | | | |
| Alachlor | 2020 01 06 | <MDL 0.02 | µg/L | 5.0 | No |
| Atrazine + N-dealkylated metabolites | 2020 01 06 | <MDL 0.01 | µg/L | 5.0 | No |
| Azinphos-methyl | 2020 01 06 | <MDL 0.05 | µg/L | 20.0 | No |
| Benzene | 2020 01 06 | <MDL 0.32 | µg/L | 1.0 | No |
| Benzo(a)pyrene | 2020 01 06 | <MDL 0.004 | µg/L | 0.01 | No |
| Bromoxynil | 2020 01 06 | <MDL 0.33 | µg/L | 5.0 | No |
| Carbaryl | 2020 01 06 | <MDL 0.05 | µg/L | 90.0 | No |
| Carbofuran | 2020 01 06 | <MDL 0.01 | µg/L | 90.0 | No |
| Carbon Tetrachloride | 2020 01 06 | <MDL 0.17 | µg/L | 2.0 | No |
| Chlorpyrifos | 2020 01 06 | <MDL 0.02 | µg/L | 90.0 | No |
| Diazinon | 2020 01 06 | <MDL 0.02 | µg/L | 20.0 | No |
| Dicamba | 2020 01 06 | <MDL 0.2 | µg/L | 120.0 | No |

| | Sample Date (yyyy/mm/dd) | Sample Result | Unit of Measure | MAC | Exceedance |
|--|-----------------------------|------------------|--------------------|-------|------------|
| 1,2-Dichlorobenzene | 2020 01 06 | <MDL 0.41 | µg/L | 200.0 | No |
| 1,4-Dichlorobenzene | 2020 01 06 | <MDL 0.36 | µg/L | 5.0 | No |
| 1,2-Dichloroethane | 2020 01 06 | <MDL 0.35 | µg/L | 5.0 | No |
| 1,1-Dichloroethylene | 2020 01 06 | <MDL 0.33 | µg/L | 14.0 | No |
| Dichloromethane (Methylene Chloride) | 2020 01 06 | <MDL 0.35 | µg/L | 50.0 | No |
| 2,4-Dichlorophenol | 2020 01 06 | <MDL 0.15 | µg/L | 900.0 | No |
| 2,4-Dichlorophenoxy acetic acid (2,4-D) | 2020 01 06 | <MDL 0.19 | µg/L | 100.0 | No |
| Diclofop-methyl | 2020 01 06 | <MDL 0.4 | µg/L | 9.0 | No |
| Dimethoate | 2020 01 06 | <MDL 0.06 | µg/L | 20.0 | No |
| Diquat | 2020 01 06 | <MDL 1.0 | µg/L | 70.0 | No |
| Diuron | 2020 01 06 | <MDL 0.03 | µg/L | 150.0 | No |
| Glyphosate | 2020 01 06 | <MDL 1.0 | µg/L | 280.0 | No |
| Malathion | 2020 01 06 | <MDL 0.02 | µg/L | 190.0 | No |
| 2-Methyl- 4chlorophenoxyacetic Acid (MCPA) | | | | | |
| Metolachlor | 2020 01 06 | <MDL 0.01 | µg/L | 50.0 | No |
| Metribuzin | 2020 01 06 | <MDL 0.02 | µg/L | 80.0 | No |
| Monochlorobenzene (Chlorobenzene) | 2020 01 06 | <MDL 0.3 | µg/L | 80.0 | No |
| Paraquat | 2020 01 06 | <MDL 1.0 | µg/L | 10.0 | No |
| PCB | 2020 01 06 | <MDL 0.04 | µg/L | 3.0 | No |
| Pentachlorophenol | 2020 01 06 | <MDL 0.15 | µg/L | 60.0 | No |
| Phorate | 2020 01 06 | <MDL 0.01 | µg/L | 2.0 | No |
| Picloram | 2020 01 06 | <MDL 1.0 | µg/L | 190.0 | No |
| Prometryne | 2020 01 06 | <MDL 0.03 | µg/L | 1.0 | No |
| Simazine | 2020 01 06 | <MDL 0.01 | µg/L | 10.0 | No |
| Terbufos | 2020 01 06 | <MDL 0.01 | µg/L | 1.0 | No |
| Tetrachloroethylene | 2020 01 06 | <MDL 0.35 | µg/L | 10.0 | No |
| 2,3,4,6- Tetrachlorophenol | 2020 01 06 | <MDL 0.2 | µg/L | 100.0 | No |
| Triallate | 2020 01 06 | <MDL 0.01 | µg/L | 230.0 | No |
| Trichloroethylene | 2020 01 06 | <MDL 0.44 | µg/L | 5.0 | No |
| 2,4,6-Trichlorophenol | 2020 01 06 | <MDL 0.25 | µg/L | 5.0 | No |
| Trifluralin | 2020 01 06 | <MDL 0.02 | µg/L | 45.0 | No |
| Vinyl Chloride | 2020 01 06 | <MDL 0.17 | µg/L | 1.0 | No |
| Distribution Water | | | | | |
| Trihalomethane Total Annual Average Q1 | 2024 01 15 | 76.75 | µg/L | 100.0 | No |

| | Sample Date (yyyy/mm/dd) | Sample Result | Unit of Measure | MAC | Exceedance |
|--|-----------------------------|------------------|--------------------|-------|------------|
| Trihalomethane Total Annual Average Q2 | 2024 04 08 | 79.5 | µg/L | 100.0 | No |
| Trihalomethane Total Annual Average Q3 | 2024 07 02 | 84.5 | µg/L | 100.0 | No |
| Trihalomethane Total Annual Average Q4 | 2024 10 07 | 83.5 | µg/L | 100.0 | No |
| HAA Total Annual Average Q1 | 2024 01 15 | 62.68 | µg/L | 80.0 | No |
| HAA Total Annual Average Q2 | 2024 04 08 | 65.85 | µg/L | 80.0 | No |
| HAA Total Annual Average Q3 | 2024 07 02 | 64.43 | µg/L | 80.0 | No |
| HAA Total Annual Average Q4 | 2024 10 07 | 66.85 | µg/L | 80.0 | No |

MAC = Maximum Allowable Concentration as O. Reg. 169/03

MDL = Method Detection Limit

Additional Legislated Samples

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Harmful Algal Blooms monitoring is required as a condition within the Municipal Drinking Water Licence between June and October of each reporting year at a minimum. Treated and Raw samples are collected weekly during this time period and tested for Microcystin, which is an indicator for harmful algal blooms.

Table 8. Microcystin Sample Results

| Municipal Drinking Water Licence | Collected Weekly June – Oct | Total Microcystin Raw Results Range (µg/L) | Total Microcystin Treated Water Results Range (µg/L) | Treated Water Total Microcystin Limit 1.5 µg/L Exceeded |
|----------------------------------|-----------------------------|--|--|---|
| Harmful Algal Blooms Monitoring | June | <0.1 - <0.1 | <0.1 - <0.1 | N |
| | July | <0.1 - <0.1 | <0.1 - <0.1 | N |
| | August | <0.1 - <0.1 | <0.1 - <0.1 | N |
| | September | <0.1 - <0.1 | <0.1 - <0.1 | N |
| | October | <0.1 - <0.1 | <0.1 - <0.1 | N |

Method Detection Limit is 0.1 µg/L

Table 9. Suspended Solids Sample Results

| Municipal Drinking Water Licence | Date Collected | Suspended Solids to Sanitary Sewer (mg/L) | Free Chlorine Residual (mg/L) |
|----------------------------------|----------------|---|-------------------------------|
| Settling Tank Discharge Point | January | <2 | 0.02 |
| | February | <2 | 0.01 |
| | March | 5 | 0.01 |
| | April | <2 | 0.02 |
| | May | 6 | 0.02 |
| | June | <2 | 0.01 |
| | July | <2 | 0.02 |
| | August | <2 | 0.00 |
| | September | <2 | 0.03 |
| | October | <2 | 0.01 |
| | November | 5 | 0.02 |
| | December | <2 | 0.04 |
| | Average | 2.83 | |

Note: The Suspended Solids 12 month running average limit is 25 mg/L.

Minor Maintenance

- Mixer installed
- Dehumidifier repairs
- Replace blower #1
- AC breaker installed




Major Maintenance Expense (above \$10,000)

Under Section 11 of O. Reg. 170/03, a description of any major expenses incurred during this reporting period to install, repair or replace required equipment must be included in the annual report. The details of the major expenses for this drinking water system are as follows:

Nothing to report for the reporting period.

APPENDIX A

WTR Submission Confirmation



Ministry of the Environment,
Conservation and Parks

| [WT DATA](#) | [USER PROFILE](#) | [CONTACT US](#) | [HELP](#) | [HOME](#) | [LOGOUT](#) |

Location: [WTRS](#) / [WT DATA](#) / [Input WT Record](#) WTRS-WT-008

Water Taking Data submitted successfully.

Confirmation:


Thank you for submitting your water taking data online.

Permit Number: 2447-AWDJEA
Permit Holder: THE CORPORATION OF THE CITY OF KAWARTHA LAKES.
Received on: Feb 19, 2025 10:34 AM

This confirmation indicates that your data has been received by the Ministry, but should not be construed as acceptance of this data if it differs from that specified on the Permit Number, assigned to the Permit Holder stated above.

[Print Confirmation](#) [Return to Main Page](#)

CITY OF KAWARTHA LAKES | 2025/02/19
version: v4.5.0.21 (build#: 22)
Last modified: 2018/09/18

 This site maintained by
the Government of Ontario

©2025 [Queen's Printer for Ontario](#)