



NOTES:

1. YARD HYDRANTS TO CONFORM TO APPROVED "MANUFACTURERS LIST" OF LEAD FREE YARD HYDRANTS.
2. YARD HYDRANTS ARE TO BE INSTALLED WITH A MINIMUM 1.0m CLEARANCE TO ALL INFRASTRUCTURE INCLUDING SIDEWALK AND DRIVEWAYS.



ENGINEERING & CORPORATE
ASSETS

19mmØ YARD HYDRANT

CHECKED: JN

APPROVED: CS

APPROVED DATE: AUGUST 2017

CKL-109

SCALE: NOT TO SCALE

DATE: AUGUST 2017

REVISION No. 1