

King's Bay Environmental Centre

Works # 110003665

Annual Wastewater Performance Report

Prepared For: The City of Kawartha Lakes

Reporting Period of January 1st – December 31st, 2023

Issued: March 28, 2024

Revision: 0

Operating Authorities:



2023 Performance Report for King's Bay Environmental Centre

The King's Bay Environmental Centre, unless noted within this report, complies with all requirements of the regulating authorities and operates under:

- Environmental Compliance Approval (ECA) No. 7037-A77JLP issued February 16, 2016
- Environmental Compliance Approval (ECA) No. 141-W601 issued June 20, 2023

The Environmental Compliance Approval Number 7037-A77JLP, for the King's Bay Environmental Centre, stipulates that the operating authority for the following conditions shall maintain annual records:

Section 10 - Reporting (6)

- (a) a summary and interpretation of all monitoring data and a comparison to the effluent limits outlined in Condition 7, including an overview of the success and adequacy of the Works;
- (b) a description of any operating problems encountered and corrective actions taken;
- (c) a summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming a part of the Works;
- (d) a summary of any effluent quality assurance or control measures undertaken in the reporting period;
- (e) a summary of the calibration and maintenance procedures conducted on all monitoring equipment; and
- (f) a description of efforts made and results achieved in meeting the Effluent Objectives of Condition 6.
- (g) a tabulation of the volume of sludge generated in the reporting period and an outline of anticipated volumes to be generated in the next reporting period and a summary of the locations to where the sludge was disposed;
- (h) a summary of any complaints received during the reporting period and any steps taken to address the complaints;
- (i) a summary of all by-pass, spill or abnormal discharge events;
- (j) a copy of all Notice of Modifications submitted to the Water Supervisor as a result of Schedule B, Section 1, with a status report on the implementation of each modification;

- (k) a report summarizing all modifications completed as a result of Schedule B, Section 3; and
- (l) any other information the Water Supervisor requires from time to time.

The Environmental Compliance Approval Number 141-W601 for the City of Kawartha Lakes Wastewater Collection System, including the King's Bay Environmental Sewage Collection System, stipulates that the Owner shall prepare an annual performance report for the Authorized System and includes:

Schedule E – Reporting (4.6)

- a) a summary of all required monitoring data along with an interpretation of the data and any conclusion drawn from the data evaluation about the need for future modifications to the Authorized System or system operations.
- b) a summary of any operating problems encountered and corrective actions taken.
- c) a summary of all calibration, maintenance, and repairs carried out on any major structure, Equipment, apparatus, mechanism, or thing forming part of the Municipal Sewage Collection System.
- d) a summary of any complaints related to the Sewage Works received during the reporting period and any steps taken to address the complaints.
- e) a summary of all Alterations to the Authorized System within the reporting period that are authorized by this Approval including a list of Alterations that pose a Significant Drinking Water Threat.
- f) a summary of all Collection System Overflow(s) and Spill(s) of Sewage, including:
 - i. Dates;
 - ii. Volumes and durations;
 - iii. If applicable, loadings for total suspended solids, BOD, total phosphorus, and total Kjeldahl nitrogen, and sampling results for E.coli;
 - iv. Disinfection, if any; and
 - v. Any adverse impact(s) and any corrective actions, if applicable.
- g) a summary of efforts made to reduce Collection System Overflows, Spills, STP Overflows, and/or STP Bypasses, including the following items, as applicable:
 - i. A description of projects undertaken and completed in the Authorized System that result in overall overflow reduction or elimination including expenditures and proposed projects to eliminate overflows with estimated budget forecast for the year following that for which the report is submitted.
 - ii. Details of the establishment and maintenance of a PPCP, including a summary of project progresses compared to the PPCP's timelines.
 - iii. An assessment of the effectiveness of each action taken.
 - iv. An assessment of the ability to meet Procedure F-5-1 or Procedure F-5-5 objectives (as applicable) and if able to meet the objectives, an overview of next steps and estimated timelines to meet the objectives.
 - v. Public reporting approach including proactive efforts

Environmental Compliance Approval (ECA) No. 7037-A77JLP

The following is a report from the records maintained by the Ontario Clean Water Agency for the King's Bay Environmental Centre for the year 2023.

(a) Attached, as **Appendix I**, is a copy of the 2023 **Performance Assessment Report (PAR)** for the King's Bay Environmental Centre showing effluent criteria. The PAR contains: a tabulation of all monthly average raw sewage and final effluent sample results obtained during the reporting period, a tabulation of average daily flows, and monthly volumes for the reporting period, and a tabulation of calculated total loading of BOD, suspended solids, total phosphorus, and ammonia + ammonium as nitrogen concentrations in the final effluent.

Attached as **Appendix II: Groundwater Monitoring**, are the results of the groundwater monitoring as required by the Environmental Compliance Approval – Table 3.

The following table summarizes the average concentration and annual average loading of the effluent parameters CBOD₅, Total Suspended Solids, Total Phosphorus, and pH in comparison to the effluent limits and objectives specified by the Environmental Compliance Approval. Attached in **Appendix III**, a summary of the final effluent pH and temperature recorded at the facility. The recording frequency required by the Environmental Compliance Approval is monthly.

Table 1 outlines the effluent criteria limits as set out in Section 7(1) of Environmental Compliance Approval Number 7037-A77JLP as follows:

Table 1: Final Effluent Compliance Limits 2023

Effluent Parameters (Column 1)	Average Effluent Concentration limit (mg/L) (Column 2)	Actual Annual Average Effluent Concentration (mg/L)	Compliant (Y/N)	Average Total Effluent Loading Limit (kg/d) (Column 3)	Actual Annual Average Effluent Loading (kg/d)	Compliant (Y/N)
CBOD ₅	15.0	7.33	Y	N/A	N/A	N/A
Total Suspended Solids	15.0	12.88	Y	N/A	N/A	N/A
Total Phosphorus	1.0	0.26	Y	0.17	0.01	Y

King's Bay Environmental Centre – 2023 Performance Report

Effluent Parameters (Column 1)	Average Effluent Concentration limit (mg/L) (Column 2)	Actual Annual Average Effluent Concentration (mg/L)	Compliant (Y/N)	Average Total Effluent Loading Limit (kg/d) (Column 3)	Actual Annual Average Effluent Loading (kg/d)	Compliant (Y/N)
pH	6.0 to 9.0, inclusive, at all times	7.57	Y	N/A	N/A	N/A

Note:

Condition 7(2) states that for the purposes of determining compliance with and enforcing subsection (1):

(a) The Annual Average Concentration of CBOD5 and Total Suspended Solids named in Column 1 of subsection (1) shall not exceed the corresponding maximum concentration set out in Column 2 of subsection (1).

(b) The Annual Average Loading of a parameter named in Column 1 of subsection (1) shall not exceed the corresponding maximum waste loading set out in Column 3 of subsection (1).

The maximum raw flow into the facility was 82.59 m³/d, which occurred in April 2023. This is well below the allowable peak flow rate of approximately 666.0 m³/d and is also well below the rated capacity of 170.0 m³/d listed in the Environmental Compliance Approval. The average daily flow for 2023 was 46.39 m³/d.

ECA Condition 6(2)(b) states: “The Owner shall use best efforts to operate the works within the Rated Capacity of the Works.” Rated Capacity is defined as Average Daily Flow for which the Works are approved to handle. Table 2 provides a summary of the average daily influent flows in comparison with the rated capacity of 170.0 m³/day.

Table 2: Effluent Objectives Influent Flow Data for 2023 (per ECA # 7037-A77JLP, Condition 6(2)(b))

Month	Avg. Daily Flow (m ³)	ECA Rated Capacity (m ³)	Compliant (Y/N)
January	47.09	170.0	Y
February	45.91	170.0	Y
March	47.43	170.0	Y
April	58.36	170.0	Y
May	55.55	170.0	Y
June	49.43	170.0	Y
July	44.31	170.0	Y
August	42.25	170.0	Y
September	41.35	170.0	Y
October	43.24	170.0	Y

King's Bay Environmental Centre – 2023 Performance Report

Month	Avg. Daily Flow (m ³)	ECA Rated Capacity (m ³)	Compliant (Y/N)
November	39.11	170.0	Y
December	42.73	170.0	Y


Table 3 provides a summary of the average daily effluent flows in comparison with the rated capacity of 170.0 m³/day.

Table 3: Effluent Objectives Effluent Flow Data for 2023 (per ECA # 7037-A77JLP, Condition 6(2)(b))

Month	Avg. Daily Flow (m ³)	ECA Rated Capacity (m ³)	Compliant (Y/N)
January	45.80	170.0	Y
February	43.74	170.0	Y
March	44.82	170.0	Y
April	54.71	170.0	Y
May	53.96	170.0	Y
June	45.77	170.0	Y
July	41.87	170.0	Y
August	40.95	170.0	Y
September	37.41	170.0	Y
October	41.32	170.0	Y
November	37.75	170.0	Y
December	38.84	170.0	Y

Graph 1 provides a summary of the annual total effluent flows from 2013 to the 2023 reporting period.

Graph 1: Annual Total Effluent Flow Comparison



The final effluent quality for total phosphorus was well below the limits set in the Environmental Compliance Approval. The annual average concentration for total phosphorus was 0.26 mg/L (limit of 1.0 mg/L) and the annual average loading for total phosphorus was 0.01 kg/d (limit of 0.17 kg/d based on design average day flow of 170.0 m³/d).

The pH of the effluent ranged from 7.16 to 7.96, which are within the range of 6.0 – 9.0 required by the Environmental Compliance Approval.

The total suspended solids effluent objective was not met but the limit was met in 2023. The annual effluent average of 12.88 mg/L exceeded the objective of 10.0 mg/L but met the limit of 15.0 mg/L.

The carbonaceous biochemical oxygen demand effluent objective and limit was met in 2023. The annual effluent average of 7.33 mg/L met the objective of 10.0 mg/L and met the limit of 15.0 mg/L.

During the reporting period, work continued to bring and keep the system in compliance. Adjustments to the system include: alum dosage, the timers on the return sludge system to optimize the return rate, and removal of sludge from the system by a licensed waste hauler to lower the solids build-up. The facility operators continued to closely monitor the process and make necessary adjustments as required.

Groundwater Monitoring Wells

The well levels were measured once in Quarter 1, 2, 3 and 4 of 2023. The well levels for the eight groundwater monitoring wells are found in **Appendix IV: Groundwater Monitor Wells - Levels**.

King's Bay Environmental Centre – 2023 Performance Report

The groundwater quality monitoring in the eight monitoring wells (**Appendix II**) show consistent results with few anomalies for pH, conductivity, CBOD, total phosphorous, total suspended solids, nitrite, nitrate, and nitrate + nitrite.

The Provincial Water Quality Objective for pH is 6.5 – 8.5 and all samples collected from the eight monitoring wells fell within this range. The Provincial Water Quality Objectives does not outline objectives or interim objectives for any of the remaining parameters.

The Amended ECA issued February 16, 2016 has changed the groundwater monitoring to Quarterly water levels and semi-annually samples for: pH, Conductivity, Total Phosphorous, Nitrate Nitrogen, Total Suspended Solids and CBOD5. It also specifies that Total Phosphorous is to be a field filtered grab sample. The trigger value is a concentration of 0.3 mg/L in either GW1 or GW8.

The following table (Table 4) shows the performance related to groundwater.

Table 4: Groundwater Well Monitoring Performance for Total Phosphorous

Well #	March 2023	September 2023
Up gradient	mg/L	mg/L
Well 5	0.012	0.007
Well 4	0.01	<0.003
Down gradient	mg/L	mg/L
East trench		
Well 3 (5m)	0.064	0.015
Well 2 (10m)	0.014	<0.003
Well 1 (15m)	0.008	0.014
West trench		
Well 6 (5m)	0.011	<0.003
Well 7 (10m)	0.009	<0.003
Well 8 (15m)	0.033	<0.003

Shading indicates a result > 0.3mg/L

(b) The facility has experienced a number of challenges over the past few years, primarily with breakdowns of the rotating biological contactors (RBC). This has historically affected the effluent quality. During the reporting period, both RBC units continued to function as designed. Adjustments to the system include: alum dosage, the timers on the return sludge system to optimize the return rate, and removal of sludge from the system by a licensed waste hauler to lower the solids build-up. The operators are continuing to closely monitor the process and make necessary adjustments as required.

(c) Ontario Clean Water Agency (OCWA) maintenance activities are based on a computerized Work Management System (WMS) using the Maximo application. In its developmental stages, each piece of equipment at the operating facility was tagged with a unique bar code number, and this information was entered into the electronic WMS database. In addition, data regarding the description of the equipment, model number, serial number, the equipment type, location at the facility as related to process, serviceable status, manufacturer's suggested maintenance activities, all risk factor information and average monthly usage was also recorded.

Once the equipment inventory was established, preventive maintenance procedures and schedules were developed for each piece of equipment. Each work order generated by the Preventive Maintenance schedule includes materials and parts required, any special tool requirements, work protection, job safety planning, running checks, a preventive maintenance job procedure, and upon completion of the task, the work order is closed out.

Corrective or breakdown maintenance is required when equipment is determined to be non-serviceable, or the potential for non-serviceability exists. All preventive and corrective/breakdown maintenance in OCWA and more specifically the King's Bay Environmental Centre is executed and accounted for under a Maximo work order.

Attached is **Appendix V: Maintenance Summary**, a Work Order Summary report, showing all preventive and corrective maintenance activities performed at the King's Bay Environmental Centre during 2023.

(d) Effluent control measures include in-house sampling and testing for operational parameters such as suspended solids, pH, phosphorus, and temperature. In-house testing provides real time results, which are then evaluated to determine if process changes are necessary to enhance operational performance. All in-house sampling and analysis are performed by certified operations staff utilizing approved methods and protocols for sampling, analysis and recording as specified in the Ministry's Procedure F-10-1, "Procedures for Sampling and Analysis Requirements for Municipal and Private Sewage Treatment Works", the Ministry's publication, "Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater" and the publication, "Standard Methods for the Examination of Water and Wastewater".

All final effluent samples collected during the reporting period to meet ECA sampling requirements were submitted to SGS Lakefield Research Ltd. laboratory for analysis, with the exception of pH and temperature. SGS Lakefield Research has been deemed accredited by the Canadian Association for Laboratory Accreditation (CALA), meeting strict provincial guidelines including an extensive quality assurance/quality control program. By choosing this laboratory, the Ontario Clean Water Agency is ensuring appropriate control measures are undertaken during sample analysis. The pH and temperature parameters were analyzed in the field at the time of sample collection by certified operators, to ensure accuracy and precision of the results obtained.

(e) Flow meter calibrations were conducted on June 28, 2023. The reports are attached as **Appendix VI: Calibration Reports**.

(f) OCWA uses a number of **Efforts to achieve the Effluent Objectives**. Effluent quality assurance and control measures include in-house sampling and testing for operational parameters such as pH, temperature, TSS and phosphorous. In-house testing provides real time results, which are then used to enhance process and operational performance. OCWA also collects raw sewage and effluent samples as per the ECA and reviews these results on a regular basis to ensure compliance with the ECA objectives and limits.

Table 5 provides a summary of the ECA effluent objectives, specified in Condition 6(1), in comparison to the actual effluent results obtained during the reporting period.

Table 5: Effluent Objectives and Results – 2023

Effluent Parameters	ECA - Effluent Objective Concentration	Actual Annual Average Concentration in Effluent	Compliant (Y/N)
CBOD ₅	10.0 mg/L	7.33	Y
Total Suspended Solids	10.0 mg/L	12.88	N
Total Phosphorus	0.8 mg/L	0.26	Y
pH	6.5 - 9.0	7.57	Y

The effluent objectives for CBOD₅, Total Suspended Solids, Total Phosphorus and pH in the effluent are recommended not to exceed: 10.0 mg/L, 10.0 mg/L, 0.8 mg/L and range of pH between 6.5 – 9.0 respectively. The annual average effluent objective concentrations for CBOD₅, Total Phosphorus and pH were met during the 2023 reporting period. The annual average effluent objective concentration for Total Suspended Solids was not met during the 2023 reporting period. The Annual Average for TSS was 12.88 mg/L which exceeded the objective of 10.0 mg/L but met the limit of 15.0 mg/L. The objectives were met for all other parameters.

OCWA has developed comprehensive manuals detailing operations, maintenance, instrumentation and emergency procedures. To ensure facilities are operated in compliance with applicable legal requirements, facility staff have access to a network of operational compliance and support experts at the Hub, Region and Corporate level.

Appendix VII contains a summary of the coagulant used in 2023.

(g) Attached as **Appendix VIII: Biosolids Summary** that contains the volume of sludge generated for the reporting period which was 309.98 m³. The anticipated volume for the next reporting period is not expected to be appreciably different from this reporting period. Sludge is hauled to the Lindsay Water Pollution Control Plant. No change is expected from the current sludge handling methods.

- (h) There were zero (0) **Community Complaints** received regarding the King's Bay Environmental Centre during the reporting period.
- (i) **Bypass, spill and abnormal discharge event summary:** None to report.
- (j) **Notices of Modifications:** None to report.
- (k) **Report Summarizing all Modifications:** A summary of all modifications completed as a result of Schedule B, Section 3 are included in **Appendix V: Maintenance Summary**.
- (l) **Additional information the Water Supervisor requires:** None to report.

Environmental Compliance Approval (ECA) No. 141-W601

4.6 (a) a summary of all required monitoring data along with an interpretation of the data and any conclusion drawn from the data evaluation about the need for future modifications to the Authorized System or system operations.

The King's Bay Environmental Sewage Collection System consists of works for the collection and transmission of sewage, comprising approximately 1.5 km of sanitary sewer piping that discharges to the King's Bay Environmental Centre.

There are no required monitoring data requirements for the King's Bay Environmental Sewage Collection System.

4.6 (b) a summary of any operating problems encountered and corrective actions taken.

There were no operating problems encountered in 2023 for the King's Bay Environmental Sewage Collection System.

4.6 (c) a summary of all calibration, maintenance, and repairs carried out on any major structure, Equipment, apparatus, mechanism, or thing forming part of the Municipal Sewage Collection System.

A regular scheduled calibration and maintenance program has been kept up to date as scheduled on a daily, weekly, semi-annual and annual basis. All equipment calibration & maintenance scheduling and standard procedures are provided by Maximo Computerized Maintenance System.

Attached is **Appendix V: Maintenance Summary**, a Work Order Summary report, showing all preventive and corrective maintenance activities performed at the King's Bay Environmental Centre, including the sewage collection system, during 2023.

There was no additional repairs or maintenance carried out on any of the linear infrastructure in 2023.

4.6 (d) a summary of any complaints related to the Sewage Works received during the reporting period and any steps taken to address the complaints.

Complaints related to the King's Bay Environmental Sewage Collection System and steps taken to address the complaints are included in Section (h) for 2023.

4.6 (e) a summary of all Alterations to the Authorized System within the reporting period that are authorized by this Approval including a list of Alterations that pose a Significant Drinking Water Threat.

There were no Alterations made to the King's Bay Environmental Sewage Collection System in 2023.

4.6 (f) a summary of all Collection System Overflow(s) and Spill(s) of Sewage, including:

- i) Dates;**
- ii) Volumes and durations;**
- iii) If applicable, loadings for total suspended solids, BOD, total phosphorus, and total Kjeldahl nitrogen, and sampling results for E.coli;**
- iv) Disinfection, if any; and**
- v) Any adverse impact(s) and any corrective actions, if applicable.**

The King's Bay Environmental Sewage Collection system did not experience any collection system Overflows or Spills in 2023.

4.6 (g) a summary of efforts made to reduce Collection System Overflows, Spills, STP Overflows, and/or STP Bypasses, including the following items, as applicable:

- i) A description of projects undertaken and completed in the Authorized System that result in overall overflow reduction or elimination including expenditures and proposed projects to eliminate overflows with estimated budget forecast for the year following that for which the report is submitted.**

The City of Kawartha Lakes continues to work on a Master Servicing Study and Capacity Assessment for all facilities analyzing existing capacity and future growth requirements. Sanitary sewer flushing is conducted on an annual basis (3 years of dead ends/trouble areas and 4th year is full system flush). During this program, any manholes with infiltration issues are identified and are included in operational maintenance contracts for grouting, frame and cover replacements, etc.

In addition, where manholes are located in lower lying areas and are at risk of being submerged and contributing to inflow, rain bladders are installed to prevent excess water from entering the system, further reducing the risk of overflow.

The King's Bay wastewater collection system infrastructure is relatively new and does experience excessive infiltration and inflow which could contribute to potential overflows. No deficiencies were identified in 2023.

ii) Details of the establishment and maintenance of a PPCP, including a summary of project progresses compared to the PPCP's timelines.

The King's Bay Environmental Sewage Collection system does not contain combined sewers and therefore is not required to complete a Pollution Prevention and Control Plan (PPCP).

iii) An assessment of the effectiveness of each action taken.

None to report.

iv) An assessment of the ability to meet Procedure F-5-1 or Procedure F-5-5 objectives (as applicable) and if able to meet the objectives, an overview of next steps and estimated timelines to meet the objectives.

N/A

v) Public reporting approach including proactive efforts

SOP WWC02 Wastewater Bypass/Overflow Notification Procedure has been developed and has been in practice since 2021, which clearly outlines all reporting protocols to both regulatory agencies and the public in various situations. This procedure was developed in consultation with Ontario Clean Water Agency, Ministry of Environment, Conservation and Parks and Ministry of Health.



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Appendix I:
Performance Assessment Report



Performance Assessment Report

From 1/1/2023 to 12/31/2023 11:59:59 PM

5318 KING'S BAY WASTEWATER TREATMENT FACILITY 110003665

Criteria	1 / 2023	2/ 2023	3/ 2023	4/ 2023	5/ 2023	6/ 2023	7/ 2023	8/ 2023	9/ 2023	10/ 2023	11/ 2023	12/ 2023	Total	Avg	Max
----------	----------	---------	---------	---------	---------	---------	---------	---------	---------	----------	----------	----------	-------	-----	-----

Flows

1,459.66	1,285.60	1,470.40	1,750.83	1,722.05	1,482.79	1,373.70	1,309.60	1,240.42	1,340.39	1,173.27	1,324.48	16,933.21		0.00
47.09	45.91	47.43	58.36	55.55	49.43	44.31	42.25	41.35	43.24	39.11	42.73	46.39		170.00
59.58	59.25	71.03	82.59	72.89	67.75	49.94	50.62	48.83	54.75	45.49	53.68		82.59	0.00
31.00	28.00	31.00	30.00	31.00	30.00	31.00	31.00	30.00	31.00	30.00	31.00	365.00		0.00
1,419.76	1,224.95	1,389.40	1,641.43	1,672.70	1,373.06	1,297.92	1,269.56	1,122.24	1,281.06	1,132.38	1,204.07	16,028.43		0.00
45.80	43.74	44.82	54.71	53.96	45.77	41.87	40.95	37.41	41.32	37.75	38.84	43.91		170.00
57.49	57.54	69.59	78.70	71.01	60.20	49.39	49.87	45.62	52.23	43.71	50.81		78.70	0.00
31.00	28.00	31.00	30.00	31.00	30.00	31.00	31.00	30.00	31.00	30.00	31.00	365.00		0.00

Carbonaceous Biochemical Oxygen Demand: CBOD

	5.60	<	3.50	<	3.25			3.75	<	3.80		6.00		11.40			13.00		14.25	<	8.20	<	5.75	<	7.25		7.33		14.25		15.00
	5.00		4.00		4.00			4.00		5.00		4.00		5.00			4.00		4.00		5.00		4.00		4.00						0.00

Biochemical Oxygen Demand: BOD5

[illegible]

Total Suspended Solids: TSS

2,180.00		102.00		302.00		1,380.00		97.00		605.00		144.00		145.00		5,460.00		1,630.00		211.00		260.00		1,043.00		5,460.00		0.00
	1.00	1.00		1.00		1.00		1.00		1.00		1.00		1.00		1.00		1.00		1.00		1.00		12.00			0.00	
	6.60	6.00		6.00		5.75		6.00		8.25		16.00		20.75		25.50		18.20		12.50		23.00		12.88		25.50	15.00	
	5.00	4.00		4.00		4.00		5.00		4.00		5.00		4.00		4.00		5.00		4.00		4.00		52.00			0.00	

Total Phosphorus: TP

[illegible]

Nitrogen Series

[illegible]



Performance Assessment Report

From 1/1/2023 to 12/31/2023 11:59:59 PM

[illegible]

Disinfection

[illegible]



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Appendix II:
Groundwater Monitoring

Facility Org Number: 5318
Facility Works Number: 110003665
Facility Name: KING'S BAY WASTEWATER TREATMENT FACILITY
Facility Owner: Municipality: City of Kawartha Lakes
Facility Classification: Class 2 Wastewater Treatment
Receiver: Subsurface
Service Population: 200.0
Total Design Capacity: 170.0 m3/day

	01/2023	02/2023	03/2023	04/2023	05/2023	06/2023	07/2023	08/2023	09/2023	10/2023	11/2023	12/2023	Total	Avg	Max	Min
Monitoring Well 1 / Carbonaceous Biochemical Oxygen Demand: CBOD5 - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			< 4						< 4						< 4	
Mean Lab																
Min Lab			< 4						< 4						4	
Monitoring Well 1 / Conductivity - µS/cm																< 4
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			884						1160						1160	
Mean Lab			884						1160						1022	
Min Lab			884						1160							884
Monitoring Well 1 / Nitrate + Nitrite as N: NO3-N + NO2-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			3.98						5.18						5.18	
Mean Lab			3.98						5.18						4.58	
Min Lab			3.98						5.18							3.98
Monitoring Well 1 / Nitrate as N: NO3-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			3.98						5.18						5.18	
Mean Lab			3.98						5.18						4.58	
Min Lab			3.98						5.18							3.98
Monitoring Well 1 / Nitrite as N: NO2-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			< 0.03						< 0.03						< 0.03	
Mean Lab			< 0.03						< 0.03						< 0.03	
Min Lab			< 0.03						< 0.03							0.03
Monitoring Well 1 / Total Phosphorus: TP - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			0.008						0.014						0.014	
Mean Lab			0.008						0.014						0.011	
Min Lab			0.008						0.014							0.008
Monitoring Well 1 / Total Suspended Solids: TSS - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			370						339						370	
Mean Lab			370						339						354.5	
Min Lab			370						339							339
Monitoring Well 1 / pH - ---																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			8.05						7.5						8.05	
Mean Lab			8.05						7.5						7.775	
Min Lab			8.05						7.5							7.5

From: 01/01/2023 to 31/12/2023

5318
110003665
KING'S BAY WASTEWATER TREATMENT FACILITY
Municipality: City of Kawartha Lakes
Class 2 Wastewater Treatment
Subsurface
200.0
170.0 m3/day

Facility Org Number:
Facility Works Number:
Facility Name:
Facility Owner:
Facility Classification:
Receiver:
Service Population:
Total Design Capacity:

	01/2023	02/2023	03/2023	04/2023	05/2023	06/2023	07/2023	08/2023	09/2023	10/2023	11/2023	12/2023	Total	Avg	Max	Min
Monitoring Well 2 / Carbonaceous Biochemical Oxygen Demand: CBOD5 - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			< 4						< 4						< 4	
Mean Lab									< 4							
Min Lab			< 4						< 4							< 4
Monitoring Well 2 / Conductivity - µS/cm																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			1880						1960						1960	
Mean Lab			1880						1960						1920	
Min Lab			1880						1960							1880
Monitoring Well 2 / Nitrate + Nitrite as N: NO3-N + NO2-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			15.1						14.9						15.1	
Mean Lab			15.1						14.9						15	
Min Lab			15.1						14.9							14.9
Monitoring Well 2 / Nitrate as N: NO3-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			15.1						14.9						15.1	
Mean Lab			15.1						14.9						15	
Min Lab			15.1						14.9							14.9
Monitoring Well 2 / Nitrite as N: NO2-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			< 0.03						< 0.03						< 0.03	
Mean Lab			< 0.03						< 0.03						< 0.03	
Min Lab			< 0.03						< 0.03							< 0.03
Monitoring Well 2 / Total Phosphorus: TP - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			0.014						< 0.003						< 0.014	
Mean Lab			0.014						< 0.003						< 0.009	
Min Lab			0.014						< 0.003							< 0.003
Monitoring Well 2 / Total Suspended Solids: TSS - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			334						138						334	
Mean Lab			334						138						236	
Min Lab			334						138							138
Monitoring Well 2 / pH - ---																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			8.05						7.49						8.05	
Mean Lab			8.05						7.49						7.77	
Min Lab			8.05						7.49							7.49

5318
110003665
KING'S BAY WASTEWATER TREATMENT FACILITY
Municipality: City of Kawartha Lakes
Class 2 Wastewater Treatment
Subsurface
200.0
170.0 m3/day

Facility Org Number:
Facility Works Number:
Facility Name:
Facility Owner:
Facility Classification:
Receiver:
Service Population:
Total Design Capacity:

		01/2023	02/2023	03/2023	04/2023	05/2023	06/2023	07/2023	08/2023	09/2023	10/2023	11/2023	12/2023	Total	Avg	Max	Min
Monitoring Well 3 / Carbonaceous Biochemical Oxygen Demand: CBOD5 - mg/L																	
Count Lab	0	0												2			
Max Lab			< 4							< 4						< 4	
Mean Lab																	
Min Lab			< 4							< 4							4
Monitoring Well 3 / Conductivity - µS/cm																	
Count Lab	0	0															
Max Lab														2			
Mean Lab			2290							2340						2340	
Min Lab			2290							2340							2290
Monitoring Well 3 / Nitrate + Nitrite as N: NO3-N + NO2-N - mg/L																	
Count Lab	0	0												2			
Max Lab			14.6							16.9						16.9	
Mean Lab			14.6							16.9							
Min Lab			14.6							16.9							14.6
Monitoring Well 3 / Nitrate as N: NO3-N - mg/L														2			
Count Lab	0	0															
Max Lab			14.6							16.9						16.9	
Mean Lab			14.6							16.9							
Min Lab			14.6							16.9							14.6
Monitoring Well 3 / Nitrite as N: NO2-N - mg/L																	
Count Lab	0	0												2			
Max Lab			< 0.03							< 0.03						< 0.03	
Mean Lab			< 0.03							< 0.03							
Min Lab			< 0.03							< 0.03							0.03
Monitoring Well 3 / Total Phosphorus: TP - mg/L																	
Count Lab	0	0												2			
Max Lab			0.064							0.015						0.064	
Mean Lab			0.064							0.015							
Min Lab			0.064							0.015							0.015
Monitoring Well 3 / Total Suspended Solids: TSS - mg/L																	
Count Lab	0	0												2			
Max Lab			1500							865						1500	
Mean Lab			1500							865						1182.5	
Min Lab			1500							865							865
Monitoring Well 3 / pH - ---																	
Count Lab	0	0												2			
Max Lab			8.08							7.63						8.08	
Mean Lab			8.08							7.63						7.855	
Min Lab			8.08							7.63							7.63

From: 01/01/2023 to 31/12/2023

5318
110003665
KING'S BAY WASTEWATER TREATMENT FACILITY
Municipality: City of Kawartha Lakes
Class 2 Wastewater Treatment
Subsurface
200.0
170.0 m3/day

Facility Org Number:
Facility Works Number:
Facility Name:
Facility Owner:
Facility Classification:
Receiver:
Service Population:
Total Design Capacity:

	01/2023	02/2023	03/2023	04/2023	05/2023	06/2023	07/2023	08/2023	09/2023	10/2023	11/2023	12/2023	Total	Avg	Max	Min
Monitoring Well 4 / Carbonaceous Biochemical Oxygen Demand: CBOD5 - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			< 4					0	< 4							
Mean Lab			< 4						< 4						< 4	
Min Lab			< 4						< 4							< 4
Monitoring Well 4 / Conductivity - µS/cm																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			630						686						686	
Mean Lab			630						686					658		
Min Lab			630						686							630
Monitoring Well 4 / Nitrate + Nitrite as N: NO3-N + NO2-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			3.18						5.02						5.02	
Mean Lab			3.18						5.02					4.1		
Min Lab			3.18						5.02							3.18
Monitoring Well 4 / Nitrate as N: NO3-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			3.18						5.02						5.02	
Mean Lab			3.18						5.02					4.1		
Min Lab			3.18						5.02							3.18
Monitoring Well 4 / Nitrite as N: NO2-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			< 0.03					0	< 0.03						< 0.03	
Mean Lab			< 0.03						< 0.03					< 0.03		
Min Lab			< 0.03						< 0.03							< 0.03
Monitoring Well 4 / Total Phosphorus: TP - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			0.01					0	< 0.003						< 0.01	
Mean Lab			0.01						< 0.003					< 0.007		
Min Lab			0.01						< 0.003						< 0.003	
Monitoring Well 4 / Total Suspended Solids: TSS - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			94						77						94	
Mean Lab			94						77					85.5		
Min Lab			94						77							77
Monitoring Well 4 / pH ----																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			8.09						7.73						8.09	
Mean Lab			8.09						7.73					7.91		
Min Lab			8.09						7.73							7.73

Facility Org Number: 5318
Facility Works Number: 110003665
Facility Name: KING'S BAY WASTEWATER TREATMENT FACILITY
Facility Owner: Municipality: City of Kawartha Lakes
Facility Classification: Class 2 Wastewater Treatment
Receiver: Subsurface
Service Population: 200.0
Total Design Capacity: 170.0 m3/day

		01/2023	02/2023	03/2023	04/2023	05/2023	06/2023	07/2023	08/2023	09/2023	10/2023	11/2023	12/2023	Total	Avg	Max	Min
Monitoring Well 5 / Carbonaceous Biochemical Oxygen Demand: CBOD5 - mg/L																	
Count Lab	0	0												2			
Max Lab			< 4							< 4						< 4	
Mean Lab																	
Min Lab			< 4							< 4							4
Monitoring Well 5 / Conductivity - µS/cm																	
Count Lab	0	0															
Max Lab			1480							850				2			
Mean Lab			1480							850					1.165		1480
Min Lab			1480							850							850
Monitoring Well 5 / Nitrate + Nitrite as N: NO3-N + NO2-N - mg/L																	
Count Lab	0	0								1				2			
Max Lab			6.42							5.76						6.42	
Mean Lab			6.42							5.76					6.09		
Min Lab			6.42							5.76							5.76
Monitoring Well 5 / Nitrate as N: NO3-N - mg/L																	
Count Lab	0	0								1				2			
Max Lab			6.42							5.76						6.42	
Mean Lab			6.42							5.76					6.09		
Min Lab			6.42							5.76							5.76
Monitoring Well 5 / Nitrite as N: NO2-N - mg/L																	
Count Lab	0	0								1				2			
Max Lab			0.03							< 0.03						< 0.03	
Mean Lab			< 0.03							< 0.03						< 0.03	
Min Lab			< 0.03							< 0.03							0.03
Monitoring Well 5 / Total Phosphorus: TP - mg/L																	
Count Lab	0	0								1				2			
Max Lab			0.012							0.007						0.012	
Mean Lab			0.012							0.007					0.01		
Min Lab			0.012							0.007							0.007
Monitoring Well 5 / Total Suspended Solids: TSS - mg/L																	
Count Lab	0	0								1				2			
Max Lab			162							198						198	
Mean Lab			162							198					180		
Min Lab			162							198							162
Monitoring Well 5 / pH - ---																	
Count Lab	0	0								1				2			
Max Lab			8.02							7.78						8.02	
Mean Lab			8.02							7.78					7.9		
Min Lab			8.02							7.78							7.78

From: 01/01/2023 to 31/12/2023

5318
110003665
KING'S BAY WASTEWATER TREATMENT FACILITY
Municipality: City of Kawartha Lakes
Class 2 Wastewater Treatment
Subsurface
200.0
170.0 m3/day

Facility Org Number:
Facility Works Number:
Facility Name:
Facility Owner:
Facility Classification:
Receiver:
Service Population:
Total Design Capacity:

	01/2023	02/2023	03/2023	04/2023	05/2023	06/2023	07/2023	08/2023	09/2023	10/2023	11/2023	12/2023	Total	Avg	Max	Min
Monitoring Well 6 / Carbonaceous Biochemical Oxygen Demand: CBOD5 - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			< 4						< 4						< 4	
Mean Lab			< 4						< 4							
Min Lab			< 4						< 4							4
Monitoring Well 6 / Conductivity - µS/cm																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			2260						1810						2260	
Mean Lab			2260						1810					2035		
Min Lab			2260						1810							1810
Monitoring Well 6 / Nitrate + Nitrite as N: NO3-N + NO2-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			14.4						16.8						16.8	
Mean Lab			14.4						16.8					15.6		
Min Lab			14.4						16.8							14.4
Monitoring Well 6 / Nitrate as N: NO3-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			14.4						16.8						16.8	
Mean Lab			14.4						16.8					15.6		
Min Lab			14.4						16.8							14.4
Monitoring Well 6 / Nitrite as N: NO2-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			< 0.03						< 0.03						< 0.03	
Mean Lab			< 0.03						< 0.03					< 0.03		
Min Lab			< 0.03						< 0.03							0.03
Monitoring Well 6 / Total Phosphorus: TP - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			0.011						< 0.003						< 0.011	
Mean Lab			0.011						< 0.003					< 0.007		
Min Lab			0.011						< 0.003						< 0.003	
Monitoring Well 6 / Total Suspended Solids: TSS - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			852						591						852	
Mean Lab			852						591					721.5		
Min Lab			852						591							591
Monitoring Well 6 / pH - ---																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			8.07						7.72						8.07	
Mean Lab			8.07						7.72					7.895		
Min Lab			8.07						7.72							7.72

5318
110003665
KING'S BAY WASTEWATER TREATMENT FACILITY
Municipality: City of Kawartha Lakes
Class 2 Wastewater Treatment
Subsurface
200.0
170.0 m3/day

Facility Org Number:
Facility Works Number:
Facility Name:
Facility Owner:
Facility Classification:
Receiver:
Service Population:
Total Design Capacity:

	01/2023	02/2023	03/2023	04/2023	05/2023	06/2023	07/2023	08/2023	09/2023	10/2023	11/2023	12/2023	Total	Avg	Max	Min
Monitoring Well 7 / Carbonaceous Biochemical Oxygen Demand: CBOD5 - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			< 4						< 4						< 4	
Mean Lab									< 4							
Min Lab			< 4						< 4							4
Monitoring Well 7 / Conductivity - µS/cm																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			2000						2000						2000	
Mean Lab			2000						2000						2000	
Min Lab			2000						2000							2000
Monitoring Well 7 / Nitrate + Nitrite as N: NO3-N + NO2-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			12.6						18.5						18.5	
Mean Lab			12.6						18.5						15.55	
Min Lab			12.6						18.5							12.6
Monitoring Well 7 / Nitrate as N: NO3-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			12.6						18.5						18.5	
Mean Lab			12.6						18.5						15.55	
Min Lab			12.6						18.5							12.6
Monitoring Well 7 / Nitrite as N: NO2-N - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			< 0.03						< 0.03						< 0.03	
Mean Lab			< 0.03						< 0.03						< 0.03	
Min Lab			< 0.03						< 0.03							0.03
Monitoring Well 7 / Total Phosphorus: TP - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			0.009						< 0.003						< 0.009	
Mean Lab			0.009						< 0.003						< 0.006	
Min Lab			0.009						< 0.003							< 0.003
Monitoring Well 7 / Total Suspended Solids: TSS - mg/L																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			1410						524						1410	
Mean Lab			1410						524						967	
Min Lab			1410						524							524
Monitoring Well 7 / pH - ---																
Count Lab	0	0	1	0	0	0	0	0	1	0	0	0	2			
Max Lab			8.03						7.96						8.03	
Mean Lab			8.03						7.96						7.995	
Min Lab			8.03						7.96							7.96

Facility Org Number: 5318
Facility Works Number: 110003665
Facility Name: KING'S BAY WASTEWATER TREATMENT FACILITY
Facility Owner: Municipality: City of Kawartha Lakes
Facility Classification: Class 2 Wastewater Treatment
Receiver: Subsurface
Service Population: 200.0
Total Design Capacity: 170.0 m3/day

		01/2023	02/2023	03/2023	04/2023	05/2023	06/2023	07/2023	08/2023	09/2023	10/2023	11/2023	12/2023	Total	Avg	Max	Min
Monitoring Well 8 / Carbonaceous Biochemical Oxygen Demand: CBOD5 - mg/L																	
Count Lab	0	0		1	0	0	0	0	0	1	0	0	0	2			
Max Lab			< 4							< 4						< 4	
Mean Lab																	
Min Lab			< 4							< 4					4		
Monitoring Well 8 / Conductivity - µS/cm																	4
Count Lab	0	0		1	0	0	0	0	0	1	0	0	0	2			
Max Lab			925							902						925	
Mean Lab			925							902					913.5		
Min Lab			925							902							902
Monitoring Well 8 / Nitrate + Nitrite as N: NO3-N + NO2-N - mg/L																	
Count Lab	0	0		1	0	0	0	0	0	1	0	0	0	2			
Max Lab			4.55							4.18						4.55	
Mean Lab			4.55							4.18					4.365		
Min Lab			4.55							4.18							4.18
Monitoring Well 8 / Nitrate as N: NO3-N - mg/L																	
Count Lab	0	0		1	0	0	0	0	0	1	0	0	0	2			
Max Lab			4.55							4.18						4.55	
Mean Lab			4.55							4.18					4.365		
Min Lab			4.55							4.18							4.18
Monitoring Well 8 / Nitrite as N: NO2-N - mg/L																	
Count Lab	0	0		1	0	0	0	0	0	1	0	0	0	2			
Max Lab			0.03							< 0.03						< 0.03	
Mean Lab			< 0.03							< 0.03					< 0.03		
Min Lab			< 0.03							< 0.03							0.03
Monitoring Well 8 / Total Phosphorus: TP - mg/L																	
Count Lab	0	0		1	0	0	0	0	0	1	0	0	0	2			
Max Lab			0.033							< 0.003						< 0.033	
Mean Lab			0.033							< 0.003					< 0.018		
Min Lab			0.033							< 0.003							< 0.003
Monitoring Well 8 / Total Suspended Solids: TSS - mg/L																	
Count Lab	0	0		1	0	0	0	0	0	1	0	0	0	2			
Max Lab			2230							988						2230	
Mean Lab			2230							988					1614		
Min Lab			2230							988							988
Monitoring Well 8 / pH - ---																	
Count Lab	0	0		1	0	0	0	0	0	1	0	0	0	2			
Max Lab			7.89							7.28						7.89	
Mean Lab			7.89							7.28					7.585		
Min Lab			7.89							7.28							7.28



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Appendix III:
pH & Temperature Summary

Ontario Clean Water Agency
Time Series Info Report
From: 01/01/2023 to 31/12/2023

Facility Org Number:
Facility Works Number:
Facility Name:
Facility Owner:
Facility Classification:
Receiver:
Service Population:
Total Design Capacity:

5318
110003665
KING'S BAY WASTEWATER TREATMENT FACILITY
Municipality: City of Kawartha Lakes
Class 2 Wastewater Treatment
Subsurface
200.0
170.0 m3/day

	01/2023	02/2023	03/2023	04/2023	05/2023	06/2023	07/2023	08/2023	09/2023	10/2023	11/2023	12/2023	Total	Avg	Max	Min
Final Eff / Temperature - °C																
Count IH	13	12	14	12	14	13	13	13	14	14	13	16	161			
Max IH	14.6	14.4	13.8	16.1	18.3	19.6	189.8	24	21.6	22	19.8	19.3			189.8	
Mean IH	12.792	12.258	12.707	14.792	15.564	18.431	33.085	20.615	19.757	18.936	16.569	16.25		17.649		
Min IH	10.5	10.4	10.9	13.1	13.5	17	19	19.5	18.1	16.5	14.3	13.8				10.4
Final Eff / pH - ...																
Count IH	13	12	14	12	14	13	13	13	14	14	13	16	161			
Max IH	7.79	7.76	7.96	7.8	7.8	7.83	7.54	7.58	7.96	7.77	7.85	7.66			7.96	
Mean IH	7.623	7.663	7.581	7.644	7.695	7.548	7.452	7.449	7.566	7.541	7.578	7.528		7.571		
Min IH	7.35	7.5	7.38	7.46	7.58	7.38	7.32	7.3	7.16	7.36	7.3	7.27				7.16



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Appendix IV:

Groundwater Monitoring Wells - Levels

Ontario Clean Water Agency
Time Series Info Report

From: 01/01/2023 to 31/12/2023

Facility Org Number: 5318
Facility Works Number: 110003665
Facility Name: KING'S BAY WASTEWATER TREATMENT FACILITY
Facility Owner: Municipality: City of Kawartha Lakes
Facility Classification: Class 2 Wastewater Treatment
Receiver: Subsurface
Service Population: 200.0
Total Design Capacity: 170.0 m3/day

	01/2023	02/2023	03/2023	04/2023	05/2023	06/2023	07/2023	08/2023	09/2023	10/2023	11/2023	12/2023	Total
Monitoring Well 1 / Well Level - m													
Count IH		0			0	1	0	0	1	0	0	1	4
Total IH			5.31			5.14			7.3			5.85	
Monitoring Well 2 / Well Level - m													
Count IH	0	0	1	0	0	1	0	0	1	0	0	1	4
Total IH			6.38			6.29			6.7			7	
Monitoring Well 3 / Well Level - m													
Count IH	0	0	1	0	0	1	0	0	1	0	0	1	4
Total IH			6.82			6.75			5.64			7.61	
Monitoring Well 4 / Well Level - m													
Count IH	0	0	1	0	0	1	0	0	1	0	0	1	4
Total IH			7.38			7.14			7.59			7.96	
Monitoring Well 5 / Well Level - m													
Count IH	0	0	1	0	0	1	0	0	1	0	0	1	4
Total IH			7.69			7.54			8.03			8.39	
Monitoring Well 6 / Well Level - m													
Count IH	0	0	1	0	0	1	0	0	1	0	0	1	4
Total IH			4.78			4.95			5.66			5.65	
Monitoring Well 7 / Well Level - m													
Count IH	0	0	1	0	0	1	0	0	1	0	0	1	4
Total IH			4.37			4.56			5.27			5.25	
Monitoring Well 8 / Well Level - m													
Count IH	0	0	1	0	0	1	0	0	1	0	0	1	4
Total IH			4.05			3.31			5			4.95	



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Appendix V:
Maintenance Summary

Workorder Summary Report

Report Start Date: Jan 1, 2023 12:00 AM

Report End Date: Dec 31, 2023 11:59 PM

Location: 5318*

Work Order Type: CALL,EMER

Work Order Class:

WO #	Asset Description	Location Description	WorkOrder		Workorder Details		
			Type	Class	Work Order Description	Status	Actual Start Actual Finish
3339334	5318, Kings Bay Effluent PS, Process	5318, Kings Bay WWT, Facility	CALL	Refurbish/ Replace/ Repair	5318, Kings Bay Effluent PS, Effluent Pump Fail, Alarm	CLOSE	4/5/23 06:30 AM 4/5/23 07:00 AM
3340298	5318, Kings Bay WWT, Facility	5318, Kings Bay WWT, Facility	CALL	Refurbish/ Replace/ Repair	5318, Kings Bay WWT, RBC 2, Fault	CLOSE	4/17/23 02:52 AM 4/17/23 02:25 PM
3524930	MOTOR GEAR DRIVE AC 02 RBC	5318, Kings Bay WWT, Process	CALL	Refurbish/ Replace/ Repair	5318, Kings Bay WWT, RBC 2 Fail, Alarm	CLOSE	8/12/23 03:40 PM 8/12/23 05:00 PM
3527356	GEAR DRIVE 01 RBC	5318, Kings Bay WWT, Process	CALL	Inspection	5318 Kingsbay WWT, RBC 1 Fault, Alarm	CLOSE	8/26/23 09:15 PM 8/27/23 12:15 AM
3706638	5318, Kings Bay Effluent PS, Facility, Power Distribution	5318, Kings Bay Effluent PS, Facility, Power Distribution	CALL	Inspection	5318, Kings Bay Effluent PS, Panel Fault, Alarm	CLOSE	12/18/23 10:30 PM 12/19/23 02:30 AM
3759396	5318, Kings Bay Effluent PS	5318, Kings Bay Effluent PS	CALL	Refurbish/ Replace/ Repair	5318, Kings Bay Effluent PS, Effluent Hi/LO, Alarm	COMP	12/29/23 11:09 PM 12/30/23 01:15 AM
3759397	5318, Kings Bay Effluent PS	5318, Kings Bay Effluent PS	CALL	Refurbish/ Replace/ Repair	5318, Kings Bay Effluent PS, Effluent Tank Hi/lo, Alarm	COMP	12/30/23 12:34 PM 12/30/23 04:30 PM
3759399	5318, Kings Bay Effluent PS	5318, Kings Bay Effluent PS	CALL	Refurbish/ Replace/ Repair	5318, Kings Bay Effluent PS, Effluent HI/LO, Alarm	COMP	12/30/23 10:17 PM 12/31/23 12:40 AM

3759404	5318, Kings Bay Effluent PS	CALL	Refurbish/ Replace/ Repair	5318, Kings Bay Effluent PS, Effluent HI/LO, Alarm	COMP	12/30/23 10:17 PM	12/30/23 11:40 PM
3759403	5318, Kings Bay Effluent PS	CALL	Refurbish/ Replace/ Repair	5318, Kings Bay Effluent PS, Effluent HI/LO, Alarm	COMP	12/31/23 11:36 AM	12/31/23 03:00 PM

Workorder Summary Report

Report Start Date: Jan 1, 2023 12:00 AM

Report End Date: Dec 31, 2023 11:59 PM

Location: 5318*

Work Order Type: CAP,CORR

Work Order Class:

WorkOrder			Workorder Details					
WO #	Asset Description	Location Description	Type	Class	Work Order Description	Status	Actual Start	Actual Finish
2868350		5318, Kings Bay Influent PS	CAP	Refurbish/ Replace/ Repair	5318, Kings Bay Influent PS, Influent and Effluent Pump Replacement	COMP	8/5/22 02:14 PM	1/4/24 08:06 AM
3244848		5318, Kings Bay WWT, Process	CORR	Refurbish/ Replace/ Repair	5318, Kings Bay WWT, RBC 2, Hauling	CLOSE	2/7/23 06:50 AM	2/7/23 07:50 AM
3340338		5318, Kings Bay WWT, Facility	CORR	Refurbish/ Replace/ Repair	5318, King's Bay, RBC 2 Fault, Repairs	CLOSE	4/17/23 02:38 PM	4/17/23 02:38 PM
3386972	PUMP SUBMERSIBLE 01 EFFLUENT KINGS BAY [6 HP]	5318, Kings Bay WWT, Process	CORR	Refurbish/ Replace/ Repair	5318, Kings Bay WWT, Effluent Pump 1 Pressure Gauge Replacement	CLOSE	5/26/23 10:00 AM	8/3/23 10:13 AM
3524521	MOTOR GEAR DRIVE AC 02 RBC	5318, Kings Bay WWT, Process	CORR	Refurbish/ Replace/ Repair	5318, Kings Bay WWT, Motor Gear Drive RBC 2, Motor Tripping, Repair	CLOSE	8/9/23 02:10 PM	9/18/23 02:12 PM
3526374	PANEL CONTROL EFFLUENT	5318, Kings Bay WWT, Facility, Power Distribution	CORR	Refurbish/ Replace/ Repair	5318, Kings Bay WWT, Effluent Pump Control Panel, Failure, Repair	CLOSE	8/22/23 07:45 AM	9/1/23 08:30 AM
3571193	GEAR DRIVE 01 RBC	5318, Kings Bay WWT, Process	CORR	Refurbish/ Replace/ Repair	5318, Kings Bay WWT, RBC Chain, Repair Follow Up	CLOSE	9/7/23 02:02 PM	9/7/23 02:02 PM
3703870		5318, Kings Bay WWT, Process	CORR	Refurbish/ Replace/ Repair	5318, Kings Bay WWT, RBC 1 Clarifier Inflow Pipe Fallen Off Weir, Follow up	CLOSE	12/5/23 12:34 PM	12/8/23 02:43 PM

3705497	UPS BATTERY BANK	5318, Kings Bay WWT, Facility, Power Generation, Backup Power	CORR	Refurbish/ Replace/ Repair	5318, Kings Bay WWTP, UPS Battery Bank Fail, Replace	CLOSE	12/13/23 07:56 AM	12/14/23 01:24 PM
-------------------------	------------------	---	------	----------------------------------	--	-------	-------------------	-------------------

Workorder Summary Report

Report Start Date: Jan 1, 2023 12:00 AM

Report End Date: Dec 31, 2023 11:59 PM

Location: 5318*

Work Order Type: OPER,PM

Work Order Class:

WO #	Asset Description	Location Description	WorkOrder		Workorder Details		
			Type	Class	Work Order Description	Status	Actual Start Actual Finish
3153232		5318, Kings Bay WWT	PM	Inspection	Daily Operational Activities (1y) - 5318 - KTS	COMP	1/1/23 12:00 AM 1/2/24 08:49 AM
3155695	TANK STORAGE ALUM BULK	5318, Kings Bay WWT, Process	PM	Refurbish/ Replace/ Repair	Tank Alum Inspection (1m) - 5318 - KTS	CLOSE	1/10/23 10:30 AM 1/10/23 10:45 AM
3156401		5318, Kings Bay WWT, Process	PM	Refurbish/ Replace/ Repair	Tank RBC #2 Insp/Service (3m) - 5318 - KTS	CLOSE	1/10/23 10:00 AM 1/11/23 12:00 AM
3178210		5318, Kings Bay WWT	PM	Inspection	Chemical Feed System Insp (1m) - 5318 - KTS	CLOSE	1/10/23 10:30 AM 1/10/23 10:45 AM
3182462		5318, Kings Bay WWT	OPER	Compliance	Operator PDM Entry & Review (1m) - 5318 - KTS	CLOSE	1/4/23 12:30 PM 1/4/23 01:30 PM
3184034		5318, Kings Bay WWT	OPER	Health and Safety	Corporate Facility Workplace H & S Inspection (3m) - 5318 - KTS	CLOSE	1/4/23 09:30 AM 1/4/23 09:45 AM
3210998	TANK STORAGE ALUM BULK	5318, Kings Bay WWT, Process	PM	Refurbish/ Replace/ Repair	Tank Alum Inspection (1m) - 5318 - KTS	CLOSE	2/10/23 07:00 AM 2/10/23 07:20 AM
3226954		5318, Kings Bay WWT	PM	Inspection	Chemical Feed System Insp (1m) - 5318 - KTS	CLOSE	2/10/23 07:00 AM 2/10/23 07:20 AM
3229503		5318, Kings Bay WWT	OPER	Compliance	Operator PDM Entry & Review (1m) - 5318 - KTS	CLOSE	2/3/23 08:34 AM 2/3/23 09:19 AM
3251791		5318, Kings Bay WWT	PM	Inspection	Tank Wetwell Level Equipment Inspection (6m) - 5318- KTS	CLOSE	3/7/23 09:10 AM 3/7/23 09:40 AM

3251793	5318, Kings Bay WWT, Process	PM	Refurbish/ Replace/ Repair	Tank RBC #1 Insp/Service (3m) - 5318 - KTS	CLOSE	3/14/23 07:00 AM	3/20/23 01:40 PM
3252080	TANK STORAGE ALUM BULK	PM	Refurbish/ Replace/ Repair	Tank Alum Inspection (1m) - 5318 - KTS	CLOSE	3/7/23 09:40 AM	3/7/23 10:10 AM
3252083	TANK PROCESS WETWELL EFFLUENT Process	PM	Refurbish/ Replace/ Repair	Tank Wetwell Cleaning/Inspection (6m) - 5318 Effluent- KTS	CLOSE	5/26/23 06:50 AM	5/26/23 11:30 AM
3269886	5318, Kings Bay WWT	PM	Inspection	Chemical Feed System Insp (1m) - 5318 - KTS	CLOSE	3/7/23 10:26 AM	3/7/23 10:26 AM
3272433	5318, Kings Bay WWT	OPER	Compliance	Operator PDM Entry & Review (1m) - 5318 - KTS	CLOSE	3/2/23 07:00 AM	3/7/23 10:22 AM
3296731	TANK STORAGE ALUM BULK	PM	Refurbish/ Replace/ Repair	Tank Alum Inspection (1m) - 5318 - KTS	CLOSE	4/18/23 11:35 AM	4/18/23 12:05 PM
3297544	5318, Kings Bay WWT, Process	PM	Refurbish/ Replace/ Repair	Tank RBC #2 Insp/Service (3m) - 5318 - KTS	CLOSE	4/17/23 10:00 AM	4/20/23 07:15 AM
3316186	5318, Kings Bay WWT	PM	Inspection	Chemical Feed System Insp (1m) - 5318 - KTS	CLOSE	4/18/23 11:35 AM	4/18/23 12:05 PM
3318393	5318, Kings Bay WWT, Process	PM	Refurbish/ Replace/ Repair	Gear Drive RBC #1 Inspection/Service (1y) - 5318 - KTS	CLOSE	4/17/23 09:00 AM	4/17/23 10:00 AM
3318399	5318, Kings Bay WWT, Process	PM	Refurbish/ Replace/ Repair	Gear Drive RBC #2 Inspection/Service (1y) - 5318 - KTS	CLOSE	4/17/23 09:00 AM	4/17/23 10:00 AM
3319513	5318, Kings Bay WWT	OPER	Compliance	Operator PDM Entry & Review (1m) - 5318 - KTS	CLOSE	4/3/23 08:50 AM	4/3/23 11:30 AM
3321439	5318, Kings Bay WWT	OPER	Health and Safety	Corporate Facility Workplace H & S Inspection (3m) - 5318 - KTS	CLOSE	4/14/23 08:35 AM	4/14/23 08:35 AM
3346173	5318, Kings Bay WWT	PM	Inspection	Lifting Devices & Fall Arrest Inspection by Contractor (1y) - 5318 - KTS	CLOSE	6/15/23 11:28 AM	6/15/23 01:00 PM
3346255	TANK STORAGE ALUM BULK	PM	Refurbish/ Replace/ Repair	Tank Alum Inspection (1m) - 5318 - KTS	CLOSE	5/9/23 12:45 PM	5/9/23 01:00 PM

3364276	5318, Kings Bay WWT	PM	Inspection	Chemical Feed System Insp (1m) - 5318 - KTS	CLOSE	5/9/23 12:45 PM	5/9/23 01:00 PM
3366910	5318, Kings Bay WWT	OPER	Compliance	Operator PDM Entry & Review (1m) - 5318 - KTS	CLOSE	5/2/23 09:00 AM	5/2/23 11:45 AM
3383730	TANK PROCESS WETWELL INFLUENT	PM	Refurbish/ Replace/ Repair	Tank Wetwell Cleaning/Inspection (6m) - 5318 Influent- KTS	CLOSE	5/26/23 06:50 AM	5/26/23 11:30 AM
3391789	5318, Kings Bay WWT	PM	Calibration	Online Process Equipment Calibration Service by Contractor (1y) - 5318 - KTS	CLOSE	6/28/23 09:40 AM	6/28/23 03:30 PM
3391794	5318, Kings Bay WWT, Process	PM	Refurbish/ Replace/ Repair	Tank RBC #1 Insp/Service (3m) - 5318 - KTS	CLOSE	6/15/23 07:00 AM	6/29/23 11:35 AM
3392027	TANK STORAGE ALUM BULK	PM	Refurbish/ Replace/ Repair	Tank Alum Inspection (1m) - 5318 - KTS	CLOSE	6/15/23 09:41 AM	6/15/23 09:56 AM
3411199	5318, Kings Bay WWT	PM	Inspection	Chemical Feed System Insp (1m) - 5318 - KTS	CLOSE	6/15/23 09:56 AM	6/15/23 10:10 AM
3414199	5318, Kings Bay WWT	OPER	Compliance	Operator PDM Entry & Review (1m) - 5318 - KTS	CLOSE	6/2/23 01:35 PM	6/2/23 03:16 PM
3415715	5318, Kings Bay Effluent PS	OPER	Health and Safety	Corporate Facility Workplace H & S Inspection (1y) - 5318 - KTS	CLOSE	10/12/23 11:17 AM	10/12/23 11:30 AM
3441062	TANK STORAGE ALUM BULK	PM	Refurbish/ Replace/ Repair	Tank Alum Inspection (1m) - 5318 - KTS	CLOSE	7/13/23 08:30 AM	7/13/23 08:45 AM
3441499	5318, Kings Bay WWT, Process	PM	Refurbish/ Replace/ Repair	Tank RBC #2 Insp/Service (3m) - 5318 - KTS	CLOSE	7/13/23 06:50 AM	7/14/23 02:02 PM
3458770	5318, Kings Bay WWT	PM	Inspection	Chemical Feed System Insp (1m) - 5318 - KTS	CLOSE	7/13/23 08:30 AM	7/13/23 08:45 AM
3461898	5318, Kings Bay WWT	OPER	Compliance	Operator PDM Entry & Review (1m) - 5318 - KTS	CLOSE	6/30/23 02:33 PM	7/12/23 02:34 PM
3463391	5318, Kings Bay WWT	OPER	Health and Safety	Corporate Facility Workplace H & S Inspection (3m) - 5318 - KTS	CLOSE	7/13/23 08:45 AM	7/13/23 09:00 AM
3488339	TANK STORAGE ALUM BULK	PM	Refurbish/ Replace/ Repair	Tank Alum Inspection (1m) - 5318 - KTS	CLOSE	8/9/23 01:40 PM	8/9/23 02:10 PM

3504834	5318, Kings Bay WWT	PM	Inspection	Chemical Feed System Insp (1m) - 5318 - KTS	CLOSE	8/9/23 01:40 PM	8/9/23 02:10 PM
3507217	5318, Kings Bay WWT	OPER	Compliance	Operator PDM Entry & Review (1m) - 5318 - KTS	CLOSE	8/1/23 01:00 PM	8/1/23 01:30 PM
3531578	5318, Kings Bay WWT	PM	Inspection	Tank Wetwell Level Equipment Inspection (6m) - 5318- KTS	CLOSE	9/12/23 11:20 AM	9/12/23 11:40 AM
3531580	5318, Kings Bay WWT, Process	PM	Refurbish/ Replace/ Repair	Tank RBC #1 Insp/Service (3m) - 5318 - KTS	CLOSE	9/27/23 10:00 AM	9/28/23 08:00 AM
3532100	TANK STORAGE ALUM BULK	PM	Refurbish/ Replace/ Repair	Tank Alum Inspection (1m) - 5318 - KTS	CLOSE	9/13/23 11:50 AM	9/13/23 12:00 PM
3532103	TANK PROCESS WETWELL EFFLUENT Process	PM	Refurbish/ Replace/ Repair	Tank Wetwell Cleaning/Inspection (6m) - 5318 Effluent- KTS	CLOSE	9/20/23 11:59 AM	9/20/23 11:59 AM
3550311	5318, Kings Bay WWT	PM	Inspection	Chemical Feed System Insp (1m) - 5318 - KTS	CLOSE	9/12/23 11:40 AM	9/12/23 12:15 PM
3553161	5318, Kings Bay WWT	OPER	Compliance	Operator PDM Entry & Review (1m) - 5318 - KTS	CLOSE	9/1/23 12:00 PM	9/1/23 12:30 PM
3580714	TANK STORAGE ALUM BULK	PM	Refurbish/ Replace/ Repair	Tank Alum Inspection (1m) - 5318 - KTS	CLOSE	10/24/23 10:30 AM	10/24/23 10:45 AM
3581311	5318, Kings Bay WWT, Process	PM	Refurbish/ Replace/ Repair	Tank RBC #2 Insp/Service (3m) - 5318 - KTS	CLOSE	10/24/23 10:30 AM	10/24/23 10:58 AM
3597469	5318, Kings Bay WWT	PM	Inspection	UPS Insp/Service (1y) - 5318 - KTS	CLOSE	12/19/23 12:49 PM	12/19/23 12:49 PM
3598787	5318, Kings Bay WWT	PM	Inspection	Chemical Feed System Insp (1m) - 5318 - KTS	CLOSE	10/24/23 10:30 AM	10/24/23 10:45 AM
3602529	5318, Kings Bay WWT	OPER	Compliance	Operator PDM Entry & Review (1m) - 5318 - KTS	CLOSE	10/5/23 12:30 PM	10/5/23 03:30 PM
3603966	5318, Kings Bay WWT	OPER	Health and Safety	Corporate Facility Workplace H & S Inspection (3m) - 5318 - KTS	CLOSE	10/12/23 11:17 AM	10/12/23 11:30 AM
3629458	TANK STORAGE ALUM BULK	PM	Refurbish/ Replace/ Repair	Tank Alum Inspection (1m) - 5318 - KTS	CLOSE	11/15/23 10:30 AM	11/15/23 11:00 AM

3629461	TANK PROCESS WETWELL INFLUENT	5318, Kings Bay WWT, Process	PM	Refurbish/ Replace/ Repair	Tank Wetwell Cleaning/Inspection (6m) - 5318 Influent- KTS	CLOSE	11/16/23 09:15 AM	11/16/23 11:10 AM
3644483		5318, Kings Bay WWT	PM	Inspection	Chemical Feed System Insp (1m) - 5318 - KTS	CLOSE	11/15/23 10:30 AM	11/15/23 11:00 AM
3647319		5318, Kings Bay WWT	OPER	Compliance	Operator PDM Entry & Review (1m) - 5318 - KTS	CLOSE	11/9/23 07:00 AM	11/9/23 03:30 PM
3670548		5318, Kings Bay WWT, Process	PM	Refurbish/ Replace/ Repair	Tank RBC #1 Insp/Service (3m) - 5318 - KTS	CLOSE	12/1/23 12:47 PM	12/19/23 12:47 PM
3670685	TANK STORAGE ALUM BULK	5318, Kings Bay WWT, Process	PM	Refurbish/ Replace/ Repair	Tank Alum Inspection (1m) - 5318 - KTS	CLOSE	12/18/23 12:00 PM	12/18/23 12:15 PM
3686415		5318, Kings Bay WWT	PM	Inspection	Chemical Feed System Insp (1m) - 5318 - KTS	CLOSE	12/18/23 12:00 PM	12/18/23 12:15 PM
3688769		5318, Kings Bay WWT	OPER	Compliance	Operator PDM Entry & Review (1m) - 5318 - KTS	CLOSE	12/6/23 11:30 AM	12/7/23 12:00 PM



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Appendix VI:
Calibration Report



Franklin Empire Inc,
550 Braidwood Ave
Peterborough ON K9J 1W1, CANADA

Tel: (705) 745-1626
Fax: (705) 745-3493

OCWA Kawartha

2023 Calibrations Kings Bay WTP & WWTP

Leaders in Instrumentation and Control

SIEMENS MAGFLO® Verification Certificate



Customer:

Name OCWA Kawartha
Address _____

Phone _____
Email _____

MAGFLO® Identification:

TAG No./Name 0
Sensor Code No. 7ME658
Sensor Serial No. 041101U493
Transmitter Code No. 7ME691
Transmitter Serial No. 229730U463
Location RBC 1

Results:

Verification file name or No. RBC 1 Flow
Transmitter

Passed

Sensor Insulation

Passed

Magnetic Circuit

Passed

Velocity	Current Output			Frequency Output		
Theoretical	Theoretical	Actual	Deviation	Theoretical	Actual	Deviation
0.5m/s	4.800mA	4.796mA	-0.52%	0.500kHz	0.497kHz	-0.56%
1.0m/s	5.600mA	5.599mA	-0.08%	1.000kHz	1.000kHz	-0.05%
3.0m/s	8.800mA	8.800mA	-0.01%	3.000kHz	3.002kHz	0.06%

Current Output 4-20mA

Frequency Output 0-10kHz

Transmitter Settings:

Basic Qmax. 10.0000 l/s
Flow Direction Positive
Low flow Cut-off 1.50%
Empty Pipe ON

Output Current Output ON (4-20mA)
Time Constant 5.0 Sec.
Relay Output Error Level

Digital Output Pulse
Frequency Range N/A
Time Constant N/A
Volume/pulse 0.99999953 US G/p
Pulse width 0.066 sec.
Pulse polarity Positiv

Totalizer 1 value before test 87724.8359375 m³
Totalizer 1 value after test 87724.8515625 m³
Totalizer 2 value before test 956.33630371 m³
Totalizer 2 value after test 956.33630371 m³
Operating time in days 3470

Sensor Details:

Size DN 80 3 IN

Cal. Factor 5.12170267

Correction Factor 1.0

Excitation Freq. 7.5Hz

Vericator Details (083F5061)

Serial No. 000811N218

Device No. 91739

Software Version 1.40

PC-Software Version 5.01

Cal. date 2022.12.29

ReCal. date 2023.12.29

Comments

These tests verify that the flowmeter is functioning within 2% deviation of the original test parameters.
Verification is traceable to National and International Standards.

Date and signature

2023.06.28

M Manley

SIEMENS MAGFLO® Verification Certificate



Customer:

Name OCWA Kawartha
Address Kings Bay WW

Phone
Email

MAGFLO® Identification:

TAG No./Name 0
Sensor Code No. 7ME658
Sensor Serial No. 041001U493
Transmitter Code No. 7ME691
Transmitter Serial No. 231030U463
Location Kings Bay RBC2

Results:

Verification file name or No. RBC 2
Transmitter

Passed

Sensor Insulation

Passed

Magnetic Circuit

Passed

Velocity	Current Output			Frequency Output		
Theoretical	Theoretical	Actual	Deviation	Theoretical	Actual	Deviation
0.5m/s	4.800mA	4.806mA	0.80%	0.500kHz	0.501kHz	0.13%
1.0m/s	5.600mA	5.604mA	0.25%	1.000kHz	0.999kHz	-0.10%
3.0m/s	8.800mA	8.807mA	0.15%	3.000kHz	3.001kHz	0.04%

Current Output 4-20mA

Frequency Output 0-10kHz

Transmitter Settings:

Basic Qmax. 10.0000 l/s
Flow Direction Positive
Low flow Cut-off 1.50%
Empty Pipe ON

Output Current Output ON (4-20mA)
Time Constant 5.0 Sec.
Relay Output Error Level

Digital Output Pulse
Frequency Range N/A
Time Constant N/A
Volume/pulse 0.99999953 US G/p
Pulse width 0.066 sec.
Pulse polarity Positiv

Totalizer 1 value before test 87475.984375 m³
Totalizer 1 value after test 87476.0 m³
Totalizer 2 value before test 2355.4230957 m³
Totalizer 2 value after test 2355.42504883 m³
Operating time in days 3470

Sensor Details:

Size DN 80 3 IN

Cal. Factor 4.97646475

Correction Factor 1.0

Excitation Freq. 7.5Hz

Vericator Details (083F5061)

Serial No. 000811N218

Device No. 91739

Software Version 1.40

PC-Software Version 5.01

Cal. date 2022.12.29

ReCal. date 2023.12.29

Comments

These tests verify that the flowmeter is functioning within 2% deviation of the original test parameters.
Verification is traceable to National and International Standards.

Date and signature

2023.06.28

M Manley



VeriMaster - Flow Meter Verification Report

Customer Information		Meter Information	
Customer	OCWA	Meter Owner	King Bay WW
Verification Download	Wed, Jun 28, 2023	Meter Type	WaterMaster
		Sensor Size	DN100
		Pipe Status	Fluid Present
		Sensor Type	Fullbore
		Sensor Serial No	3K620000164062
		Transmitter Serial No	3K620000168464
		Tag	ABB Warminster
		Location	?

Overall Status: Pass

The flowmeter has passed its internal continuous verification and automatic self calibration. It is working within +/-1% of its original factory calibration

Summary of Results		Verification History	
Coil Group	Passed	OIML Accuracy Alarms	0
Electrode Group	Passed	Totaliser Information	
Sensor Group	Passed		
Transmitter Signal	Passed		
Transmitter Driver	Passed		
Output Group	Passed	Forward	31686.54 m3
Configuration	Passed	Reverse	1316.62 m3
		Net	30369.92 m3
Sensor Information		Sensor Data	
Q3	69.44 l/s	Coil Current	179.9 mA
Calibration Accuracy	OIML Class 2	Coil Inductance	205.0 mH
Sensor Calibration Factors	88.1%; 0.00 mm/s; 11	Coil Inductance Shift	-0.1%
Date of Manufacture	20 May 2014	Coil / Loop Resistance	39.1 ohm
Run Hours	3108days 22hrs 20mins	Transmitter Data	
Transmitter Information		Tx Gain - Adjustment	0.2%
		VeriMaster Information	
		Version	01.00.03
		Limit Version	01.00.01
Current Output		Pulse Output	
4mA Value	Pass : 4.000 mA ; 0.00%	Output 1: 1200.0Hz	Not tested
12mA Value	Pass : 11.980 mA ; 0.17%	Output 1: 600.0Hz	Not tested
20mA Value	Pass : 20.000 mA ; 0.00%	Output 2: 1200.0Hz	Not tested
		Output 2: 600.0Hz	Not tested

Installation Comments / Equipment used:	Configuration Settings
Pump 1	Mains Frequency 60 Hz
	Qmax 10.00 l/s
	Pulses/Unit 120.000000
	Pulses Limit Frequency 1200.0 Hz
	Sensor User Span/Zero 100.0%; 0.00 mm/s
	User Flow Cutoff/Hysteresis 3.00%; 20%
	Meter Mode Normal operation

Date Wed, Jun 28, 2023

Operator Signature

Print

ABB Instrumentation World Flow Technology

ABB Limited
Oldends Lane, Stonehouse
Gloucestershire, GL10 3TA UK
Tel: +44(0) 1453 826661
Fax: +44(0) 1453 821121
instrumentation@gb.abb.com

ABB Automation Inc.
125 East County Line Road
Warminster, PA 18974 USA
Tel: +1 215 674 6000
Fax: +1 215 674 6394
instrumentation@gb.abb.com

ABB Australia Pty Ltd.
Bapaune Rd
Moorebank, NSW 2170
Tel: +61-2-982 1-0111
Fax: +61-2-9821-0950

ABB Automation GmbH
Dransfelder Str.2
37079 Gottingen, GERMANY
Tel: +49 (0) 551 905212
Fax: +1 (215) 674 6394



VeriMaster - Flow Meter Verification Report

Customer Information		Meter Information	
Customer	OCWA	Meter Owner	Kings Bay WW
Verification Download	Wed, Jun 28, 2023	Meter Type	WaterMaster
		Sensor Size	DN100
		Pipe Status	Fluid Present
		Sensor Type	Fullbore
		Sensor Serial No	3K620000168465
		Transmitter Serial No	3K620000168466
		Tag	?
		Location	?

Overall Status: Pass

The flowmeter has passed its internal continuous verification and automatic self calibration. It is working within +/-1% of its original factory calibration

Summary of Results		Verification History	
Coil Group	Passed	OIML Accuracy Alarms	0
Electrode Group	Passed	Totaliser Information	
Sensor Group	Passed		
Transmitter Signal	Passed		
Transmitter Driver	Passed	Forward	40482.98 m3
Output Group	Passed	Reverse	1584.49 m3
Configuration	Passed	Net	38898.48 m3
Sensor Information		Sensor Data	
Q3	69.44 l/s	Coil Current	179.9 mA
Calibration Accuracy	OIML Class 2	Coil Inductance	218.2 mH
Sensor Calibration Factors	87.0%; 0.00 mm/s; 11	Coil Inductance Shift	-0.6%
Date of Manufacture	17 May 2014	Coil / Loop Resistance	38.2 ohm
Run Hours	3108days 21hrs 25mins	Transmitter Data	
Transmitter Information		Tx Gain - Adjustment	0.2%
		VeriMaster Information	
		Version	01.00.03
		Limit Version	01.00.01
Current Output		Pulse Output	
4mA Value	Pass : 4.000 mA ; 0.00%	Output 1: 1200.0Hz	Not tested
12mA Value	Pass : 11.980 mA ; 0.17%	Output 1: 600.0Hz	Not tested
20mA Value	Pass : 20.020 mA ; -0.10%	Output 2: 1200.0Hz	Not tested
		Output 2: 600.0Hz	Not tested

Installation Comments / Equipment used:	Configuration Settings
P2	Mains Frequency 60 Hz
	Qmax 10.00 l/s
	Pulses/Unit 120.000000
	Pulses Limit Frequency 1200.0 Hz
	Sensor User Span/Zero 1200.0Hz; 0.00 mm/s
	User Flow Cutoff/Hysteresis 3.00%; 20%
	Meter Mode Normal operation

Date Wed, Jun 28, 2023

Operator Signature

Print

ABB Instrumentation World Flow Technology

ABB Limited
Oldends Lane, Stonehouse
Gloucestershire, GL10 3TA UK
Tel: +44(0) 1453 826661
Fax: +44(0) 1453 821121
instrumentation@gb.abb.com

ABB Automation Inc.
125 East County Line Road
Warminster, PA 18974 USA
Tel: +1 215 674 6000
Fax: +1 215 674 6394
instrumentation@gb.abb.com

ABB Australia Pty Ltd.
Bapaune Rd
Moorebank, NSW 2170
Tel: +61-2-982 1-0111
Fax: +61-2-9821-0950

ABB Automation GmbH
Dransfelder Str.2
37079 Gottingen, GERMANY
Tel: +49 (0) 551 905212
Fax: +1 (215) 674 6394



VeriMaster - Flow Meter Verification Report

Customer Information		Meter Information	
Customer	OCWA	Meter Owner	Kings Bay WW
Verification Download	Wed, Jun 28, 2023	Meter Type	WaterMaster
		Sensor Size	DN100
		Pipe Status	Fluid Present
		Sensor Type	Fullbore
		Sensor Serial No	3K620000168466
		Transmitter Serial No	3K620000164062
		Tag	ABB Warminster
		Location	?

Overall Status: Pass

The flowmeter has passed its internal continuous verification and automatic self calibration. It is working within + / -1% of its original factory calibration

Summary of Results		Verification History	
Coil Group	Passed	OIML Accuracy Alarms	0
Electrode Group	Passed	Totaliser Information	
Sensor Group	Passed		
Transmitter Signal	Passed		
Transmitter Driver	Passed	Forward	37048.31 m3
Output Group	Passed	Reverse	73.84 m3
Configuration	Passed	Net	36974.47 m3
Sensor Information		Sensor Data	
Q3	69.44 l/s	Coil Current	179.9 mA
Calibration Accuracy	OIML Class 2	Coil Inductance	219.6 mH
Sensor Calibration Factors	85.4%; 0.00 mm/s; 11	Coil Inductance Shift	0.9%
Date of Manufacture	11 Apr 2014	Coil / Loop Resistance	38.8 ohm
Run Hours	3108days 21hrs 15mins	Transmitter Data	
Transmitter Information		Tx Gain - Adjustment	0.2%
		VeriMaster Information	
		Version	01.00.03
		Limit Version	01.00.01
Current Output		Pulse Output	
4mA Value	Pass : 4.000 mA ; 0.00%	Output 1: 1200.0Hz	Not tested
12mA Value	Pass : 11.980 mA ; 0.17%	Output 1: 600.0Hz	Not tested
20mA Value	Pass : 19.980 mA ; 0.10%	Output 2: 1200.0Hz	Not tested
		Output 2: 600.0Hz	Not tested

Installation Comments / Equipment used:	Configuration Settings
Pump 3	Mains Frequency 60 Hz
	Qmax 10.00 l/s
	Pulses/Unit 120.000000
	Pulses Limit Frequency 1200.0 Hz
	Sensor User Span/Zero 100.0%; 0.00 mm/s
	User Flow Cutoff/Hysteresis 3.00%; 20%
	Meter Mode Normal operation

Date Wed, Jun 28, 2023

Operator Signature

Print

ABB Instrumentation World Flow Technology

ABB Limited
Oldends Lane, Stonehouse
Gloucestershire, GL10 3TA UK
Tel: +44(0) 1453 826661
Fax: +44(0) 1453 821121
instrumentation@gb.abb.com

ABB Automation Inc.
125 East County Line Road
Warminster, PA 18974 USA
Tel: +1 215 674 6000
Fax: +1 215 674 6394
instrumentation@gb.abb.com

ABB Australia Pty Ltd.
Bapaune Rd
Moorebank, NSW 2170
Tel: +61-2-982 1-0111
Fax: +61-2-9821-0950

ABB Automation GmbH
Dransfelder Str.2
37079 Gottingen, GERMANY
Tel: +49 (0) 551 905212
Fax: +1 (215) 674 6394



VeriMaster - Flow Meter Verification Report

Customer Information		Meter Information	
Customer	OCWA	Meter Owner	Kings Bay WWTP
Verification Download	Wed, Jun 28, 2023	Meter Type	WaterMaster
		Sensor Size	DN100
		Pipe Status	Fluid Present
		Sensor Type	Fullbore
		Sensor Serial No	3K620000168464
		Transmitter Serial No	3K620000168465
		Tag	ABB Warminster
		Location	?

Overall Status: Pass

The flowmeter has passed its internal continuous verification and automatic self calibration. It is working within +/-1% of its original factory calibration

Summary of Results		Verification History	
Coil Group	Passed	OIML Accuracy Alarms	0
Electrode Group	Passed	Totaliser Information	
Sensor Group	Passed		
Transmitter Signal	Passed		
Transmitter Driver	Passed	Forward	26444.76 m3
Output Group	Passed	Reverse	722.70 m3
Configuration	Passed	Net	25722.06 m3
Sensor Information		Sensor Data	
Q3	69.44 l/s	Coil Current	179.9 mA
Calibration Accuracy	OIML Class 2	Coil Inductance	218.4 mH
Sensor Calibration Factors	86.0%; -3.00 mm/s; 11	Coil Inductance Shift	-0.1%
Date of Manufacture	16 May 2014	Coil / Loop Resistance	38.5 ohm
Run Hours	3108days 19hrs 15mins	Transmitter Data	
Transmitter Information		Tx Gain - Adjustment	-0.0%
		VeriMaster Information	
		Version	01.00.03
		Limit Version	01.00.01
Current Output		Pulse Output	
		Output 1: 100.0Hz	Not tested
		Output 1: 50.0Hz	Not tested
		Output 2: 250Hz	Not available for testing
4mA Value	Pass : 4.000 mA ; 0.00%	Output 2: 125Hz	Not available for testing
12mA Value	Pass : 11.980 mA ; 0.17%		
20mA Value	Pass : 19.980 mA ; 0.10%		

Installation Comments / Equipment used:	Configuration Settings
Pump 4	Mains Frequency 60 Hz
	Qmax 10.00 l/s
	Pulses/Unit 120.000000
	Pulses Limit Frequency 100.0 Hz
	Sensor User Span/Zero 100.0%; 0.00 mm/s
	User Flow Cutoff/Hysteresis 1.00%; 20%
	Meter Mode Normal operation

Date Wed, Jun 28, 2023

Operator Signature

Print

ABB Instrumentation World Flow Technology

ABB Limited
Oldends Lane, Stonehouse
Gloucestershire, GL10 3TA UK
Tel: +44(0) 1453 826661
Fax: +44(0) 1453 821121
instrumentation@gb.abb.com

ABB Automation Inc.
125 East County Line Road
Warminster, PA 18974 USA
Tel: +1 215 674 6000
Fax: +1 215 674 6394
instrumentation@gb.abb.com

ABB Australia Pty Ltd.
Bapaune Rd
Moorebank, NSW 2170
Tel: +61-2-982 1-0111
Fax: +61-2-9821-0950

ABB Automation GmbH
Dransfelder Str.2
37079 Gottingen, GERMANY
Tel: +49 (0) 551 905212
Fax: +1 (215) 674 6394



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Appendix VII:
Coagulant Used

From: 01/01/2023 to 31/12/2023

Facility Org Number:	5318
Facility Works Number:	1100038665
Facility Name:	KING'S BAY WASTEWATER TREATMENT FACILITY
Facility Owner:	Municipality: City of Kawartha Lakes
Facility Classification:	Class 2 Wastewater Treatment
Receiver:	Subsurface
Service Population:	200.0
Total Design Capacity:	170.0 m3/day

	01/2023	02/2023	03/2023	04/2023	05/2023	06/2023	07/2023	08/2023	09/2023	10/2023	11/2023	12/2023	Total	Avg	Max	Min
Chem / Coagulant Used - kg																
Count IH	31	28	31	30	31	30	31	31	30	31	30	31				
Max IH	11.38	9.47	10.48	9.75	9.75	9.75	9.75	11.09	13.88	13.41	13	13			13.88	
Mean IH	8.366	7.138	7.401	7.085	7.443	7.73	7.521	7.15	6.487	9.666	8.648	7.907		7.736		
Min IH	5.85	5.71	5.19	6.18	6.18	6.5	3.25	3.25	3.79	3.25	3.25	3.25				3.25
Total IH	259.36	199.86	229.43	212.56	230.728	231.903	233.165	221.66	194.615	305.84	259.44	245.11	2823.671			



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Appendix VIII:
Biosolids Summary

From: 01/01/2023 to 31/12/2023

5318
110003665
KING'S BAY WASTEWATER TREATMENT FACILITY
Municipality: City of Kawartha Lakes
Class 2 Wastewater Treatment
Subsurface
200.0
170.0 m3/day

	01/2023	02/2023	03/2023	04/2023	05/2023	06/2023	07/2023	08/2023	09/2023	10/2023	11/2023	12/2023	Total
Bsq / Hadled Vol. - m³													
Count IH	0	1	1	1	0	1	1	1	1	0	0	1	8
Total IH		35.5	34.5	35.96		35.45	36.62	35.21	34.7			62.04	309.98