

# Fenelon Falls Water Pollution Control Plant

---

Works # 110001612

## Annual Wastewater Performance Report

Prepared For: The City of Kawartha Lakes

Reporting Period of January 1<sup>st</sup> – December 31<sup>st</sup>, 2023

Issued: March 28, 2024

Revision: 0

Operating Authorities:



**2023 Performance Report for the Fenelon Falls Water Pollution Control Plant**

The Fenelon Falls Water Pollution Control Plant, unless noted within this report, complies with all requirements of the regulating authorities and operates under:

- Environmental Compliance Approval (ECA) No. 3688-BW3RGB issued January 15, 2021
- Environmental Compliance Approval (ECA) No. 141-W601 issued October 12, 2022

The Fenelon Falls Water Pollution Control Plant (WPCP) operates under Amended Environmental Compliance Approval (ECA) No. 3688-BW3RGB issued on January 15<sup>th</sup>, 2021. Condition 11.4 of this ECA requires the following:

The Owner shall prepare performance reports on a calendar year basis and submit to the District Manager by March 31 of the calendar year following the period being reported upon. The reports shall contain, but shall not be limited to, the following information pertaining to the reporting period:

- a) a summary and interpretation of all Influent monitoring data, and a review of the historical trend of the sewage characteristics and flow rates;
- b) a summary and interpretation of all Final Effluent monitoring data, including concentration, flow rates, loading and a comparison to the design objectives and compliance limits in this Approval, including an overview of the success and adequacy of the Works;
- c) a summary of all operating issues encountered and corrective actions taken;
- d) a summary of all normal and emergency repairs and maintenance activities carried out on any major structure, equipment, apparatus or mechanism forming part of the Works;
- e) a summary of any effluent quality assurance or control measures undertaken;
- f) a summary of the calibration and maintenance carried out on all Influent and Final Effluent monitoring equipment to ensure that the accuracy is within the tolerance of that equipment as required in this Approval or recommended by the manufacturer;
- g) a summary of efforts made to achieve the design objectives in this Approval, including an assessment of the issues and recommendations for pro-active actions if any are required under the following situations:
  - i. when any of the design objectives is not achieved more than 50% of the time in a year, or there is an increasing trend in deterioration of Final Effluent quality;

## Fenelon Falls Water Pollution Control Plant – 2023 Performance Report

- ii. when the Annual Average Daily Influent Flow reaches 80% of the Rated Capacity;
- h) a tabulation of the volume of sludge generated, an outline of anticipated volumes to be generated in the next reporting period and a summary of the locations to where the sludge was disposed;
- i) a summary of any complaints received and any steps taken to address the complaints;
- j) a summary of all Bypasses, Overflows, other situations outside Normal Operating Conditions and spills within the meaning of Part X of EPA and abnormal discharge events;
- k) a summary of all Notice of Modifications to Sewage Works completed under Paragraph 1.d. of Condition 10, including a report on status of implementation of all modification.
- l) a summary of efforts made to achieve conformance with Procedure F-5-1 including but not limited to projects undertaken and completed in the sanitary sewer system that result in overall Bypass/Overflow elimination including expenditures and proposed projects to eliminate Bypass/Overflows with estimated budget forecast for the year following that for which the report is submitted.
- m) a summary of any deviation from the monitoring schedule and reasons for the current reporting year and a schedule for the next reporting year.

The Environmental Compliance Approval Number 141-W601 for the City of Kawartha Lakes Wastewater Collection System, including the Fenelon Falls Sewage Collection System, stipulates that the Owner shall prepare an annual performance report for the Authorized System that includes:

### **Schedule E – Reporting (4.6)**

- a) a summary of all required monitoring data along with an interpretation of the data and any conclusion drawn from the data evaluation about the need for future modifications to the Authorized System or system operations.
- b) a summary of any operating problems encountered and corrective actions taken.
- c) a summary of all calibration, maintenance, and repairs carried out on any major structure, Equipment, apparatus, mechanism, or thing forming part of the Municipal Sewage Collection System.
- d) a summary of any complaints related to the Sewage Works received during the reporting period and any steps taken to address the complaints.
- e) a summary of all Alterations to the Authorized System within the reporting period that are authorized by this Approval including a list of Alterations that pose a Significant Drinking Water Threat.

## Fenelon Falls Water Pollution Control Plant – 2023 Performance Report

- f) a summary of all Collection System Overflow(s) and Spill(s) of Sewage, including:
  - i. Dates;
  - ii. Volumes and durations;
  - iii. If applicable, loadings for total suspended solids, BOD, total phosphorus, and total Kjeldahl nitrogen, and sampling results for E.coli;
  - iv. Disinfection, if any; and
  - v. Any adverse impact(s) and any corrective actions, if applicable.
- g) a summary of efforts made to reduce Collection System Overflows, Spills, STP Overflows, and/or STP Bypasses, including the following items, as applicable:
  - i. A description of projects undertaken and completed in the Authorized System that result in overall overflow reduction or elimination including expenditures and proposed projects to eliminate overflows with estimated budget forecast for the year following that for which the report is submitted.
  - ii. Details of the establishment and maintenance of a PPCP, including a summary of project progresses compared to the PPCP's timelines.
  - iii. An assessment of the effectiveness of each action taken.
  - iv. An assessment of the ability to meet Procedure F-5-1 or Procedure F-5-5 objectives (as applicable) and if able to meet the objectives, an overview of next steps and estimated timelines to meet the objectives.
  - v. Public reporting approach including proactive efforts

### **Environmental Compliance Approval (ECA) No. 3688-BW3RGB**

The above information is incorporated in the following report format and submitted to the District Manager of the Peterborough District Office of the Ministry of the Environment, Conservation and Parks as per the requirements of ECA No. 3688-BW3RGB.

During the period of 2023, the Ontario Clean Water Agency (OCWA) operated the Fenelon Falls WPCP, Francis Street Pumping Station (SPS), Colborne Street SPS and Ellice Street SPS on behalf of the Corporation of the City of Kawartha Lakes. OCWA's goals have remained consistent during this period and remain consistent with the following priorities:

- provide quality assurance, safety and environmental compliance of facility operations;
- assist our clients in achieving compliance;
- provide advice on up-to-date technology in Operations and Maintenance service delivery.

This report will show that the Ontario Clean Water Agency has made every attempt to achieve its goals through its operational performance. This performance was enhanced through the use of an electronic process data collection database, an electronic maintenance and work order database, an electronic operational excellence database,

## Fenelon Falls Water Pollution Control Plant – 2023 Performance Report


a training program focused on providing the right skills to staff - also captured and tracked by the use of an electronic database and a multi-skilled, flexible workforce.

**(a)** Environmental Compliance Approval (ECA) No. 3688-BW3RGB requires a summary and interpretation of all Influent monitoring data, and a review of the historical trend of the sewage characteristics and flow rates;


The Fenelon Falls WPCP has a Rated Capacity of 1,800m<sup>3</sup>/day. Flows are continuously measured through the plant effluent flow meter located upstream of the sand filters. The influent and effluent streams are considered not significantly different in flow rates and quantities so the effluent flow measurements are also used for influent flow measurements. ECA No. 3688-BW3RGB requires everything practicable be undertaken to operate the STP so that the annual average daily influent is within the Rated Capacity. The 2023 annual average daily influent flow was 1,119.81 m<sup>3</sup>/day or 62% of the Rated Capacity.

The total influent/effluent flow in 2023 was 408,729 m<sup>3</sup>.


**Graph 1: 2023 Influent/Effluent Flow Monthly Totals**



**Graph 2: Influent/Effluent Daily Minimum, Maximum and Average Flows**



**Graph 3: Historical Influent/Effluent Flows from 2013 to 2023**




### **Influent Monitoring - Sewage Characteristics**

#### **Biochemical Oxygen Demand (BOD5)**


ECA No. 3688-BW3RGB requires at least one composite sample be collected and analyzed monthly for Biochemical Oxygen Demand (BOD5). The Biochemical Oxygen Demand (BOD5) monthly average results ranged from 30 mg/L to 170 mg/L.

**Graph 4: 2023 Monthly BOD5 Influent Concentration Comparisons**



### Biochemical Oxygen Demand Historical Trends

**Graph 5: Historical Influent Biochemical Oxygen Demand Concentration Comparisons**




The Biochemical Oxygen Demand (BOD5) annual average has been relatively consistent for the past ten years but has experienced an increase in 2021 and 2022 with a decrease in 2023.


### Total Suspended Solids

ECA No. 3688-BW3RGB requires at least one composite sample be collected and analyzed monthly for Total Suspended Solids. The monthly results ranged from 18mg/L to 144mg/L.

**Graph 6: 2023 Monthly Total Suspended Solids Influent Concentration Comparisons**



**Graph 7: Historical Influent Total Suspended Solids Concentration Comparisons**



### Total Suspended Solids Historical Review


The Total Suspended Solids annual average has been between 52mg/L and 227mg/L showing a slight decrease in 2016 - 2017, an increase in 2021 and a decrease in 2022 and 2023.

### Total Phosphorus


ECA No. 3688-BW3RGB requires at least one composite sample be collected and analyzed monthly for Total Phosphorus. The monthly results ranged from 0.98mg/L to 2.37mg/L.



**Graph 8: 2023 Monthly Total Phosphorus Influent Concentration Comparisons**



**Graph 9: Historical Influent Total Phosphorus Concentration Comparisons**




### Total Phosphorus Historical Trends

The Total Phosphorus annual average in the raw has trended downward since 2012 decreasing from 2.59 mg/L to 1.69mg/L; however, experienced an increase in 2021 while 2022 and 2023 concentration showed a decrease.


### Total Kjeldahl Nitrogen (TKN)

ECA No. 3688-BW3RGB requires at least one composite sample be collected and analyzed monthly for Total Kjeldahl Nitrogen. The monthly Total Kjeldahl Nitrogen results ranged from 6.4mg/L to 22.3mg/L.

**Graph 10: 2023 Monthly Total Kjeldahl Nitrogen Influent Concentration Comparisons**



**Graph 11: Historical Influent Total Kjeldahl Nitrogen Concentration Comparisons**



### Total Kjeldahl Nitrogen Historical Review

The Total Kjeldahl Nitrogen annual average was fairly consistent with a decreasing trend from above 22.7 mg/L to a low of 17.4 mg/L in 2020; however, experienced an increase in 2021 while 2022 and 2023 concentrations returned to historical levels.

Refer to **Appendix I** for Performance Assessment Report which summarizes Influent (raw) BOD<sub>5</sub>, TSS, TP, and TKN Results.

**(b)** Environmental Compliance Approval (ECA) No. 3688-BW3RGB requires a summary and interpretation of all Final Effluent monitoring data, including concentration, flow rates, loading and a comparison to the design objectives and compliance limits in this Approval, including an overview of the success and adequacy of the Works.

The Final Effluent Monitoring Data for 2023 is summarized below and compared to ECA No. 3688-BW3RGB.

Flows are continuous measured through the plant effluent flow meter. The influent and effluent streams are considered not significantly different in flow rates and quantities so the effluent flow measurements are also used for influent flow measurements.

The total influent/effluent flow in 2023 was 408,729m<sup>3</sup>. The effluent flow summary and interpretation are included in a. above with the influent flow summary and interpretation.

**Carbonaceous Biochemical Oxygen Demand (CBOD5) and Total Suspended Solids (TSS)**

ECA No. 3688-BW3RGB has an annual average concentration limit of 25mg/L for CBOD5 and TSS. The annual average results for 2023 are presented in the following table.

**Table 1: CBOD5 and Suspended Solids 2023 Effluent Concentration Results Comparison to Limit**

Effluent Parameter	Annual Average Limit (mg/L)	Annual Average (mg/L)	Compliant Y/N
CBOD5	25	2.95	Y
Total Suspended Solids	25	7.33	Y

ECA No. 3688-BW3RGB has an annual average concentration objective of 15 mg/L for CBOD5 and TSS. The annual average results for 2023 are presented in the following table.

**Table 2: CBOD5 and Suspended Solids 2023 Effluent Concentration Results Comparison to Objectives**

Effluent Parameter	Annual Average Objective (mg/L)	Annual Average (mg/L)	Objective Met Y/N
CBOD5	15	2.95	Y
Total Suspended Solids	15	7.33	Y

ECA No. 3688-BW3RGB has an annual average daily effluent loading limit of 45.0 kg/day for CBOD5 and TSS. The annual average daily loading results for 2023 are presented in the following table.

**Table 3: CBOD5 and Suspended Solids 2023 Effluent Loading Results Comparison to Limits**

Effluent Parameter	Annual Average Daily Loading Limit (mg/L)	Annual Average Daily Loading (mg/L)	Compliant Y/N
CBOD5	45	3.31	Y
Total Suspended Solids	45	8.21	Y

### **Total Phosphorus (TP)**

ECA No. 3688-BW3RGB has a monthly average concentration limit of 0.5 mg/L for Total Phosphorus. The monthly average results for 2023 were calculated as required. The plant had emergency partial bypassing of the sand filters due to weather occurring December 31, 2022- January 6, 2023 and April 05 – 11, 2023. Bypass and Overflow information is included in item 'j' of this report. Results are presented in the following table.

**Table 4: Total Phosphorus 2023 Monthly Average Concentrations Comparison to Limit**


Month	Monthly Average Limit (mg/L)	Effluent Monthly Average (mg/L)	Compliant Y/N
January	0.5	0.13	N
February	0.5	0.08	Y
March	0.5	0.08	Y
April	0.5	0.08	Y
May	0.5	0.11	Y
June	0.5	0.08	Y
July	0.5	0.12	Y
August	0.5	0.14	Y
September	0.5	0.12	Y
October	0.5	0.21	Y
November	0.5	0.14	Y
December	0.5	0.13	Y

ECA No. 3688-BW3RGB has a monthly average concentration objective of 0.3 mg/L for Total Phosphorus. The monthly average results for 2023 were calculated as required and are presented in the following table.

**Table 5: Total Phosphorus 2023 Monthly Average Concentrations Comparison to Objective**

Month	Monthly Average Objective (mg/L)	Effluent Monthly Average (mg/L)	Objective Met Y/N
January	0.3	0.13	Y
February	0.3	0.08	Y
March	0.3	0.08	Y
April	0.3	0.08	Y
May	0.3	0.11	Y
June	0.3	0.08	Y
July	0.3	0.12	Y
August	0.3	0.14	Y
September	0.3	0.12	Y
October	0.3	0.21	Y
November	0.3	0.14	Y
December	0.3	0.13	Y

**Graph 12: 2023 Monthly Final Effluent Total Phosphorus Concentration Comparisons**



ECA No. 3688-BW3RGB has a monthly average daily loading limit of 0.9 kg/d for Total Phosphorus. The monthly average results for 2023 were calculated as required for each approval and are presented in the following table.

**Table 6: Total Phosphorus 2023 Monthly Average Daily Loading Comparison to Limit**

Month	Monthly Average Daily Loading Limit (kg/d)	Effluent Monthly Average Daily Loading (kg/d)	Compliant Y/N
January	0.9	0.19	Y
February	0.9	0.11	Y
March	0.9	0.11	Y
April	0.9	0.13	Y
May	0.9	0.14	Y
June	0.9	0.07	Y
July	0.9	0.11	Y
August	0.9	0.12	Y
September	0.9	0.09	Y
October	0.9	0.18	Y
November	0.9	0.12	Y
December	0.9	0.16	Y

### **Total Ammonia Nitrogen (TAN)**

ECA No. 3688-BW3RGB has monthly Total Ammonia Nitrogen (TAN) concentration limits based on seasonal periods within the annual year. The following table compares monthly results to the limits for seasonal concentrations. The plant had emergency partial bypassing of the sand filters due to weather occurring December 31, 2022- January 6, 2023 and April 05 – 11, 2023. Bypass and Overflow information is included in item j of this report.

**Table 7: Total Ammonia Nitrogen 2023 Monthly Average Concentration Comparison to Limits**

Month	Monthly Average Concentration Limit (mg/L)	Effluent Monthly Average (mg/L)	Compliant Y/N
January	7.0	<0.10	Y
February	7.0	0.20	Y
March	7.0	1.68	Y
April	3.5	<0.92	Y
May	3.5	1.56	Y
June	3.5	<0.30	Y
July	3.5	<0.10	Y
August	3.5	<1.42	Y

## Fenelon Falls Water Pollution Control Plant – 2023 Performance Report


Month	Monthly Average Concentration Limit (mg/L)	Effluent Monthly Average (mg/L)	Compliant Y/N
September	3.5	<0.23	Y
October	3.5	<0.26	Y
November	7.0	<0.48	Y
December	7.0	<0.83	Y

Total Ammonia Nitrogen (TAN) concentration objectives are calculated monthly based on seasonal periods within the annual year for ECA No. 3688-BW3RGB. The following table compares all results to the objectives for seasonal concentrations. As previously noted, the plant had emergency partial bypassing of the sand filters due to weather occurring December 31, 2022- January 6, 2023 and April 05 – 11, 2023. Bypass and Overflow information is included in item j of this report.

**Table 8: Total Ammonia Nitrogen 2023 Monthly Average Concentration Comparison to Objectives**

Month	Monthly Average Concentration Objective (mg/L)	Effluent Monthly Average (mg/L)	Objective Met Y/N
January	5.0	<0.10	Y
February	5.0	0.20	Y
March	5.0	1.68	Y
April	2.5	<0.92	Y
May	2.5	1.56	Y
June	2.5	<0.30	Y
July	2.5	<0.10	Y
August	2.5	<1.42	Y
September	2.5	<0.23	Y
October	2.5	<0.26	Y
November	5.0	<0.48	Y
December	5.0	<0.83	Y

**Graph 13: 2023 Monthly Final Effluent Total Ammonia Nitrogen Concentration Comparisons**



Total Ammonia Nitrogen (TAN) monthly average daily loading limits are calculated based on seasonal periods within the annual year for ECA No. 3688-BW3RGB. The following table compares all results to the limits for monthly average daily loading results. As previously noted, the plant had emergency partial bypassing of the sand filters due to weather occurring December 31, 2022- January 6, 2023 and April 05 – 11, 2023. Bypass and Overflow information is included in item j of this report.

**Table 9: Total Ammonia Nitrogen 2023 Monthly Average Daily Loading Results Comparison to Limits**

Month	Monthly Average Daily Loading Limit (kg/d)	Effluent Monthly Average Daily Loading (kg/d)	Compliant Y/N
January	12.6	<0.14	Y
February	12.6	<0.26	Y
March	12.6	<2.39	Y
April	6.3	<2.65	Y
May	6.3	<1.95	Y
June	6.3	<0.30	Y
July	6.3	<0.09	Y
August	6.3	<1.23	Y
September	6.3	<0.17	Y
October	6.3	<0.22	Y
November	12.6	<0.43	Y
December	12.6	<0.97	Y



## **E. Coli**

ECA No. 3688-BW3RGB has a compliance monthly geometric mean density limit of 200 cfu/100mL. Many wastewater treatment facilities must test for and report results using a 'Geometric Mean' (average) of all the test results obtained during a specific reporting period. The geometric mean calculation is different than a normal arithmetic mean (average) calculation and is considered to be a more accurate calculation. A geometric mean, unlike an arithmetic mean, tends to dampen the effect of very high or low values which might bias the mean if a straight average (arithmetic mean) were calculated.

The following provides monthly geometric mean density values of E. Coli in effluent for each month in 2023.

**Table 10: E. Coli 2023 Results Comparison to Limit**

<b>Month</b>	<b>Monthly Geometric Mean Density of E. Coli (org/100mL)</b>	<b>Compliant with Limit of 200 cfu/100 mL Y/N</b>
<b>January</b>	2	Y
<b>February</b>	1	Y
<b>March</b>	3	Y
<b>April</b>	4	Y
<b>May</b>	2	Y
<b>June</b>	2	Y
<b>July</b>	2	Y
<b>August</b>	2	Y
<b>September</b>	2	Y
<b>October</b>	2	Y
<b>November</b>	2	Y
<b>December</b>	4	Y

ECA No. 3688-BW3RGB has a monthly geometric mean E. Coli objective of 150 cfu/100mL. The following provides monthly geometric mean density values of E. Coli in effluent for each month in 2023 compared to the objective.

**Table 11: E. Coli 2023 Results Comparison to Objective**

<b>Month</b>	<b>Monthly Geometric Mean Density of E. Coli (org/100mL)</b>	<b>Met Objective of 150 cfu/100mL Y/N</b>
<b>January</b>	2	Y
<b>February</b>	1	Y
<b>March</b>	3	Y
<b>April</b>	4	Y
<b>May</b>	2	Y
<b>June</b>	2	Y

Month	Monthly Geometric Mean Density of E. Coli (org/100mL)	Met Objective of 150 cfu/100mL Y/N
July	2	Y
August	2	Y
September	2	Y
October	2	Y
November	2	Y
December	4	Y

## **pH**

ECA No. 3688-BW3RGB has a pH compliance limit within the range of 6.0 to 9.5, inclusive, for every single sample result. Every pH reading in 2023 was within the compliance limits. A summary of effluent pH measurements recorded in 2023 is provided in **Appendix I**.

**Table 12: pH 2023 Results Comparison to Limit**

Limit 6.0 – 9.5	ECA No. 3688-BW3RGB Every Single Sample Result Compliant Y/N
Results range: 6.42 – 7.81	Y

ECA No. 3688-BW3RGB has a pH objective within the range of 6.0 to 9.5, inclusive, for every single sample result.

**Table 13: pH 2023 Results Comparison to Objective**

Objective 6.5 – 9.0	ECA No. 3688-BW3RGB Every Single Sample Result Objective Met Y/N
Results range: 6.42 – 7.81	N

Field pH results were below the lower objective of 6.5 as follows:

June 08      6.42  
June 26      6.48

## **Un-ionized Ammonia**

The concentration of un-ionized ammonia is calculated using the TAN concentration, field pH and field temperature using the methodology stipulated in “Ontario’s Provincial

## Fenelon Falls Water Pollution Control Plant – 2023 Performance Report

Water Quality Objectives” dated July 1994, as amended. Un-ionized ammonia results are provided in **Appendix I**.

The results in the preceding tables show the limits for concentrations and loadings of the final effluent CBOD5, Total Ammonia Nitrogen, Total Phosphorus and Total Suspended Solids were met. E. Coli results met the limits and objectives of ECA No. 3688-BW3RGB. All results for pH met the limits required by ECA No. 3688-BW3RGB; however, two results for field pH were below the lower objective of 6.5 as noted earlier in this report.

Refer to **Appendix I** for Performance Assessment Report and Summaries of Effluent CBOD5, TSS, TP, TAN, TKN, E. Coli, and pH Results. Also included in **Appendix I** are the un-ionized ammonia results for 2023.

(c) a summary of all operating issues encountered and corrective actions taken;

The following table describes all operating problems encountered during the reporting period and the corrective actions taken. Please note, the first challenge noted in the below table was reported in the Fenelon Falls WPCP 2022 Annual Report but a portion of the challenge occurred in 2023, see below for details.

**Table 14: Summary of Operating Issues**

Date	Challenges	Corrective Actions
<b>Dec 31 2022 – Jan 6, 2023</b>	Unseasonably warm temperatures, heavy rain/storm events after significant snowfall accumulation resulted in high flows – secondary treatment and disinfection provided; however, sand filters hydraulically overloaded and required partial bypassing.	Flows, process monitored throughout event – samples collected and analyzed as per ECA requirements. Detention tank utilized, additional staff called in to assist. Notifications made to MOH and SAC.
<b>April 5-11, 2023</b>	A heavy rainfall event and snow melt resulted in high flows- secondary treatment and disinfection provided; however, sand filters hydraulically overloaded and required partial bypassing	Flows, process monitored throughout event – samples collected and analyzed as per ECA requirements. Detention tank utilized, additional staff called in to assist, additional hauling by licensed sewage hauler from Francis St. SPS to plant. Notifications made to MOH and SAC.
<b>April 5-6, 2023</b>	A heavy rainfall event and snow melt caused high flows resulting in raw sewage overflow at Colborne St. SPS.	Monitored flows, detention tank utilized, additional staff called in to assist, additional hauling by licensed sewage hauler from Francis St SPS to plant to help reduce volume. Notifications made to MOH and SAC.

**(d)** a summary of all normal and emergency repairs and maintenance activities carried out on any major structure, equipment, apparatus or mechanism forming part of the Works;

OCWA uses a Work Maintenance System (WMS) to schedule normal maintenance activities and track repairs. WMS is a maintenance tracking system that can generate work orders as well as give summaries of completed and scheduled work. During the year, the operating authority at the facility generates scheduled work orders on a weekly, monthly and annual basis. The service work is recorded in the work order history. This ensures routine and preventive maintenance is carried out and assets are maintained to manufacturer's and/or industry standards. Emergency and capital repair maintenance is completed and added to the system.

Refer to **Appendix II** for work order and maintenance summary.

**(e)** a summary of any effluent quality assurance or control measures undertaken;

Effluent quality assurance is maintained in several ways. Laboratory samples are sent to accredited laboratory (SGS Lakefield) for analysis of all effluent parameters. Sampling calendars issued to the operator denote frequency of sampling and these calendars are submitted to the Process Compliance Technician at the end of each month. Raw and effluent samples are collected as per ECA No. 3688-BW3RGB and the results are reviewed on a regular basis to ensure compliance with the site's objectives and limits.

Effluent control measures include in-house sampling and testing for operational parameters such as pH, temperature, phosphorus, dissolved oxygen, 30-minute settling and Mixed Liquor Suspended Solids (MLSS). In-house testing provides real time results which are then evaluated to determine if process changes are necessary to enhance operational performance. All in-house sampling and analysis are performed by certified operations staff utilizing approved methods and protocols for sampling, analysis and recording as specified in the Ministry's Procedure F-10-1, "Procedures for Sampling and Analysis Requirements for Municipal and Private Sewage Treatment Works", the Ministry's publication, "Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater" and the publication, "Standard Methods for the Examination of Water and Wastewater".

Work orders are scheduled through our asset maintenance management system to ensure preventative and corrective maintenance is completed and recorded by operations staff. A summary is attached as **Appendix II**. Flow meters are calibrated annually and the 2023 calibration report is provided in **Appendix III**.

OCWA conducts internal audits of facilities and develops Action Plans to ensure deficiencies are identified and corrected. OCWA has developed comprehensive manuals detailing operations, maintenance, instrumentation and emergency procedures. To ensure facilities are operated in compliance with applicable legal

requirements, facility staff has access to a network of compliance and support professionals at the hub, region and corporate level. Continuous phosphorus removal is achieved with the dosing of aluminum sulphate. A summary of its use and dosing rates for 2023 is provided in the following table.

**Table 15: Coagulant Use and Dosing 2023**

Month	Aluminum Sulphate (kg)	Aluminum Sulphate Average Dosage (mg/L)
January	1927.58	52.25
February	1472.70	52.41
March	1887.80	48.91
April	1653.50	35.59
May	1817.90	50.83
June	1710.60	60.76
July	1580.00	58.16
August	1669.50	62.64
September	1756.80	75.99
October	1806.00	71.14
November	1700.60	63.02
December	1916.98	54.90

(f) a summary of the calibration and maintenance carried out on all Influent and Final Effluent monitoring equipment to ensure that the accuracy is within the tolerance of that equipment as required in this Approval or recommended by the manufacturer;

Refer to **Appendix III** for 2023 calibration reports.

(g) a summary of efforts made to achieve the design objectives in this Approval, including an assessment of the issues and recommendations for pro-active actions if any are required under the following situations:

(i) when any of the design objectives is not achieved more than 50% of the time in a year, or there is an increasing trend in deterioration of Final Effluent quality;

(ii) when the Annual Average Daily Influent Flow reaches 80% of the Rated Capacity;

Continuous efforts were made to meet the Effluent Objectives in 2023:

1. Development of the sampling plan which meets or exceeds the minimum sample requirements as required in the ECA;
2. Visual Inspection of the entire process while performing rounds including visual inspection of effluent to ensure it did not contain oil or other substance in amounts sufficient to create a visible film or sheen on the surface of the receiving waters, and which was essentially free of any floating material;

## Fenelon Falls Water Pollution Control Plant – 2023 Performance Report


3. Influent monitoring;
4. Ensuring that chemicals are being dosed as required;
5. Calibration of lab equipment;
6. Annual calibration of flow meters;
7. Oxidation ditch increased DO monitoring;
8. Ensure UV is providing disinfection, both banks on regardless of flow rates;
9. Performing preventative maintenance activities in accordance with work order schedules;
10. Performing in-house lab tests;
11. Monitoring treatment processes by performing regular laboratory analysis and reviewing of lab results;
12. Biosolids monitoring

Effluent design objectives were met 100% of the time for CBOD, Total Suspended Solids, TAN, Total Phosphorus monthly concentration and E. Coli. The pH objective was met 98.9% in 2023. Two partial sand filter bypasses that occurred in January and April were sampled as required by ECA No. 3688-BW3RGB. One overflow occurred at the Colborne St. SPS in April and was sampled as required by ECA No. 141-W601. Details of the bypasses and sampling results are included under Condition ‘j’.

The ECA states the plant has a Rated Capacity of 1,800 m<sup>3</sup>/day. The Rated Capacity means the Average Daily Flow for which the plant is approved to treat. The Average Daily Flow is determined by the cumulative total sewage flow into the plant during a calendar year, which is then divided by the number of days during which sewage flowed into the plant. The annual average daily influent flow for 2023 is 1,119.81 m<sup>3</sup>/day or 62% of the Rated Capacity.

The following graph shows the plant has been operating within the Rated Capacity for the past ten years.

**Graph 14: Average Sewage Flow and Rated Capacity Comparisons**



(h) a tabulation of the volume of sludge generated, an outline of anticipated volumes to be generated in the next reporting period and a summary of the locations to where the sludge was disposed;

Attached is **Appendix IV: Sludge/Biosolids Summary** that contains quantities of organics, inorganics, E. coli and volumes of Biosolids/sludge generated for the reporting period, which was a total of 2,389.5 m<sup>3</sup>. This is a slight decrease from 2022 when 2,439.6m<sup>3</sup> of biosolids were hauled. The anticipated volume for the next reporting period is not expected to be appreciably different from this reporting period.

Biosolids from the Fenelon Falls WPCP were hauled, stored and land applied by Shepherds Environmental in 2023 and will be again in 2024. The Biosolids are hauled to fields with a valid NASM Plan (NASM Plan 23771) or to A710160 Shepherds Environmental Storage Structure.

(i) a summary of any complaints received and any steps taken to address the complaints;

**Table 16: Complaints Received Summary for 2023**

Date	Issue	Actions Taken
	None received for 2023	

(j) a summary of all Bypasses, Overflows, other situations outside Normal Operating Conditions and spills within the meaning of Part X of EPA and abnormal discharge events;

The following table summarizes all Bypasses, Overflows and other situations outside of Normal Operating Conditions and spills and abnormal discharge events that occurred in 2023. The Operations Event Forms and sampling results for these events are provided in **Appendix V**. All were reported to MOH, MECP and the City.

**Table 17: 2023 Summary of Events as per Condition 11.4 j**

Date 2023	Type of Event	Total Volume (m <sup>3</sup> )	Disinfect (Y/N)	Samples Collected (Y/N)	Reason
Dec 31, 2022 – Jan 6, 2023	Partial Sand Filter Bypass	3,381	Y	Y	Wet weather event
April 5 – 11, 2023	Partial Sand Filter Bypass	2,417	Y	Y	Wet weather event

## Fenelon Falls Water Pollution Control Plant – 2023 Performance Report

Date 2023	Type of Event	Total Volume (m <sup>3</sup> )	Disinfect (Y/N)	Samples Collected (Y/N)	Reason
April 5 – 6, 2023	Colborne St. SPS Overflow	2,220	N	Y	Wet weather event

ECA No. 3688-BW3RGB requires submission of quarterly summary reports of any Bypass Events and Overflows Events. Copies of these reports are provided in **Appendix V**.

**(k)** summary of all Notice of Modifications to Sewage Works completed under Paragraph 1.d. of Condition 10, including a report on status of implementation of all modification.

No Notice of Modifications was submitted in 2023 to the District Manager as a result of Schedule B, Section 1.

**(l)** a summary of efforts made to achieve conformance with Procedure F-5-1 including but not limited to projects undertaken and completed in the sanitary sewer system that result in overall Bypass/Overflow elimination including expenditures and proposed projects to eliminate Bypass/Overflows with estimated budget forecast for the year following that for which the report is submitted;

The Fenelon Falls Sewage Pumping Station #1 Ellice St. SCADA programming was updated in 2023 to include a high flow mode to allow more than one pump to operate at one time automatically to send wastewater to the Fenelon Falls Water Pollution Control Plant once a sand filter bypass has been initiated. Previous to the updated SCADA programming, only one pump could be operated at one time automatically at the Fenelon Falls Sewage Pumping Station #1 Ellice St. More than one pump could be operated manually, with operations monitoring levels and flows.

The City of Kawartha Lakes continues to work on a Master Servicing Study and Capacity Assessment for all facilities analyzing existing capacity and future growth requirements. Sanitary sewer flushing is conducted on an annual basis (3 years of dead ends/trouble areas and 4<sup>th</sup> year is full system flush). During this program, any manholes with infiltration issues are identified and are included in operational maintenance contracts for grouting, frame and cover replacements, etc. In 2023 the entire collection system was flushed and CCTV inspected. The CCTV inspection records were reviewed by an engineering consultant who prepared a deficiency list, and assigned a priority ranking to each one. Any repair work identified will be tendered in 2024. Below is a summary of operational manhole rehabilitation that was undertaken in 2023 to help reduce I&I.

### **Manhole Rehabilitation**

MH2133 John St. – Manhole Grouting



## Fenelon Falls Water Pollution Control Plant – 2023 Performance Report

MH2026 91 Queen St. – Replace 14" Moduloc + New Frame and Cover  
MH2054 Queen St. @ John St. – Replace 12" Moduloc + New Frame and Cover  
MH2036 Clifton @ Head St. – Replace 6" Moduloc + New Frame and Cover  
MH2094 93 Francis St. East – Replace 8" Moduloc + New Frame and Cover  
MH2015 Lindsay St @ Green St. – Replace 8" Moduloc + New Frame and Cover  
MH2182 13 Eva St. – Replaced cracked manhole lid  
MH2043 8 Ellice St. – Replace Frame and Cover  
MH2677 68 Ellice St. – Replace Frame and Cover

### **Rain Bladder Installs**

MH2117 Francis St. W  
Market St. @ Francis St. W  
140 Lindsay St.  
John St. (between Francis and Bond)

**(m)** a summary of any deviation from the monitoring schedule and reasons for the current reporting year and a schedule for the next reporting year;

ECA No. 3688-BW3RGB Schedule D Monitoring Program describes the requirement for sample collection at the following locations, frequencies and by means of the specified sample type and analyzed for each parameter listed and all results recorded:

**Table 18: Influent – Influent Sampling Point**

Parameter	Type of Sample	Minimum Sampling Frequency
BOD <sub>5</sub>	24 hour composite	Monthly
Total Suspended Solids	24 hour composite	Monthly
Total Phosphorus	24 hour composite	Monthly
Total Kjeldahl Nitrogen	24 hour composite	Monthly

**Table 19: Final Effluent – Final Effluent Sampling Point**

Parameter	Type of Sample	Minimum Sampling Frequency
CBOD <sub>5</sub>	24 hour composite	Weekly
Total Suspended Solids	24 hour composite	Weekly
Total Phosphorus	24 hour composite	Weekly
Total Ammonia Nitrogen	24 hour composite	Weekly
Total Kjeldahl Nitrogen	24 hour composite	Weekly
Nitrate as Nitrogen	24 hour composite	Weekly
Nitrite as Nitrogen	24 hour composite	Weekly
E. Coli	Grab	Weekly
pH*	Grab/Probe/Analyzer	Weekly
Temperature*	Grab/Probe/Analyzer	Weekly
Un-ionized Ammonia**	As Calculated	Weekly

## Fenelon Falls Water Pollution Control Plant – 2023 Performance Report

\*pH and temperature of the Final Effluent shall be determined in the field at the time of sampling for Total Ammonia Nitrogen.

\*\*The concentration of un-ionized ammonia shall be calculated using the total ammonia concentration, pH and temperature using the methodology stipulated in “Ontario’s Provincial Water Quality Objectives” dated July 1994, as amended.

The following tables provide a summary of the number of samples collected each month for those parameters required for analysis.

**Table 20: Number of Raw Sewage Parameters Tested in 2023**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
BOD <sub>5</sub>	1	1	1	1	1	1	1	1	1	1	1	1
TSS	1	1	1	1	1	1	1	1	1	1	1	1
Total P	1	1	1	1	1	1	1	1	1	1	1	1
TKN	1	1	1	1	1	1	1	1	1	1	1	1

**Table 21: Number of Final Effluent Parameters Tested in 2023**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
cBOD <sub>5</sub>	10	4	4	10	5	4	4	5	4	5	4	4
TSS	10	4	4	10	5	4	4	5	4	5	4	4
Total P	10	4	4	10	5	4	4	5	4	5	4	4
Total Ammonia Nitrogen	10	4	4	10	5	4	4	5	4	5	4	4
TKN	5	4	4	4	5	4	4	5	4	5	4	4
Nitrite as N	5	4	4	4	5	4	4	5	4	5	4	4
Nitrate as N	5	4	4	4	5	4	4	5	4	5	4	4
E. Coli	5	4	4	4	5	4	4	5	4	5	4	4
pH	17	13	15	13	16	15	15	16	13	15	14	15
Temp °C	17	13	15	13	16	15	15	16	13	15	14	15
Unionized Ammonia (calculated)	10	4	4	4	5	4	4	5	4	5	4	4

The required number of influent and final effluent samples were collected at the specified locations and frequencies during the reporting period as per ECA No. 3688-BW3RGB Schedule D. There following are deviations from the scheduled sampling calendar in 2023:

January - additional sampling during partial sand filter bypassing

April - Sample day shifted due to timing of ending of partial sand filter bypass event/bypass sampling.

October - Sample day shifted due to the new statutory holiday of the National Day of Truth and Reconciliation

## Fenelon Falls Water Pollution Control Plant – 2023 Performance Report

ECA No. 3688-BW3RGB Schedule D prescribes the following sampling requirements for Sludge/Biosolids as shown in the following table.

**Table 22: Sludge/Biosolids – Holding Tank/Truck Loading Bay**

Parameter	Type of Sample	Minimum Sampling Frequency
Total Solids	Grab	Quarterly
Total Phosphorus	Grab	Quarterly
Total Ammonia Nitrogen	Grab	Quarterly
Nitrate as Nitrogen	Grab	Quarterly
Metal Scan - Arsenic - Cadmium - Cobalt - Chromium - Copper - Lead - Mercury - Molybdenum - Nickel - Potassium - Selenium - Zinc	Grab	Quarterly

**Table 22: Number of Sludge/Biosolids Parameters Tested in 2023**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Total Solids	0	2	1	0	2	1	1	2	1	1	1	1
TP	0	2	1	0	2	1	1	2	1	1	1	1
TAN	0	2	1	0	2	1	1	2	1	1	1	1
Nitrate as Nitrogen	0	2	1	0	2	1	1	2	1	1	1	1
Arsenic	0	2	1	0	2	1	1	2	1	1	1	1
Cadmium	0	2	1	0	2	1	1	2	1	1	1	1
Cobalt	0	2	1	0	2	1	1	2	1	1	1	1
Chromium	0	2	1	0	2	1	1	2	1	1	1	1
Copper	0	2	1	0	2	1	1	2	1	1	1	1
Lead	0	2	1	0	2	1	1	2	1	1	1	1
Mercury	0	2	1	0	2	1	1	2	1	1	1	1
Molybdenum	0	2	1	0	2	1	1	2	1	1	1	1
Nickel	0	2	1	0	2	1	1	2	1	1	1	1
Potassium	0	2	1	0	2	1	1	2	1	1	1	1

## Fenelon Falls Water Pollution Control Plant – 2023 Performance Report

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Selenium	0	2	1	0	2	1	1	2	1	1	1	1
Zinc	0	2	1	0	2	1	1	2	1	1	1	1

Sludge/biosolids samples are collected typically once per month when sludge/biosolids are hauled from the facility with the exception of January and April 2023. Sludge was not required to be hauled during these months. This meets the required minimum number samples at the specified location and frequency during the reporting period as required by ECA No. 3688-BW3RGB Schedule D.

The 2024 sample schedule for the Fenelon Falls WPCP is provided in **Appendix VII**.


### **Environmental Compliance Approval (ECA) No. 141-W601**

**4.6 (a) a summary of all required monitoring data along with an interpretation of the data and any conclusion drawn from the data evaluation about the need for future modifications to the Authorized System or system operations.**

The Fenelon Falls Sewage Collection System consists of works for the collection and transmission of sewage, comprising approximately 13.4 km in total linear length of gravity sewers discharging to three sewage pumping stations, eventually leading to the Fenelon Falls Water Pollution Control Plant.


See the below graphs for a summary of the flow meter data gathered at the Fenelon Falls Sewage Pumping Station 2 & 3:

**Graph 15: Fenelon Falls Sewage Pumping Station 2 Daily Minimum, Maximum and Average Flows**



Note: The program used to complete the above summary has a maximum daily value the program could capture at the Fenelon Falls Sewage Pumping Station 2. The maximum value the program can capture is: 1000 m³/day.

**Graph 16: Fenelon Falls Sewage Pumping Station 3 Daily Minimum, Maximum and Average Flows**



Refer to Graph 1: 2023 Influent/Effluent Flow Monthly Totals, Graph 2: Influent/Effluent Daily Minimum, Maximum and Average Flows and Graph 3: Historical Influent/Effluent Flows from 2013 to 2023 for additional information related to the raw water being conveyed from the Fenelon Falls Sewage Collection System to the wastewater treatment facility.

### Fenelon Falls Sewage Pumping Station Trends

The flows captured in the above graphs for the Fenelon Falls Sewage Pumping Stations 1 & 2 show increases in maximum daily flows when high flow events occurred in January and April. The wet weather flow detention tank located at the Fenelon Falls Sewage Pumping Station 1 was utilized in 2023.

### Pumping Station Overflow Monitoring Data

The Fenelon Falls Sewage Collection system had one Overflow in 2023. Please see Table 17: 2023 Summary of Events as per Condition 3.4.1 (b) and 4.2.1 along with The Operations Event Form and sampling results for the event provided in **Appendix V**. Below is a summary of the sample results from the samples collected during the one Overflow in 2023:

**Table 23: 2023 Overflow Sample Summary**

Date	BOD (mg/L)	TSS (mg/L)	Total Phosphorus (mg/L)	Total Kjeldahl Nitrogen (mg/L)	E. Coli (org/100mL)
April 5, 2023	29.0	21.0	0.66	5.1	NDOGEC*
April 6, 2023	26.0	36.0	1.04	8.7	NDOGEC*

\*NDOGEC: No Data: Overgrown with E. Coli

### Monitoring Data Evaluation

As the annual average daily influent flow of the Fenelon Falls WWTP was 1,119.81 m³/day or 62% of the Rated Capacity and the single Overflow event within the sewage

collection system was caused by a heavy rainfall event and melting snow, the monitoring data does not indicate the need for future modifications at this time.

**4.6 (b) a summary of any operating problems encountered and corrective actions taken.**

**Table 24: 2023 Operating Problems & Corrective Actions**

Date	Operating Problem	Corrective Action(s)
April 5-6, 2023	A heavy rainfall event and snow melt caused high flows resulting in raw sewage overflow at Colborne St. SPS.	Monitored flows, detention tank utilized, additional staff called in to assist, additional hauling by licensed sewage hauler from Francis St SPS to plant to help reduce volume. Notifications made to MOH and SAC.

**4.6 (c) a summary of all calibration, maintenance, and repairs carried out on any major structure, Equipment, apparatus, mechanism, or thing forming part of the Municipal Sewage Collection System.**

A regular scheduled calibration and maintenance program has been kept up to date as scheduled on a daily, weekly, semi-annual and annual basis. All equipment calibration & maintenance scheduling and standard procedures are provided by Maximo Computerized Maintenance System.

Attached is **Appendix II**: Maintenance Summary, a Work Order Summary report, showing all preventive and corrective maintenance activities performed at the Fenelon Falls Water Pollution Control Plant, including the collection system, during 2023.

Attached is **Appendix III**: Calibration Report, flow meters are calibrated annually.

**4.6 (d) a summary of any complaints related to the Sewage Works received during the reporting period and any steps taken to address the complaints.**

Complaints related to the Fenelon Falls Sewage Collection System and steps taken to address the complaints are included in Table 16: Complaints Received Summary for 2023.

**4.6 (e) a summary of all Alterations to the Authorized System within the reporting period that are authorized by this Approval including a list of Alterations that pose a Significant Drinking Water Threat.**

There were no Alterations made to the Fenelon Falls Sewage Collection System in 2023.

**4.6 (f) a summary of all Collection System Overflow(s) and Spill(s) of Sewage, including:**

- i) Dates;
- ii) Volumes and durations;
- iii) If applicable, loadings for total suspended solids, BOD, total phosphorus, and total Kjeldahl nitrogen, and sampling results for E.coli;

**iv) Disinfection, if any; and**

**v) Any adverse impact(s) and any corrective actions, if applicable.**

The Fenelon Falls Sewage Collection system had one Overflow. Please see Table 17: 2023 Summary of Events as per Condition 11, 4(j) in ECA 3688-BW3RGB and The Operations Event Form and sampling results for the event is provided in **Appendix V**.

**4.6 (g) a summary of efforts made to reduce Collection System Overflows, Spills, STP Overflows, and/or STP Bypasses, including the following items, as applicable:**

**i) A description of projects undertaken and completed in the Authorized System that result in overall overflow reduction or elimination including expenditures and proposed projects to eliminate overflows with estimated budget forecast for the year following that for which the report is submitted.**

The City of Kawartha Lakes continues to work on a Master Servicing Study and Capacity Assessment for all facilities analyzing existing capacity and future growth requirements. Sanitary sewer flushing is conducted on an annual basis (3 years of dead ends/trouble areas and 4<sup>th</sup> year is full system flush). During this program, any manholes with infiltration issues are identified and are included in operational maintenance contracts for grouting, frame and cover replacements, etc. In 2023 the entire collection system was flushed and CCTV inspected. The CCTV inspection records were reviewed by an engineering consultant who prepared a deficiency list, and assigned a priority ranking to each one. Any repair work identified will be tendered in 2024. Below is a summary of operational manhole rehabilitation that was undertaken in 2023 to help reduce I&I.

In addition, where manholes are located in lower lying areas and are at risk of being submerged and contributing to inflow, rain bladders are installed to prevent excess water from entering the system, further reducing the risk of overflow.

MH2133 John St. – Manhole Grouting  
MH2026 91 Queen St. – Replace 14” Moduloc + New Frame and Cover  
MH2054 Queen St. @ John St. – Replace 12” Moduloc + New Frame and Cover  
MH2036 Clifton @ Head St. – Replace 6” Moduloc + New Frame and Cover  
MH2094 93 Francis St. East – Replace 8” Moduloc + New Frame and Cover  
MH2015 Lindsay St @ Green St. – Replace 8” Moduloc + New Frame and Cover  
MH2182 13 Eva St. – Replaced cracked manhole lid  
MH2043 8 Ellice St. – Replace Frame and Cover  
MH2677 68 Ellice St. – Replace Frame and Cover  
MH2117 Francis St. W – rain bladder installation  
MH2120 Market St. @ Francis St. W – rain bladder installation  
MH2174 140 Lindsay St. – rain bladder installation  
MH2158 John St. (between Francis and Bond) – rain bladder installation

In 2024, there is a capital project to rehabilitate sections of the collection system that were identified as deficient in the CCTV inspections completed in 2023. This

work has a budget of \$400,000. In addition, \$35,000 has been budgeted for operational repairs.

**ii) Details of the establishment and maintenance of a PPCP, including a summary of project progresses compared to the PPCP's timelines.**

The Fenelon Falls Sewage Collection system does not contain combined sewers and therefore is not required to complete a Pollution Prevention and Control Plan (PPCP).

**iii) An assessment of the effectiveness of each action taken.**

None to report at this time.

**iv) An assessment of the ability to meet Procedure F-5-1 or Procedure F-5-5 objectives (as applicable) and if able to meet the objectives, an overview of next steps and estimated timelines to meet the objectives.**

A summary of efforts is included in Section I of this report.

**v) Public reporting approach including proactive efforts**

SOP WWC02 Waterwater Bypass/Overflow Notification Procedure has been developed and has been in practice since 2021, which clearly outlines all reporting protocols to both regulatory agencies and the public in various situations. This procedure was developed in consultation with Ontario Clean Water Agency, Ministry of Environment, Conservation and Parks and Ministry of Health.



# Appendix I

---

**Performance Assessment Report**

**Effluent Field pH**

**Effluent Un-Ionized Ammonia Results**

**5886 FENELON FALLS WASTEWATER TREATMENT FACILITY 110001612**

	1/ 2023	2/ 2023	3/ 2023	4/ 2023	5/ 2023	6/ 2023	7/ 2023	8/ 2023	9/ 2023	10/ 2023	11/ 2023	12/ 2023	<--Total-->	<--Avg-->	<--Max-->
<b>Flows</b>															
Raw Flow: Total - Raw m <sup>3</sup> /d	43,358.00	36,781.00	44,300.00	49,555.00	38,680.00	29,580.00	27,277.00	26,821.00	23,194.00	25,685.00	27,215.00	36,283.00	408,729.00		
Raw Flow: Avg - Raw m <sup>3</sup> /d	1,398.65	1,313.61	1,429.03	1,651.83	1,247.74	986.00	879.90	865.19	773.13	828.55	907.17	1,170.42		1,119.81	
Raw Flow: Max - Raw m <sup>3</sup> /d	3,509.00	2,837.00	2,549.00	3,397.00	2,785.00	1,656.00	1,060.00	1,071.00	865.00	1,064.00	1,164.00	1,761.00			3,509.00
Raw Flow: Count - Raw m <sup>3</sup> /d	31.00	28.00	31.00	30.00	31.00	30.00	31.00	31.00	30.00	31.00	30.00	31.00	365.00		
Eff. Flow: Total - Eff m <sup>3</sup> /d	43,358.00	36,781.00	44,300.00	49,555.00	38,680.00	29,580.00	27,277.00	26,821.00	23,194.00	25,685.00	27,215.00	36,283.00	408,729.00		
Eff. Flow: Avg - Eff m <sup>3</sup> /d	1,398.65	1,313.61	1,429.03	1,651.83	1,247.74	986.00	879.90	865.19	773.13	828.55	907.17	1,170.42		1,119.81	
Eff. Flow: Max - Eff m <sup>3</sup> /d	3,509.00	2,837.00	2,549.00	3,397.00	2,785.00	1,656.00	1,060.00	1,071.00	865.00	1,064.00	1,164.00	1,761.00			3,509.00
Eff Flow: Count - Eff m <sup>3</sup> /d	31.00	28.00	31.00	30.00	31.00	30.00	31.00	31.00	30.00	31.00	30.00	31.00	365.00		
<b>Biochemical Oxygen Demand: BOD5</b>															
Raw: Avg BOD5 - Raw mg/L	41.00	145.00	82.00	123.00	30.00	170.00	80.00	103.00	63.00	40.00	67.00	100.00		87.00	170.00
Raw: # of samples of BOD5 - Raw mg/L	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00		
<b>Carbonaceous Biochemical Oxygen Demand: CBOD</b>															
Eff: Avg cBOD5 - Final Effluent including Bypass mg/L	4.00	2.75	2.00	3.00	3.40	2.25	2.25	2.00	2.25	3.40	2.50	3.50		2.95	4.00
Eff Flow : Weighted Avg cBOD5 - Final Effluent including Bypass mg/L	3.44	2.75	2.00	2.70	3.40	2.25	2.25	2.00	0.00	0.00	0.00	0.00		2.75	3.44
Eff: # of samples of cBOD5 - Final Effluent including Bypass mg/L	10.00	4.00	4.00	10.00	5.00	4.00	4.00	5.00	4.00	5.00	4.00	4.00	63.00		
Loading: cBOD5 - Final Effluent including Bypass kg/d	5.595	3.612	2.858	4.956	4.242	2.219	1.980	1.730	1.740	2.817	2.268	4.096		3.31	5.59
Loading Flow Weighted: cBOD5 - Final Effluent including Bypass kg/d	4.815	3.612	2.858	4.466	4.242	2.219	1.980	1.730	0.000	0.000	0.000	0.000		3.08	4.82
<b>Total Suspended Solids: TSS</b>															
Raw: Avg TSS - Raw mg/L	56.00	97.00	72.00	124.00	18.00	144.00	40.00	45.00	100.00	24.00	68.00	132.00		76.67	144.00
Raw: # of samples of TSS - Raw mg/L	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00		
Eff: Avg TSS - Final Effluent including Bypass mg/L	14.20	4.75	4.25	5.30	6.20	6.00	3.75	5.60	4.50	9.40	7.75	8.50		7.33	14.20
Eff Flow : Weighted Avg TSS - Final Effluent including Bypass mg/L	8.79	4.75	4.25	5.57	6.20	6.00	3.75	5.60	0.00	0.00	0.00	0.00		6.42	8.79
Eff: # of samples of TSS - Final Effluent including Bypass mg/L	10.00	4.00	4.00	10.00	5.00	4.00	4.00	5.00	4.00	5.00	4.00	4.00	63.00		
Loading: TSS - Final Effluent including Bypass kg/d	19.861	6.240	6.073	8.755	7.736	5.916	3.300	4.845	3.479	7.788	7.031	9.949		8.21	19.86
Loading Flow Weighted: TSS - Final Effluent including Bypass kg/d	12.300	6.240	6.073	9.196	7.736	5.916	3.300	4.845	0.000	0.000	0.000	0.000		7.19	12.30
<b>Total Phosphorus: TP</b>															
Raw: Avg TP - Raw mg/L	0.98	2.21	2.02	2.26	0.61	2.37	1.82	2.03	1.48	1.43	1.82	2.03		1.76	2.37
Raw: # of samples of TP - Raw mg/L	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00		
Eff: Avg TP - Final Effluent including Bypass mg/L	0.13	0.08	0.08	0.08	0.11	0.08	0.12	0.14	0.21	0.14	0.14	0.13		0.12	0.21
Eff Flow : Weighted Avg TP - Final Effluent including Bypass mg/L	0.10	0.08	0.08	0.08	0.11	0.08	0.12	0.14	0.00	0.00	0.00	0.00		0.12	0.14
Eff: # of samples of TP - Final Effluent including Bypass mg/L	10.00	4.00	4.00	10.00	5.00	4.00	4.00	5.00	4.00	5.00	4.00	4.00	63.00		
Loading: TP - Final Effluent including Bypass kg/d	0.187	0.105	0.111	0.132	0.140	0.074	0.106	0.119	0.089	0.177	0.122	0.155		0.13	0.19
Loading Flow Weighted: TP - Final Effluent including Bypass kg/d	0.139	0.105	0.111	0.132	0.140	0.074	0.106	0.119	0.000	0.000	0.000	0.000		0.13	0.14
<b>Nitrogen Series</b>															
Raw: Avg TKN - Raw mg/L	10.10	24.00	20.60	21.10	6.40	22.20	21.00	21.20	20.30	17.40	20.80	19.20		18.69	24.00
Raw: # of samples of TKN - Raw mg/L	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00		
Eff: Avg TAN - Final Effluent including Bypass mg/L	0.10	0.20	1.68	0.92	1.56	0.30	0.10	1.42	0.23	0.26	0.48	0.83		0.67	1.68
Eff Flow : Weighted Avg TAN - Final Effluent including Bypass mg/L	0.10	0.20	1.68	1.61	1.56	0.30	0.10	1.42	0.00	0.00	0.00	0.00		0.73	1.68
Eff: # of samples of TAN - Final Effluent including Bypass mg/L	10.00	4.00	4.00	10.00	5.00	4.00	4.00	5.00	4.00	5.00	4.00	4.00	63.00		
Loading: TAN - Final Effluent including Bypass kg/d	0.140	0.263	2.394	1.520	1.946	0.296	0.088	1.229	0.174	0.215	0.431	0.966		0.75	2.39
Loading Flow Weighted: TAN - Final Effluent including Bypass kg/d	0.140	0.263	2.394	2.651	1.946	0.296	0.088	1.229	0.000	0.000	0.000	0.000		0.82	2.65
Eff: Avg NO3-N - Eff mg/L	11.54	10.46	7.15	4.59	8.71	13.48	16.33	13.12	16.50	16.70	12.03	8.20		11.57	16.70
Eff: # of samples of NO3-N - Eff mg/L	5.00	4.00	4.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	4.00	4.00	52.00		
Eff: Avg NO2-N - Eff mg/L	0.04	0.08	0.11	0.18	0.18	0.05	0.03	0.14	0.05	0.07	0.05	0.05		0.08	0.18
Eff: # of samples of NO2-N - Eff mg/L	5.00	4.00	4.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	4.00	4.00	52.00		
<b>Disinfection</b>															
Eff: GMD E. Coli - Eff cfu/100mL	2.30	1.41	3.13	4.43	2.00	2.38	2.00	2.00	1.68	2.00	2.00	3.87			
Eff: # of samples of E. Coli - Eff cfu/100mL	5.00	4.00	4.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	4.00	4.00	52.00		

Fenelon Falls WPCP 2023 Final Effluent Field pH Results

Date (mm/dd/yy)	pH
01/04/23	7.30
01/05/23	7.59
01/06/23	7.64
01/09/23	7.45
01/10/23	7.04
01/11/23	6.93
01/13/23	7.17
01/16/23	7.18
01/17/23	7.06
01/18/23	7.04
01/20/23	6.98
01/23/23	7.07
01/24/23	7.16
01/25/23	7.22
01/27/23	7.17
01/30/23	7.31
01/31/23	6.96
02/02/23	6.75
02/06/23	6.81
02/07/23	6.73
02/08/23	6.82
02/10/23	7.11
02/13/23	7.23
02/14/23	7.17
02/15/23	7.16
02/21/23	6.90
02/22/23	6.86
02/23/23	7.00
02/27/23	7.12
02/28/23	6.95
03/02/23	6.92
03/03/23	6.93
03/07/23	6.88
03/08/23	6.97
03/09/23	6.91
03/13/23	7.03
03/15/23	6.97
03/17/23	6.99
03/20/23	6.98
03/21/23	7.02
03/23/23	7.17
03/27/23	7.15
03/28/23	7.03
03/29/23	7.08

Date (mm/dd/yy)	pH
03/31/23	7.28
04/03/23	7.15
04/04/23	7.26
04/05/23	7.10
04/06/23	7.31
04/11/23	7.12
04/12/23	6.97
04/13/23	7.01
04/17/23	7.11
04/18/23	6.98
04/21/23	7.05
04/24/23	7.08
04/25/23	6.84
04/26/23	7.05
05/01/23	7.37
05/02/23	7.81
05/04/23	7.76
05/05/23	7.29
05/08/23	7.58
05/09/23	7.53
05/12/23	7.19
05/15/23	7.25
05/16/23	7.04
05/17/23	7.07
05/19/23	6.98
05/23/23	7.65
05/24/23	7.04
05/25/23	7.22
05/29/23	7.38
05/31/23	6.84
06/01/23	7.06
06/02/23	6.93
06/05/23	7.05
06/06/23	6.90
06/08/23	6.42
06/12/23	6.60
06/13/23	6.72
06/14/23	6.65
06/15/23	6.65
06/19/23	6.74
06/20/23	6.61
06/21/23	6.56
06/26/23	6.48
06/28/23	6.94
06/30/23	7.00

Date (mm/dd/yy)	pH
07/04/23	6.66
07/05/23	6.65
07/06/23	6.60
07/07/23	6.68
07/10/23	6.92
07/11/23	6.52
07/12/23	6.99
07/13/23	6.79
07/18/23	6.95
07/19/23	6.96
07/20/23	6.93
07/24/23	7.12
07/25/23	6.91
07/27/23	6.87
07/31/23	7.09
08/01/23	7.44
08/03/23	7.04
08/04/23	7.58
08/08/23	7.08
08/09/23	7.27
08/10/23	7.43
08/14/23	7.48
08/15/23	7.26
08/16/23	7.17
08/18/23	7.23
08/22/23	7.17
08/24/23	7.12
08/25/23	7.25
08/28/23	7.31
08/29/23	7.24
08/31/23	7.25
09/05/23	7.21
09/06/23	7.08
09/07/23	7.14
09/12/23	7.31
09/13/23	7.19
09/14/23	6.74
09/18/23	7.27
09/19/23	7.02
09/20/23	7.09
09/21/23	7.11
09/26/23	6.90
09/28/23	6.79
09/29/23	7.25

Date (mm/dd/yy)	pH
10/03/23	6.52
10/04/23	7.17
10/05/23	7.08
10/10/23	7.36
10/11/23	6.51
10/12/23	7.31
10/16/23	6.90
10/17/23	7.52
10/18/23	7.46
10/20/23	7.52
10/24/23	7.60
10/25/23	7.26
10/26/23	7.24
10/30/23	7.37
10/31/23	7.39
11/02/23	7.76
11/07/23	7.15
11/08/23	7.40
11/09/23	7.44
11/14/23	7.29
11/15/23	7.53
11/16/23	7.42
11/17/23	7.31
11/21/23	7.35
11/22/23	7.38
11/24/23	7.49
11/27/23	7.40
11/28/23	7.56
11/29/23	7.45
12/01/23	7.51
12/04/23	7.41
12/05/23	7.41
12/06/23	7.38
12/08/23	7.44
12/11/23	7.67
12/12/23	7.38
12/13/23	7.63
12/18/23	7.45
12/19/23	7.56
12/20/23	7.42
12/21/23	7.40
12/27/23	7.46
12/28/23	7.48
12/29/23	7.50

# Fenelon Falls WPCP 2023 Final Effluent Un-Ionized Ammonia Results

Date (mm/dd/yy)	Total Ammonia Nitrogen (mg/L)	Field pH	Field Temp (°C)	Un-ionized Ammonia (mg/L)
01/01/23	<0.1	7.42	8.4	<0.001
01/02/23	<0.1	7.34	9.7	<0.001
01/03/23	<0.1	7.97	7.5	<0.001
01/04/23	<0.1	7.51	10.0	<0.001
01/05/23	<0.1	7.65	8.1	<0.001
01/06/23	0.1	7.64	9.1	<0.001
01/10/23	<0.1	7.04	9.9	<0.001
01/17/23	0.1	7.06	9.1	<0.001
01/24/23	<0.1	7.16	10.2	<0.001
01/31/23	<0.1	6.96	9.4	<0.001
02/07/23	0.2	6.73	8.8	<0.001
02/14/23	0.2	7.17	8.2	<0.001
02/22/23	0.2	7.15	7.2	<0.001
02/28/23	0.2	6.95	8.3	<0.001
03/07/23	4.2	6.75	9.2	0.004
03/14/23	2	6.73	8.7	0.002
03/21/23	0.2	7.02	6.9	<0.001
03/28/23	0.3	7.03	8.0	<0.001
04/04/23	<0.1	7.26	8.6	<0.001
04/13/23	2	7.01	10.0	0.004
04/18/23	3.6	6.98	9.2	0.006
04/25/23	2.6	6.84	10.5	0.003
05/02/23	1.1	7.81	9.5	0.013
05/09/23	0.4	7.53	11.0	0.003
05/16/23	0.9	7.04	13.1	0.002
05/24/23	4.9	7.04	13.6	0.001
05/30/23	0.5	6.85	15.5	0.000
06/06/23	<0.1	6.5	15.9	<0.001
06/13/23	0.9	6.72	16.6	0.001
06/20/23	0.1	6.61	17.3	<0.001
06/27/23	<0.1	6.88	18.0	<0.001
07/05/23	<0.1	6.65	19.5	<0.001
07/11/23	<0.1	6.52	19.6	<0.001
07/18/23	<0.1	6.95	19.6	<0.001
07/25/23	0.1	6.91	19.9	<0.001
08/01/23	<0.1	7.44	19.1	<0.001
08/09/23	0.9	7.27	19.7	0.006
08/15/23	5.9	7.26	19.6	0.041
08/22/23	<0.1	7.17	19.3	<0.001
08/29/23	<0.1	7.26	19.2	<0.001
09/06/23	<0.1	7.08	21.5	<0.001
09/12/23	<0.1	7.31	19.9	<0.001
09/19/23	0.6	7.02	18.8	0.002
09/26/23	<0.1	6.5	18.6	<0.001
10/04/23	<0.1	7.17	19.4	<0.001
10/11/23	<0.1	6.51	16.8	<0.001
10/17/23	0.9	7.52	18.5	0.010
10/24/23	<0.1	7.6	15.0	<0.001
10/31/23	<0.1	7.39	14.3	<0.001
11/07/23	<0.1	7.15	14.4	<0.001
11/15/23	0.5	7.53	12.6	0.004
11/21/23	0.5	7.35	10.4	0.002
11/28/23	0.8	7.56	10.5	0.005
12/05/23	0.5	7.41	10.1	0.002
12/12/23	<0.1	7.38	10.6	<0.001
12/19/23	0.2	7.06	9.7	<0.001
12/28/23	2.5	7.48	10.2	0.014

# Appendix II

---

## Work Order and Maintenance Summary

# Fenelon Falls WPCP 2023 Work Order Summary

Work Order	Description	Location	Asset	Status	Work Type	Classification	Reported Date
941126	DEFERRED 5886, Ellice SPS, HS02, Install Davit for Retrieval Device for Drywell	5886-SPEL-F		CLOSE	CORR	HEALTH AND SAFETY	1/1/23 00:00:00
2500955	DEFERRED, 5886, Colborne SPS, Pump Controls, Repair	5886-SPCB-P		CLOSE	CORR	REFURBISH/REPLACE	1/1/23 00:00:00
3153596	Building and Grounds Maintenance (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	1/1/23 01:30:06
3153603	Alarm Dialer (1m) - 5886 - KTN	5886-WWFF-F-IT	0000158494	CLOSE	PM	INSPECTION	1/1/23 01:30:12
3153610	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158515	CLOSE	PM	INSPECTION	1/1/23 01:30:17
3153617	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158517	CLOSE	PM	INSPECTION	1/1/23 01:30:23
3153624	Engine Diesel (1m) - 5886 - KTN	5886-WWFF-F-PG-ENGN	0000158522	CLOSE	PM	INSPECTION	1/1/23 01:30:28
3153643	Engine Diesel (1m) - 5886 Ellice PS - KTN	5886-SPEL-F-PG-ENGN	0000158539	CLOSE	PM	INSPECTION	1/1/23 01:30:42
3153662	Engine Diesel (1m) - 5886 Colborne SPS - KTN	5886-SPCB-F-PG-ENGN	0000192454	CLOSE	PM	INSPECTION	1/1/23 01:30:55
3153681	Engine Diesel (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-ENGN	0000295831	CLOSE	PM	INSPECTION	1/1/23 01:31:07
3153912	Engine Gas Portable - (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-BACK	0000208585	CLOSE	PM	INSPECTION	1/1/23 01:34:16
3155024	Tertiary Treatment Operational Activities (1m) - 5886 - KTN	5886-WWFF-P-TT		CLOSE	PM	INSPECTION	1/1/23 01:49:59
3155356	Tank Alum Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	1/1/23 01:56:31
3167342	Actuator Electric Inspection/Service (1y) - 5886 Ellice SPS - KTN	5886-SPEL		CLOSE	PM	REFURBISH/REPLACE	1/1/23 05:47:34
3178216	Chemical Feed System Insp (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	1/1/23 08:17:49
3179789	HS03 H & S Equipment Check (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	HEALTH AND SAFETY	1/1/23 08:40:05
3181043	Analyzer DO Inspection/Cleaning (1m) - 5886 - KTN	5886-WWFF-P-PC	0000306067	CLOSE	PM	INSPECTION	1/1/23 08:57:44
3182632	Operator PDM Entry & Review (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	COMPLIANCE	1/1/23 09:19:33
3183191	Corporate Facility Workplace H & S Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	HEALTH AND SAFETY	1/1/23 09:27:41
3201651	5886, Fenelon Falls WWT, Facility, Bypass Event	5886-WWFF-F		CLOSE	CALL	REFURBISH/REPLACE	1/4/23 10:36:30
3202135	5886, Ellice SPS, Wet Well High, Alarm	5886-SPEL		CLOSE	CALL	REFURBISH/REPLACE	1/6/23 07:36:41
3202176	5886, Fenelon Falls WWT, Ellice High Level, Alarm	5886-WWFF-F		CLOSE	CALL	REFURBISH/REPLACE	1/6/23 09:28:04
3202182	5886, Fenelon Falls WWT, Ellice High Level, Alarm	5886-WWFF-F		CLOSE	CALL	REFURBISH/REPLACE	1/6/23 09:41:05
3204554	5886, Fenelon Falls WWT, Filter 3, Fault	5886-WWFF-P-TT		CLOSE	CALL	COMPLIANCE	1/18/23 08:37:37
3204588	5886, Fenelon Falls WWT, Ellice SPS Detention Tank Reprogramming (2 Pumps in Auto)	5886-WWFF-F-IT	0000208587	CLOSE	CAP	COMPLIANCE	1/18/23 10:56:49

3205510	5886, Fenelon Falls WWT, Tertiary Filter 3 Fault, Alarm	5886-WWFF-P-TT-FILT		CLOSE	CALL	REFURBISH/REPLACE	1/23/23 10:20:56
3205540	5886, Fenelon Falls WWT, Building Exit and Emergency Lighting, Repair	5886-WWFF-F		CLOSE	CORR	REFURBISH/REPLACE	1/23/23 12:02:12
3180078	Compressor Air #1 Inspection/Service by Contractor (1y) - 5886 - KTN	5886-WWFF-P-TT-FILT		CLOSE	PM	REFURBISH/REPLACE	2/1/23 00:00:00
3155343	Compressor Air #2 Inspection/Service by Contractor (1y) - 5886 - KTN	5886-WWFF-P-TT-FILT		CLOSE	PM	REFURBISH/REPLACE	2/1/23 00:00:00
2775859	5886, Fenelon Falls WWT, Replacement Pump RAS 3 Plant 2	5886-WWFF-P-ST	0000158457	CLOSE	CORR	REFURBISH/REPLACE	2/1/23 00:00:00
3209540	Building and Grounds Maintenance (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	2/1/23 00:54:40
3209542	Alarm Dialer (1m) - 5886 - KTN	5886-WWFF-F-IT	0000158494	CLOSE	PM	INSPECTION	2/1/23 00:54:42
3209549	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158515	CLOSE	PM	INSPECTION	2/1/23 00:54:47
3209556	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158517	CLOSE	PM	INSPECTION	2/1/23 00:54:52
3209563	Engine Diesel (1m) - 5886 - KTN	5886-WWFF-F-PG-ENGN	0000158522	CLOSE	PM	INSPECTION	2/1/23 00:54:58
3209582	Engine Diesel (1m) - 5886 Ellice PS - KTN	5886-SPEL-F-PG-ENGN	0000158539	CLOSE	PM	INSPECTION	2/1/23 00:55:10
3209601	Engine Diesel (1m) - 5886 Colborne SPS - KTN	5886-SPCB-F-PG-ENGN	0000192454	CLOSE	PM	INSPECTION	2/1/23 00:55:23
3209620	Engine Diesel (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-ENGN	0000295831	CLOSE	PM	INSPECTION	2/1/23 00:55:36
3209803	Engine Gas Portable - (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-BACK	0000208585	CLOSE	PM	INSPECTION	2/1/23 00:57:43
3210615	Tertiary Treatment Operational Activities (1m) - 5886 - KTN	5886-WWFF-P-TT		CLOSE	PM	INSPECTION	2/1/23 01:19:58
3210876	Filter Air Compressor #2 (3m) - 5886 - KTN	5886-WWFF-P-TT-FILT		CLOSE	PM	INSPECTION	2/1/23 01:24:01
3210883	MCC Insp/Service (3y) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	2/1/23 01:24:07
3210886	Tank Alum Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	2/1/23 01:24:11
3226960	Chemical Feed System Insp (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	2/1/23 06:22:59
3227839	HS03 H & S Equipment Check (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	HEALTH AND SAFETY	2/1/23 06:35:39
3228000	Filter Air Compressor #1 (3m) - 5886 - KTN	5886-WWFF-P-TT-FILT		CLOSE	PM	INSPECTION	2/1/23 06:37:53
3228619	Analyzer DO Inspection/Cleaning (1m) - 5886 - KTN	5886-WWFF-P-PC	0000306067	CLOSE	PM	INSPECTION	2/1/23 06:46:42
3229653	Operator PDM Entry & Review (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	COMPLIANCE	2/1/23 07:02:48
3230102	Corporate Facility Workplace H & S Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	HEALTH AND SAFETY	2/1/23 07:11:17
3247614	5886, Fenelon Falls WWT, Rotor Motor and Belt Replacement	5886-WWFF-P-ST-AERA	0000158449	CLOSE	CORR	REFURBISH/REPLACE	2/27/23 07:16:58
3250447	Building and Grounds Maintenance (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	3/1/23 01:02:34
3250449	Alarm Dialer (1m) - 5886 - KTN	5886-WWFF-F-IT	0000158494	CLOSE	PM	INSPECTION	3/1/23 01:02:37

3250456	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158515	CLOSE	PM	INSPECTION	3/1/23 01:02:43
3250463	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158517	CLOSE	PM	INSPECTION	3/1/23 01:02:49
3250470	Engine Diesel (1m) - 5886 - KTN	5886-WWFF-F-PG-ENGN	0000158522	CLOSE	PM	INSPECTION	3/1/23 01:02:55
3250489	Engine Diesel (1m) - 5886 Ellice PS - KTN	5886-SPEL-F-PG-ENGN	0000158539	CLOSE	PM	INSPECTION	3/1/23 01:03:08
3250508	Engine Diesel (1m) - 5886 Colborne SPS - KTN	5886-SPCB-F-PG-ENGN	0000192454	CLOSE	PM	INSPECTION	3/1/23 01:03:21
3250527	Engine Diesel (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-ENGN	0000295831	CLOSE	PM	INSPECTION	3/1/23 01:03:37
3250723	Engine Gas Portable - (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-BACK	0000208585	CLOSE	PM	INSPECTION	3/1/23 01:08:09
3251528	Tertiary Treatment Operational Activities (1m) - 5886 - KTN	5886-WWFF-P-TT		CLOSE	PM	INSPECTION	3/1/23 01:30:34
3251896	Tank Alum Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	3/1/23 01:37:42
3252141	Tank Wetwell Cleaning/Inspection (6m) - 5886 Colborne SPS - KTN	5886-SPCB-P	0000295845	CLOSE	PM	REFURBISH/REPLACE	3/1/23 01:41:19
3252156	Tank Wetwell Cleaning/Inspection (6m) - 5886 Ellice SPS - KTN	5886-SPEL-P	0000295850	CLOSE	PM	REFURBISH/REPLACE	3/1/23 01:41:29
3252171	Tank Wetwell Cleaning/Inspection (6m) - 5886 Francis SPS - KTN	5886-WWFF-P	0000158563	CLOSE	PM	REFURBISH/REPLACE	3/1/23 01:41:40
3269892	Chemical Feed System Insp (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	3/1/23 07:03:20
3270248	Grit Channel & Various Pit Clean-out by Contractor (6m) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	3/1/23 07:09:51
3270780	HS03 H & S Equipment Check (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	HEALTH AND SAFETY	3/1/23 07:17:50
3271571	Analyzer DO Inspection/Cleaning (1m) - 5886 - KTN	5886-WWFF-P-PC	0000306067	CLOSE	PM	INSPECTION	3/1/23 07:28:31
3272583	Operator PDM Entry & Review (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	COMPLIANCE	3/1/23 07:42:12
3273101	Corporate Facility Workplace H & S Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	HEALTH AND SAFETY	3/1/23 07:49:02
3288263	5886, Fenelon Falls WWT, UV Sensor Failure, Alarm	5886-WWFF-P-DI-ULVL		CLOSE	CALL	REFURBISH/REPLACE	3/6/23 10:08:03
3288382	5886, Fenelon Falls WWT, UV Sensor Fail,	5886-WWFF-P-DI-ULVL		CLOSE	CORR	REFURBISH/REPLACE	3/7/23 07:41:32
3290311	5886, Ellice SPS, High Level, Alarm	5886-SPEL-P-PC		CLOSE	CALL	REFURBISH/REPLACE	3/20/23 09:27:19
3290604	5886, Fenelon Falls WWT, Tertiary Filter Bypass Flow Meter , Install	5886-WWFF-P-TT-FILT		CLOSE	CAP	REFURBISH/REPLACE	3/22/23 08:08:11
3291311	5886, Fenelon Falls WWT, Clarifier 2 General, Alarm	5886-WWFF-P-ST-CLAR		CLOSE	CALL	REFURBISH/REPLACE	3/27/23 09:00:07
3291845	5886, Fenelon Falls WWT, Raw Composite Sampler, Replacement (CKL PO# 911535 OP)	5886-WWFF-P	0000158508	CLOSE	CAP	REFURBISH/REPLACE	3/30/23 14:17:05
3294792	Building and Grounds Maintenance (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	4/1/23 00:51:58
3294812	Sampler Insp/Service (1y) - 5886 - KTN	5886-WWFF-P	0000306207	CLOSE	PM	REFURBISH/REPLACE	4/1/23 00:52:15
3294818	Alarm Dialer (1m) - 5886 - KTN	5886-WWFF-F-IT	0000158494	CLOSE	PM	INSPECTION	4/1/23 00:52:20



3294825	Sampler Insp/Service (1y) - 5886 - KTN	5886-WWFF-P	0000158508	CLOSE	PM	REFURBISH/REPLACE	4/1/23 00:52:25
3294834	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158515	CLOSE	PM	INSPECTION	4/1/23 00:52:32
3294841	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158517	CLOSE	PM	INSPECTION	4/1/23 00:52:37
3294848	Engine Diesel (1m) - 5886 - KTN	5886-WWFF-F-PG-ENGN	0000158522	CLOSE	PM	INSPECTION	4/1/23 00:52:44
3294867	Engine Diesel (1m) - 5886 Ellice PS - KTN	5886-SPEL-F-PG-ENGN	0000158539	CLOSE	PM	INSPECTION	4/1/23 00:52:57
3294886	Engine Diesel (1m) - 5886 Colborne SPS - KTN	5886-SPCB-F-PG-ENGN	0000192454	CLOSE	PM	INSPECTION	4/1/23 00:53:09
3294905	Engine Diesel (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-ENGN	0000295831	CLOSE	PM	INSPECTION	4/1/23 00:53:22
3295116	Engine Gas Portable - (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-BACK	0000208585	CLOSE	PM	INSPECTION	4/1/23 00:55:50
3296120	Tertiary Treatment Operational Activities (1m) - 5886 - KTN	5886-WWFF-P-TT		CLOSE	PM	INSPECTION	4/1/23 01:09:37
3296393	Tank Alum Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	4/1/23 01:13:33
3296804	FEP Site Plan Review (1y) - 5886 - KTN	5886-WWFF		CLOSE	PM	COMPLIANCE	4/1/23 01:19:06
3296813	Aerator #2 Insp/Service (1y) - 5886 - KTN	5886-WWFF-P		CLOSE	PM	REFURBISH/REPLACE	4/1/23 01:19:15
3306328	UPS Inspection/Service (1y) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	4/1/23 03:16:42
3316192	Chemical Feed System Insp (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	4/1/23 05:47:25
3317401	HS03 H & S Equipment Check (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	HEALTH AND SAFETY	4/1/23 06:02:24
3318406	Analyzer DO Inspection/Cleaning (1m) - 5886 - KTN	5886-WWFF-P-PC	0000306067	CLOSE	PM	INSPECTION	4/1/23 06:14:26
3319665	Operator PDM Entry & Review (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	COMPLIANCE	4/1/23 06:28:46
3320164	Corporate Facility Workplace H & S Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	HEALTH AND SAFETY	4/1/23 06:34:34
3320891	Pump Cent & VFD Inspection (1y) - 5886 RASP #1 - KTN	5886-WWFF-P-SH		CLOSE	PM	INSPECTION	4/1/23 06:42:43
3320905	Blower & VFD Inspection (1y) - 5886 Blower #2 - KTN	5886-WWFF-P-ST-AERA		CLOSE	PM	INSPECTION	4/1/23 06:42:53
3320912	Blower & VFD Inspection (1y) - 5886 Blower #3 - KTN	5886-WWFF-P-ST-AERA		CLOSE	PM	INSPECTION	4/1/23 06:42:58
3320919	Blower & VFD Inspection (1y) - 5886 Blower #4 - KTN	5886-WWFF-P-SH		CLOSE	PM	INSPECTION	4/1/23 06:43:03
3320926	Pump Submersible & VFD Inspection (1y) - 5886 RASP #2 - KTN	5886-WWFF-P-SH		CLOSE	PM	INSPECTION	4/1/23 06:43:08
3320933	Pump Cent & VFD Inspection (1y) - 5886 Ellice SPS Pump #1 - KTN	5886-SPEL-P		CLOSE	PM	INSPECTION	4/1/23 06:43:12
3320940	Drive VFD Insp (1y) - 5886 Aeration Ditch Rotor - KTN	5886-WWFF-P-ST-AERA	0000291404	CLOSE	PM	REFURBISH/REPLACE	4/1/23 06:43:17
3320946	Pump Cent & VFD Inspection (1y) - 5886 Ellice SPS Pump #2 - KTN	5886-SPEL-P		CLOSE	PM	INSPECTION	4/1/23 06:43:21
3320960	Pump Submersible & VFD Inspection (1y) - 5886 RASP #3 - KTN	5886-WWFF-P-SH		CLOSE	PM	INSPECTION	4/1/23 06:43:31
3328158	ESA Inspection By Contractor (6m) - 5886- KTN	5886-WWFF-F		CLOSE	PM	CALIBRATION	4/1/23 08:19:31

3337949	5886, Ellice SPS, Wet Well High, Alarm	5886-SPEL		CLOSE	CALL	REFURBISH/REPLACE	4/3/23 08:43:50
3338004	5886, Ellice SPS, High Level Alarm Monitor Flows	5886-SPEL		CLOSE	CALL	COMPLIANCE	4/3/23 10:45:33
3338008	Duplicate	5886-WWFF-P-PC		CAN	CALL	COMPLIANCE	4/3/23 10:50:54
3338012	5886, Ellice SPS, High Level Alarm	5886-SPEL-F		CLOSE	CALL	COMPLIANCE	4/3/23 10:58:08
3338284	5886, Ellice SPS, Wet Well High, Alarm	5886-SPEL-P		CLOSE	CALL	COMPLIANCE	4/4/23 11:14:07
3338710	5886, Francis SPS, Pump 2 Fault, Alarm	5886-SPFR-P		CLOSE	CALL	COMPLIANCE	4/6/23 13:20:15
3339337	5886, Colborne SPS, Overflow SAC Incident #: 1-34X4M0	5886-SPCB		CLOSE	CALL	COMPLIANCE	4/11/23 07:58:52
3339340	5886, Fenelon Falls WWT, Sand Filter Bypass SAC Incident # : 1-34X4L0	5886-WWFF-P-DI		CLOSE	CALL	COMPLIANCE	4/11/23 08:04:56
3340341	5886, Fenelon Falls WWT, UV Fault, Alarm	5886-WWFF-P-DI-ULVL		CLOSE	CALL	REFURBISH/REPLACE	4/17/23 08:32:28
3341120	5886, Fenelon Falls WWT, Filter, Alarm	5886-WWFF-P		CLOSE	CALL	COMPLIANCE	4/23/23 08:34:05
3344802	Building and Grounds Maintenance (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	5/1/23 00:57:50
3344804	Alarm Dialer (1m) - 5886 - KTN	5886-WWFF-F-IT	0000158494	CLOSE	PM	INSPECTION	5/1/23 00:57:52
3344811	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158515	CLOSE	PM	INSPECTION	5/1/23 00:58:00
3344818	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158517	CLOSE	PM	INSPECTION	5/1/23 00:58:05
3344825	Engine Diesel (1m) - 5886 - KTN	5886-WWFF-F-PG-ENGN	0000158522	CLOSE	PM	INSPECTION	5/1/23 00:58:11
3344844	Engine Diesel (1m) - 5886 Ellice PS - KTN	5886-SPEL-F-PG-ENGN	0000158539	CLOSE	PM	INSPECTION	5/1/23 00:58:29
3344863	Engine Diesel (1m) - 5886 Colborne SPS - KTN	5886-SPCB-F-PG-ENGN	0000192454	CLOSE	PM	INSPECTION	5/1/23 00:58:42
3344882	Engine Diesel (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-ENGN	0000295831	CLOSE	PM	INSPECTION	5/1/23 00:58:55
3345065	Engine Gas Portable - (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-BACK	0000208585	CLOSE	PM	INSPECTION	5/1/23 01:01:26
3345865	Tertiary Treatment Operational Activities (1m) - 5886 - KTN	5886-WWFF-P-TT		CLOSE	PM	INSPECTION	5/1/23 01:13:51
3346142	Filter Air Compressor #2 (3m) - 5886 - KTN	5886-WWFF-P-TT-FILT		CLOSE	PM	INSPECTION	5/1/23 01:18:22
3346149	Lifting Devices & Fall Arrest Inspection by Contractor (1y) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	5/1/23 01:18:27
3346153	Tank Alum Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	5/1/23 01:18:33
3361784	Dehumidifier Service by Contractor (1y) - 5886 - KTN	5886-WWFF-F-HV	0000158518	CLOSE	PM	REFURBISH/REPLACE	5/1/23 04:41:30
3364282	Chemical Feed System Insp (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	5/1/23 05:51:40
3365150	HS03 H & S Equipment Check (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	HEALTH AND SAFETY	5/1/23 06:03:24
3365330	Filter Air Compressor #1 (3m) - 5886 - KTN	5886-WWFF-P-TT-FILT		CLOSE	PM	INSPECTION	5/1/23 06:05:49
3365999	Analyzer DO Inspection/Cleaning (1m) - 5886 - KTN	5886-WWFF-P-PC	0000306067	CLOSE	PM	INSPECTION	5/1/23 06:14:42
3366621	Air Conditioning Unit Service by Contractor (1y) - 5886 - KTN	5886-WWFF-F-HV		CLOSE	PM	REFURBISH/REPLACE	5/1/23 06:22:26
3367060	Operator PDM Entry & Review (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	COMPLIANCE	5/1/23 06:28:05

3367522	Corporate Facility Workplace H & S Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	HEALTH AND SAFETY	5/1/23 06:34:48
3373931	ESA Inspection By Contractor (1y) - 5886 Colborne SPS - KTN	5886-SPCB-F		CLOSE	PM	CALIBRATION	5/1/23 08:23:25
3373937	ESA Inspection By Contractor (1y) - 5886 Ellice SPS - KTN	5886-SPEL-F		CLOSE	PM	CALIBRATION	5/1/23 08:23:30
3373947	ESA Inspection By Contractor (1y) - 5886 Francis SPS - KTN	5886-SPFR	0000306084	CLOSE	PM	CALIBRATION	5/1/23 08:23:40
3385664	5886, Fenelon Falls WWT, Workshop Compressor, Refurbish	5886-WWFF-F		CLOSE	CORR	REFURBISH/REPLACE	5/17/23 12:14:42
3386187	5886, Fenelon Falls WWT, Train # 1 Fault, Carriage Misalignment, Alarm	5886-WWFF-F-PD	0000158498	CLOSE	CALL	REFURBISH/REPLACE	5/21/23 20:21:22
3386603	5886, Fenelon Falls WWT, Filter 1 Fault, Alarm	5886-WWFF-P-TT-FILT		CLOSE	CALL	REFURBISH/REPLACE	5/24/23 07:30:45
3390481	Building and Grounds Maintenance (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	6/1/23 00:55:17
3390483	Alarm Dialer (1m) - 5886 - KTN	5886-WWFF-F-IT	0000158494	CLOSE	PM	INSPECTION	6/1/23 00:55:19
3390490	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158515	CLOSE	PM	INSPECTION	6/1/23 00:55:24
3390497	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158517	CLOSE	PM	INSPECTION	6/1/23 00:55:30
3390504	Engine Diesel (1m) - 5886 - KTN	5886-WWFF-F-PG-ENGN	0000158522	CLOSE	PM	INSPECTION	6/1/23 00:55:36
3390523	Engine Diesel (1m) - 5886 Ellice PS - KTN	5886-SPEL-F-PG-ENGN	0000158539	CLOSE	PM	INSPECTION	6/1/23 00:55:49
3390542	Engine Diesel (1m) - 5886 Colborne SPS - KTN	5886-SPCB-F-PG-ENGN	0000192454	CLOSE	PM	INSPECTION	6/1/23 00:56:03
3390561	Engine Diesel (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-ENGN	0000295831	CLOSE	PM	INSPECTION	6/1/23 00:56:16
3390744	Engine Gas Portable - (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-BACK	0000208585	CLOSE	PM	INSPECTION	6/1/23 00:58:41
3391607	Tertiary Treatment Operational Activities (1m) - 5886 - KTN	5886-WWFF-P-TT		CLOSE	PM	INSPECTION	6/1/23 01:10:35
3391842	Tank Alum Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	6/1/23 01:15:11
3411205	Chemical Feed System Insp (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	6/1/23 06:04:02
3412510	HS03 H & S Equipment Check (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	HEALTH AND SAFETY	6/1/23 06:22:12
3413280	Analyzer DO Inspection/Cleaning (1m) - 5886 - KTN	5886-WWFF-P-PC	0000306067	CLOSE	PM	INSPECTION	6/1/23 06:34:06
3414349	Operator PDM Entry & Review (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	COMPLIANCE	6/1/23 06:49:28
3414880	Corporate Facility Workplace H & S Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	HEALTH AND SAFETY	6/1/23 06:57:21
3434681	5886, Fenelon Falls WWT, Train#1 Filter, Alarm	5886-WWFF-P-TT-FILT		CLOSE	CALL	COMPLIANCE	6/21/23 05:58:18
3439325	Building and Grounds Maintenance (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	7/1/23 01:05:13
3439327	Alarm Dialer (1m) - 5886 - KTN	5886-WWFF-F-IT	0000158494	CLOSE	PM	INSPECTION	7/1/23 01:05:15
3439334	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158515	CLOSE	PM	INSPECTION	7/1/23 01:05:21

3439341	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158517	CLOSE	PM	INSPECTION	7/1/23 01:05:28
3439348	Engine Diesel (1m) - 5886 - KTN	5886-WWFF-F-PG-ENGN	0000158522	CLOSE	PM	INSPECTION	7/1/23 01:05:33
3439367	Engine Diesel (1m) - 5886 Ellice PS - KTN	5886-SPEL-F-PG-ENGN	0000158539	CLOSE	PM	INSPECTION	7/1/23 01:05:46
3439386	Engine Diesel (1m) - 5886 Colborne SPS - KTN	5886-SPCB-F-PG-ENGN	0000192454	CLOSE	PM	INSPECTION	7/1/23 01:05:58
3439405	Engine Diesel (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-ENGN	0000295831	CLOSE	PM	INSPECTION	7/1/23 01:06:11
3439616	Engine Gas Portable - (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-BACK	0000208585	CLOSE	PM	INSPECTION	7/1/23 01:08:56
3440564	Tertiary Treatment Operational Activities (1m) - 5886 - KTN	5886-WWFF-P-TT		CLOSE	PM	INSPECTION	7/1/23 01:22:33
3440818	Valve Backflow Preventer Testing/Inspection by Contractor (1y) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	7/1/23 01:26:37
3440834	Online Process Equipment Calibration Service by Contractor (1y) - 5886 - KTN	5886-WWFF		CLOSE	PM	CALIBRATION	7/1/23 01:26:49
3440839	Tank Alum Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	7/1/23 01:26:53
3458776	Chemical Feed System Insp (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	7/1/23 05:47:46
3459902	HS03 H & S Equipment Check (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	HEALTH AND SAFETY	7/1/23 06:03:20
3460774	Analyzer DO Inspection/Cleaning (1m) - 5886 - KTN	5886-WWFF-P-PC	0000306067	CLOSE	PM	INSPECTION	7/1/23 06:14:39
3462050	Operator PDM Entry & Review (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	COMPLIANCE	7/1/23 06:30:21
3462519	Corporate Facility Workplace H & S Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	HEALTH AND SAFETY	7/1/23 06:36:23
3479410	5886, Fenelon Falls WWT, Filter 2, Alarm	5886-WWFF-P-TT-FILT		CLOSE	CALL	COMPLIANCE	7/4/23 08:13:47
3479469	5886, Fenelon Falls WWT, Filter 1 Fault	5886-WWFF-P-TT-FILT		CLOSE	CALL	COMPLIANCE	7/4/23 09:47:36
3480107	5886, Fenelon Falls WWT, Filter, Alarm	5886-WWFF-P-TT-FILT		CLOSE	CALL	COMPLIANCE	7/6/23 02:15:00
3481398	5886, Fenelon Falls Colborne Low Level Alarm	5886-SPCB-P-PC		CLOSE	CALL	COMPLIANCE	7/11/23 18:29:37
3481715	5886, Fenelon Falls WWT, Sludge Hauling Hose, Repair	5886-WWFF-F		CLOSE	CORR	REFURBISH/REPLACE	7/13/23 09:06:45
3482089	5886, Colborne SPS, SCADA, Alarm	5886-SPCB-P	0000295844	CLOSE	CALL	REFURBISH/REPLACE	7/17/23 00:05:31
3486905	Building and Grounds Maintenance (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	8/1/23 00:54:38
3486907	Alarm Dialer (1m) - 5886 - KTN	5886-WWFF-F-IT	0000158494	CLOSE	PM	INSPECTION	8/1/23 00:54:40
3486914	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158515	CLOSE	PM	INSPECTION	8/1/23 00:54:45
3486921	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158517	CLOSE	PM	INSPECTION	8/1/23 00:54:51
3486928	Engine Diesel (1m) - 5886 - KTN	5886-WWFF-F-PG-ENGN	0000158522	CLOSE	PM	INSPECTION	8/1/23 00:54:56
3486947	Engine Diesel (1m) - 5886 Ellice PS - KTN	5886-SPEL-F-PG-ENGN	0000158539	CLOSE	PM	INSPECTION	8/1/23 00:55:09
3486966	Engine Diesel (1m) - 5886 Colborne SPS - KTN	5886-SPCB-F-PG-ENGN	0000192454	CLOSE	PM	INSPECTION	8/1/23 00:55:30
3486985	Engine Diesel (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-ENGN	0000295831	CLOSE	PM	INSPECTION	8/1/23 00:55:46
3487196	Engine Gas Portable - (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-BACK	0000208585	CLOSE	PM	INSPECTION	8/1/23 00:58:14

3488037	Tertiary Treatment Operational Activities (1m) - 5886 - KTN	5886-WWFF-P-TT		CLOSE	PM	INSPECTION	8/1/23 01:10:01
3488255	Filter Air Compressor #2 (3m) - 5886 - KTN	5886-WWFF-P-TT-FILT		CLOSE	PM	INSPECTION	8/1/23 01:13:21
3488262	Tank Alum Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	8/1/23 01:13:28
3504840	Chemical Feed System Insp (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	8/1/23 04:59:59
3505661	HS03 H & S Equipment Check (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	HEALTH AND SAFETY	8/1/23 05:51:30
3505829	Filter Air Compressor #1 (3m) - 5886 - KTN	5886-WWFF-P-TT-FILT		CLOSE	PM	INSPECTION	8/1/23 05:53:46
3506361	Analyzer DO Inspection/Cleaning (1m) - 5886 - KTN	5886-WWFF-P-PC	0000306067	CLOSE	PM	INSPECTION	8/1/23 06:01:19
3507367	Operator PDM Entry & Review (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	COMPLIANCE	8/1/23 06:15:14
3507824	Corporate Facility Workplace H & S Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	HEALTH AND SAFETY	8/1/23 06:21:45
3522692	5886, Colborne SPS, SCADA Communication Fail	5886-SPCB-P-PC		CLOSE	CALL	REFURBISH/REPLACE	8/2/23 14:34:04
3525064	5886, Colborne SPS, SCADA, Alarm	5886-SPCB-P-PC		CLOSE	CALL	COMPLIANCE	8/14/23 05:42:15
3526376	5886, Fenelon Falls WWT, Filter Sand Train One, Alarm	5886-WWFF-P-TT-FILT	0000158497	CLOSE	CALL	REFURBISH/REPLACE	8/22/23 08:38:55
3527651	5886, Colborne SPS, Low Wet Well Level, Alarm	5886-SPCB-P-PC		CLOSE	CALL	COMPLIANCE	8/30/23 11:32:54
3530327	Building and Grounds Maintenance (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	9/1/23 00:55:42
3530332	Alarm Dialer (1m) - 5886 - KTN	5886-WWFF-F-IT	0000158494	CLOSE	PM	INSPECTION	9/1/23 00:55:48
3530339	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158515	CLOSE	PM	INSPECTION	9/1/23 00:55:54
3530346	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158517	CLOSE	PM	INSPECTION	9/1/23 00:56:00
3530353	Engine Diesel (1m) - 5886 - KTN	5886-WWFF-F-PG-ENGN	0000158522	CLOSE	PM	INSPECTION	9/1/23 00:56:07
3530372	Engine Diesel (1m) - 5886 Ellice PS - KTN	5886-SPEL-F-PG-ENGN	0000158539	CLOSE	PM	INSPECTION	9/1/23 00:56:20
3530399	Engine Diesel (1m) - 5886 Colborne SPS - KTN	5886-SPCB-F-PG-ENGN	0000192454	CLOSE	PM	INSPECTION	9/1/23 00:56:41
3530418	Engine Diesel (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-ENGN	0000295831	CLOSE	PM	INSPECTION	9/1/23 00:56:55
3530604	Engine Gas Portable - (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-BACK	0000208585	CLOSE	PM	INSPECTION	9/1/23 00:59:28
3531407	Tertiary Treatment Operational Activities (1m) - 5886 - KTN	5886-WWFF-P-TT		CLOSE	PM	INSPECTION	9/1/23 01:11:31
3531672	Tank Alum Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	9/1/23 01:15:50
3532186	HS09 Chemical Review (1y) - 5886 - KTN	5886-WWFF		CLOSE	PM	HEALTH AND SAFETY	9/1/23 01:23:20
3532193	Tank Wetwell Cleaning/Inspection (6m) - 5886 Colborne SPS - KTN	5886-SPCB-P	0000295845	CLOSE	PM	REFURBISH/REPLACE	9/1/23 01:23:27
3532208	Tank Wetwell Cleaning/Inspection (6m) - 5886 Ellice SPS - KTN	5886-SPEL-P	0000295850	CLOSE	PM	REFURBISH/REPLACE	9/1/23 01:23:41
3532223	Tank Wetwell Cleaning/Inspection (6m) - 5886 Francis SPS - KTN	5886-WWFF-P	0000158563	CLOSE	PM	REFURBISH/REPLACE	9/1/23 01:23:52

3550317	Chemical Feed System Insp (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	9/1/23 06:25:45
3550728	Grit Channel & Various Pit Clean-out by Contractor (6m) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	9/1/23 06:31:27
3551275	HS03 H & S Equipment Check (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	HEALTH AND SAFETY	9/1/23 06:39:20
3552165	Analyzer DO Inspection/Cleaning (1m) - 5886 - KTN	5886-WWFF-P-PC	0000306067	CLOSE	PM	INSPECTION	9/1/23 06:52:09
3553311	Operator PDM Entry & Review (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	COMPLIANCE	9/1/23 07:12:55
3553819	Corporate Facility Workplace H & S Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	HEALTH AND SAFETY	9/1/23 07:19:36
3572729	5886,Colborne SPS,SCADA Loss of Communication, Alarm	5886-SPCB-P-PC	0000291209	CLOSE	CALL	REFURBISH/REPLACE	9/11/23 07:15:24
3573036	5886,Fenelon Falls WWT, Train # 3 Fault, Alarm	5886-WWFF-P-TT-FILT	0000158505	CLOSE	CALL	REFURBISH/REPLACE	9/13/23 07:16:11
3578875	Building and Grounds Maintenance (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	10/1/23 00:56:55
3578877	Alarm Dialer (1m) - 5886 - KTN	5886-WWFF-F-IT	0000158494	CLOSE	PM	INSPECTION	10/1/23 00:56:57
3578884	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158515	CLOSE	PM	INSPECTION	10/1/23 00:57:02
3578891	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158517	CLOSE	PM	INSPECTION	10/1/23 00:57:07
3578898	Engine Diesel (1m) - 5886 - KTN	5886-WWFF-F-PG-ENGN	0000158522	CLOSE	PM	INSPECTION	10/1/23 00:57:12
3578917	Engine Diesel (1m) - 5886 Ellice PS - KTN	5886-SPEL-F-PG-ENGN	0000158539	CLOSE	PM	INSPECTION	10/1/23 00:57:24
3578936	Engine Diesel (1m) - 5886 Colborne SPS - KTN	5886-SPCB-F-PG-ENGN	0000192454	CLOSE	PM	INSPECTION	10/1/23 00:57:36
3578955	Engine Diesel (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-ENGN	0000295831	CLOSE	PM	INSPECTION	10/1/23 00:57:48
3579166	Engine Gas Portable - (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-BACK	0000208585	CLOSE	PM	INSPECTION	10/1/23 01:00:28
3580111	Tertiary Treatment Operational Activities (1m) - 5886 - KTN	5886-WWFF-P-TT		CLOSE	PM	INSPECTION	10/1/23 01:12:52
3580422	Tank Alum Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	10/1/23 01:17:21
3580755	Engine Diesel Inspection/Service by Contractor (1y) - 5886 - KTN	5886-WWFF-F-PG-ENGN	0000158522	CLOSE	PM	REFURBISH/REPLACE	10/1/23 01:21:42
3580761	Engine Diesel Inspection/Service by Contractor (1y) - 5886 Ellice SPS - KTN	5886-SPEL-F-PG-ENGN	0000158539	CLOSE	PM	REFURBISH/REPLACE	10/1/23 01:21:46
3580767	Engine Diesel Inspection/Service by Contractor (1y) - 5886 Portable - KTN	5886-WWFF-F-PG-ENGN	0000295831	CLOSE	PM	REFURBISH/REPLACE	10/1/23 01:21:51
3580773	Engine Diesel Inspection/Service by Contractor (1y) - 5886 Colborne SPS - KTN	5886-SPCB-F-PG-ENGN	0000192454	CLOSE	PM	REFURBISH/REPLACE	10/1/23 01:21:55
3598793	Chemical Feed System Insp (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	10/1/23 06:03:57
3600318	HS03 H & S Equipment Check (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	HEALTH AND SAFETY	10/1/23 06:23:19
3601378	Analyzer DO Inspection/Cleaning (1m) - 5886 - KTN	5886-WWFF-P-PC	0000306067	CLOSE	PM	INSPECTION	10/1/23 06:37:05
3602681	Operator PDM Entry & Review (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	COMPLIANCE	10/1/23 06:52:59

3603222	Corporate Facility Workplace H & S Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	HEALTH AND SAFETY	10/1/23 06:59:40
3620909	5886, Fenelon Falls WWT, Train #3 Fault, Alarm	5886-WWFF-P-TT		CLOSE	CALL	REFURBISH/REPLACE	10/4/23 10:45:12
3623518	5886, Fenelon Falls WWT, Scum Pit Valve, Inspection	5886-WWFF-P-ST-CLAR		CLOSE	OPER	INSPECTION	10/18/23 13:35:19
3623894	5886, Colborne SPS, Loss of Communication and Ellice Inter lock, Alarm	5886-SPCB-P-PC		CLOSE	CALL	COMPLIANCE	10/20/23 14:24:29
3624214	5886, Ellice SPS, Communication Fail, Alarm	5886-SPEL-F		CLOSE	CALL	REFURBISH/REPLACE	10/23/23 12:08:23
3624302	5886, Ellice SPS, Communication Fail, Alarm	5886-SPEL		CLOSE	CALL	REFURBISH/REPLACE	10/24/23 08:43:54
3625376	5886 Fenelon Falls WWTP - Colborne SPS Scada alarm	5886-SPCB-F		CLOSE	CALL	REFURBISH/REPLACE	10/30/23 14:39:32
3628078	Building and Grounds Maintenance (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	11/1/23 00:58:06
3628080	Alarm Dialer (1m) - 5886 - KTN	5886-WWFF-F-IT	0000158494	CLOSE	PM	INSPECTION	11/1/23 00:58:09
3628087	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158515	CLOSE	PM	INSPECTION	11/1/23 00:58:15
3628094	UV Light Cleaning & Insp. (1m) - 5886 - KTN	5886-WWFF-P-DI-ULVL	0000158517	CLOSE	PM	INSPECTION	11/1/23 00:58:21
3628101	Engine Diesel (1m) - 5886 - KTN	5886-WWFF-F-PG-ENGN	0000158522	CLOSE	PM	INSPECTION	11/1/23 00:58:27
3628120	Engine Diesel (1m) - 5886 Ellice PS - KTN	5886-SPEL-F-PG-ENGN	0000158539	CLOSE	PM	INSPECTION	11/1/23 00:58:42
3628139	Engine Diesel (1m) - 5886 Colborne SPS - KTN	5886-SPCB-F-PG-ENGN	0000192454	CLOSE	PM	INSPECTION	11/1/23 00:59:04
3628158	Engine Diesel (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-ENGN	0000295831	CLOSE	PM	INSPECTION	11/1/23 00:59:18
3629155	Tertiary Treatment Operational Activities (1m) - 5886 - KTN	5886-WWFF-P-TT		CLOSE	PM	INSPECTION	11/1/23 01:15:07
3629382	Filter Air Compressor #2 (3m) - 5886 - KTN	5886-WWFF-P-TT-FILT		CLOSE	PM	INSPECTION	11/1/23 01:18:54
3629389	Tank Alum Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	REFURBISH/REPLACE	11/1/23 01:19:00
3644489	Chemical Feed System Insp (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	INSPECTION	11/1/23 04:57:16
3645742	HS03 H & S Equipment Check (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	HEALTH AND SAFETY	11/1/23 05:36:14
3645905	Filter Air Compressor #1 (3m) - 5886 - KTN	5886-WWFF-P-TT-FILT		CLOSE	PM	INSPECTION	11/1/23 05:38:16
3646445	Analyzer DO Inspection/Cleaning (1m) - 5886 - KTN	5886-WWFF-P-PC	0000306067	CLOSE	PM	INSPECTION	11/1/23 05:45:25
3647469	Operator PDM Entry & Review (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	COMPLIANCE	11/1/23 05:58:18
3647918	Corporate Facility Workplace H & S Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	HEALTH AND SAFETY	11/1/23 06:04:07
3662607	5886, Fenelon Falls WWT, Train #2, Alarm	5886-WWFF-P-TT		CLOSE	CALL	REFURBISH/REPLACE	11/6/23 09:01:54
3665776	5886, Fenelon Falls WWT, UV Fault, Alarm	5886-WWFF-P-DI-ULVL		CLOSE	CALL	REFURBISH/REPLACE	11/23/23 09:59:34
3669297	Alarm Dialer (1m) - 5886 - KTN	5886-WWFF-F-IT	0000158494	CLOSE	PM	INSPECTION	12/1/23 00:51:48
3669318	Engine Diesel (1m) - 5886 - KTN	5886-WWFF-F-PG-ENGN	0000158522	CLOSE	PM	INSPECTION	12/1/23 00:52:06
3669356	Engine Diesel (1m) - 5886 Colborne SPS - KTN	5886-SPCB-F-PG-ENGN	0000192454	CLOSE	PM	INSPECTION	12/1/23 00:52:34
3669375	Engine Diesel (1m) - 5886 Portable - KTN	5886-WWFF-F-PG-ENGN	0000295831	CLOSE	PM	INSPECTION	12/1/23 00:52:48

3687252	HS03 H & S Equipment Check (1m) - 5886 - KTN	5886-WWFF		CLOSE	PM	HEALTH AND SAFETY	12/1/23 05:32:48
3688919	Operator PDM Entry & Review (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	COMPLIANCE	12/1/23 05:55:23
3689390	Corporate Facility Workplace H & S Inspection (1m) - 5886 - KTN	5886-WWFF		CLOSE	OPER	HEALTH AND SAFETY	12/1/23 06:01:36
3705723	5886, Colborne SPS, SCADA, Alarm	5886-SPCB-P-PC		CLOSE	CALL	REFURBISH/REPLACE	12/15/23 07:42:01



# Appendix III

---

## Calibration Report



**Franklin Empire Inc,**  
550 Braidwood Ave. Unit 4  
Peterborough ON K9J 1W1, CANADA

Tel: (705) 745-1626  
Fax: (705) 745-3493

---

## **OCWA Kawartha**

## **2023 Calibrations Fenelon Falls WW**

---

*Leaders in Instrumentation and Control*

	<b>CALIBRATION REPORT</b>	<b>Report No.:</b> OCWA K23    FIT-402
		<b>Date:</b> 22-Aug-23

<b>SITE:</b>	Fenelon Falls WWTP	<b>SERVICE DATE:</b>	August 22, 2023
<b>PROCESS AREA:</b>	Basement	<b>TECHNICIAN:</b>	Mitch Manley
<b>INSTR. TAG:</b>	FIT-402	<b>JOB REFERENCE:</b>	OCWA K23
<b>MANUFACTURER:</b>	Krohne		
<b>MODEL:</b>	IFC 010D		
<b>SERIAL No.:</b>	A0044687		
<b>OCWA CODE No.:</b>	0000158514		

Input (Test)			Output (Signal)		Output (Process)	
Type:	GS 8 (X val)		Type or EGU:	mA	L/S	
Min:	0.00		Min:	4.00	0.00	
Max:	4.17		Max:	20.00	25.00	
DN (mm):	100					
GK=1 GKL=2	2					
GK:	5.014					
Constant:	4177.44					
			Before Calibration		After Calibration	
Input (Y pos)	Knob Setting	Calc. O/P	Output	%Error	Output	%Error
0.00	0	4.00	4.00	0.00%	4.00	0.00%
0.50	A	5.92	5.94	0.34%	5.94	0.34%
1.00	B	7.84	7.88	0.51%	7.88	0.51%
2.00	C	11.68	11.73	0.43%	11.73	0.43%

Calibration Equipment			
Type:	DMM	Simulator	
Manufacturer:	Fluke	Krohne	
2023 Calibrations By:	Model 87	GS 8B	
Serial No.:	13440128	U1127700020705	
Last Cal. Date:	Feb. 17, 2023	Mar. 27, 2023	

Comments: 104.3, open to ground, total 24200 m3

CERTIFIED BY: 

## Report No.: OCWA K23      FIT-301

**Date:** 22-Aug-23

**JOB REFERENCE:** OCWA K23

Calibration Equipment			
Type:	DMM	Simulator	
Manufacturer:	Fluke	Krohne	
2023 Calibrations By:	Model 87	GS 8B	
Serial No.:	13440128	U1127700020705	
Last Cal. Date:	Feb. 17, 2023	Mar. 27, 2023	

**Comments:** 102.9 ohms , open to ground, Total 433901

**CERTIFIED BY:**

White Male

	<b>CALIBRATION REPORT</b>	<b>Report No.:</b> OCWA K23   FIT-Bypass
		<b>Date:</b> 22-Aug-23

<b>SITE:</b>	Fenelon Falls WWTP	<b>SERVICE DATE:</b>	August 22, 2023
<b>PROCESS AREA:</b>	Bypass Flow	<b>TECHNICIAN:</b>	Mitch Manley
<b>INSTR. TAG:</b>	FIT-Bypass	<b>JOB REFERENCE:</b>	OCWA K23
<b>MANUFACTURER:</b>	Siemens		
<b>MODEL:</b>	FST 030		
<b>SERIAL No.:</b>	PBD R 3294546		
<b>OCWA CODE No.:</b>	0000306230		

Input (Test)			Output (Signal)		(Process)	
Type:	C1 H		Type or EGU:	mA	L/S	
Spacing:	19.117 in		Min:	4.00	0.00	
Wall:	0.168		Max:	20.00		
OD (in):	16.2					
Sonic Vel	1432 m/s					
Damping:	5.000					
User Cal:	0.82		Before Calibration		After Calibration	
Test Flow (l/s)	Mag Reading	Calc. flow	Output	%Error	Output	%Error
5.80	5.80	5.80	5.7-6.6		5.7-6.6	
14.60	14.6	14.60	13.7 - 15.8		13.7 - 15.8	

Calibration Equipment			
Type:	DMM	Simulator	
Manufacturer:	Fluke	Krohne	
2023 Calibrations By:	Model 87	GS 8B	
Serial No.:	13440128	U1127700020705	
Last Cal. Date:	Feb. 17, 2023	Mar. 27, 2023	

**Comments:**      Tested by comparison to Mag meter upstream of clamp-on meter.  
Bypass = Final effluent - clamp on flow to filters

mA output was slightly jumpy, increased mA output damping to 5 sec.

**CERTIFIED BY:** 



# CALIBRATION REPORT

Report No.: OCWA K23 WEL\_PIT\_101

Date: 22-Aug-23

**SITE:** Ellice St SPS, Fenelon Falls  
**PROCESS AREA:** Discharge Pressure  
**INSTR. TAG:** WEL\_PIT\_101  
**MANUFACTURER:** Siemens  
**MODEL:** Sitrans P DSIII  
**SERIAL No.:** IXHD089009751  
**OCWA CODE No.:** 0000306039

**SERVICE DATE:** August 22, 2023

**TECHNICIAN:** Mitch Manley

**JOB REFERENCE:** OCWA K23

Input (Test) Type: KPA 0.00 400.00			Output (Signal)		(Process)	
			Type or EGU:	SCADA	KPA	
			Min:	0.00	0.00	
			Max:	400.00	400.00	
			Before Calibration		After Calibration	
Input	Input %	Calc. O/P	Output	%Error	Output	%Error
0	0.00%	0.00	0.1	0.03%	0.1	0.03%
100	25.00%	100.00	99.7	-0.30%	99.7	-0.30%
200	50.00%	200.00	199.1	-0.45%	199.1	-0.45%
300	75.00%	300.00	299.5	-0.17%	299.5	-0.17%
400	100.00%	400.00	399.9	-0.03%	399.9	-0.03%

Calibration Equipment			
Type:	Pressure Calibrator	DMM	
Manufacturer:	Crystal	Fluke	
2023 Calibrations F	XP2i 300 PSI	Model 87	
Serial No.:	153455	13440128	
Last Cal. Date:	Dec. 1, 2022	Feb. 17, 2023	

Comments:

AS FOUND: PASS

AS LEFT: PASS

CERTIFIED BY:

# Flowmeter Verification Certificate Transmitter

OCWA Kawartha

Customer

Sludge Flow

Order code

PROMAG 53 W DN100

Device type

F3080516000

Serial number

V2.03.00

Software Version Transmitter

22.08.2023

Verification date

Fenlon Falls WWTP

Plant

FENLON-F

Tag Name

1.2687 - 1.2687

K-Factor

4

Zero point

V1.05.03

Software Version I/O-Module

09:57

Verification time

## Verification result Transmitter: Passed

Test item	Result	Applied Limits
Amplifier	Passed	Basis: 0.55 %
Current Output 1	Passed	0.05 mA
Pulse Output 1	Not tested	0 P
Test Sensor	Passed	

### FieldCheck Details

550149

Production number

1.07.10

Software Version

04/2023

Last Calibration Date

### Simubox Details

Production number

1.00.01

Software Version

04/2023

Last Calibration Date

Date

Operator's Sign

Inspector's Sign

### Overall results:

The achieved test results show that the instrument is completely functional, and the measuring results lie within +/- 1% of the original calibration. <sup>1)</sup>

The calibration of the Fieldcheck test system is fully traceable to national standards.

1) Prerequisite is an additional proof of electrode integrity with a high voltage test.

## FieldCheck - Result Tab Transmitter

Customer	OCWA Kwartha	Plant	Fenlon Falls WWTP
Order code	Sludge Flow	Tag Name	FENLON-F
Device type	PROMAG 53 W DN100	K-Factor	1.2687 - 1.2687
Serial number	F3080516000	Zero point	4
Software Version Transmitter	V2.03.00	Software Version I/O-Module	V1.05.03
Verification date	22.08.2023	Verification time	09:57

Verification Flow end value ( 100 % ): 31.416 l/s

Flow speed 4.00 m/s

Passed / Failed	Test item	Simul. Signal	Limit Value	Deviation
	<b>Test Transmitter</b>			
✓	Amplifier	1.571 l/s (5%)	1.50 %	0.61 %
✓		3.142 l/s (10.0%)	1.00 %	0.71 %
✓		15.708 l/s (50.0%)	0.60 %	0.08 %
✓		31.416 l/s (100%)	0.55 %	0.04 %
✓	Current Output 1	4.000 mA (0%)	0.05 mA	0.002 mA
✓		4.800 mA (5%)	0.05 mA	0.002 mA
✓		5.600 mA (10.0%)	0.05 mA	-0.008 mA
✓		12.000 mA (50.0%)	0.05 mA	0.005 mA
✓		20.000 mA (100%)	0.05 mA	0.006 mA
—	Pulse Output 1	---	---	---
		<b>Start value</b>	<b>Limits range</b>	<b>Measured value</b>
	<b>Test Sensor</b>			
✓	Coil Curr. Rise	5.000 ms	0.000..14.250 ms	6.380 ms
✓	Coil Curr. Stability		---	---
✓	Electrode Integrity	mV	0.0..300.001 mV	29.461 mV

Legend of symbols

✓	✗	—	?	!
Passed	Failed	not tested	not testable	Attention



## FieldCheck: Parameters Transmitter

Customer	OCWA Kawartha	Plant	Fenlon Falls WWTP
Order code	Sludge Flow	Tag Name	FENLON-F
Device type	PROMAG 53 W DN100	K-Factor	1.2687 - 1.2687
Serial number	F3080516000	Zero point	4
Software Version Transmitter	V2.03.00	Software Version I/O-Module	V1.05.03
Verification date	22.08.2023	Verification time	09:57

Curent Output	Assign	Current Range	Value 0_4mA	Value 20 mA		
Terminal 26/27	VOLUME FLOW	4-20 mA active	0.0 I/s	40.00 I/s		
Pulse Output	Assign	Pulse Value	Output signal	Pulse width		
Terminal 24/25	VOLUME FLOW	7.571 I/P	Passive/Positive	100.01 ms		

Actual System Ident.

123.0

# SIEMENS MAGFLO® Verification Certificate

## Customer:

Name OCWA Kawartha  
Address Fenelon Falls WW  
  
  
Phone   
Email

## MAGFLO® Identification:

TAG No./Name 0  
Sensor Code No. 7ME658  
Sensor Serial No. 860103U017  
Converter Code No. 7ME691  
Converter Serial No. N1H9150044  
Location Ellice St SPS

## Results:

Verification file name or No. 00000291194  
Converter Passed  
Sensor Insulation Passed  
Magnetic Circuit Passed

Velocity	Current Output			Frequency Output		
Theoretical	Theoretical	Actual	Deviation	Theoretical	Actual	Deviation
0.5m/s	4.800mA	4.806mA	0.79%	0.500kHz	0.502kHz	0.37%
1.0m/s	5.600mA	5.602mA	0.14%	1.000kHz	1.000kHz	-0.05%
3.0m/s	8.800mA	8.807mA	0.15%	3.000kHz	3.003kHz	0.10%

Current Output 4-20mA

Frequency Output 0-10kHz

## Converter Settings:

### Basic

Qmax. 80.0 l/s  
Flow Direction Positive  
Low flow Cut-off 1.50%  
Empty Pipe ON

### Output

Current Output ON (4-20mA)  
Time Constant 5.0 Sec.  
Relay Output Error Level  
  
Digital Output OFF  
Frequency Range N/A  
Time Constant N/A  
Volume/pulse 0.0 US G/p  
Pulse width 0.066 sec.  
Pulse polarity Positiv

Totalizer 1 value before test 440979.78125 m<sup>3</sup>  
Totalizer 1 value after test 440979.84375 m<sup>3</sup>  
Totalizer 2 value before test 1243.16137695 m<sup>3</sup>  
Totalizer 2 value after test 1243.16137695 m<sup>3</sup>

## Sensor Details:

Size DN 200 8 IN  
  
Cal. Factor 32.04983521  
  
Correction Factor 1.0  
  
Excitation Freq. 3.75Hz

## Vericator Details (083F5060)

Serial No. 001113N039  
Device No. 91738  
Software Version 1.40  
PC-Software Version 4.02  
Cal. date 2022.12.29  
ReCal. date 2023.12.29

## Comments

These tests verify that the flowmeter is functioning within 2% deviation of the original test parameters.  
Verification is traceable to National and International Standards.

Date and signature

2023.08.22

M Manley

# Flowmeter Verification Certificate Transmitter

OCWA Kawartha

Customer

Fenlon Falls SPS Flow

Order code

PROMAG 50 W DN200

Device type

F5158619000

Serial number

V2.04.00

Software Version Transmitter

22.08.2023

Verification date

Fenlon Falls SPS

Plant

-----

Tag Name

1.0406 - 1.0406

K-Factor

-1

Zero point

V1.04.10

Software Version I/O-Module

13:03

Verification time

## Verification result Transmitter: Passed

Test item	Result	Applied Limits
Amplifier	Passed	Basis: 0.55 %
Current Output 1	Passed	0.05 mA
Pulse Output 1	Not tested	0 P
Test Sensor	Passed	

### FieldCheck Details

550149

Production number

1.07.10

Software Version

04/2023

Last Calibration Date

### Simubox Details

Production number

1.00.01

Software Version

04/2023

Last Calibration Date

Date

Operator's Sign

Inspector's Sign

### Overall results:

The achieved test results show that the instrument is completely functional, and the measuring results lie within +/- 1% of the original calibration. <sup>1)</sup>

The calibration of the Fieldcheck test system is fully traceable to national standards.

1) Prerequisite is an additional proof of electrode integrity with a high voltage test.

## FieldCheck - Result Tab Transmitter

Customer	OCWA Kwartha	Plant	Fenlon Falls SPS
Order code	Fenlon Falls SPS Flow	Tag Name	-----
Device type	PROMAG 50 W DN200	K-Factor	1.0406 - 1.0406
Serial number	F5158619000	Zero point	-1
Software Version Transmitter	V2.04.00	Software Version I/O-Module	V1.04.10
Verification date	22.08.2023	Verification time	13:03

Verification Flow end value ( 100 % ): 125.664 l/s

Flow speed 4.00 m/s

Passed / Failed	Test item	Simul. Signal	Limit Value	Deviation
	<b>Test Transmitter</b>			
✓	Amplifier	6.283 l/s (5%)	1.50 %	0.71 %
✓		12.566 l/s (10.0%)	1.00 %	0.00 %
✓		62.832 l/s (50.0%)	0.60 %	0.05 %
✓		125.665 l/s (100%)	0.55 %	0.03 %
✓	Current Output 1	4.000 mA (0%)	0.05 mA	0.000 mA
✓		4.800 mA (5%)	0.05 mA	0.000 mA
✓		5.600 mA (10.0%)	0.05 mA	-0.013 mA
✓		12.000 mA (50.0%)	0.05 mA	0.001 mA
✓		20.000 mA (100%)	0.05 mA	-0.005 mA
—	Pulse Output 1	---	---	---
		<b>Start value</b>	<b>Limits range</b>	<b>Measured value</b>
	<b>Test Sensor</b>			
✓	Coil Curr. Rise	13.300 ms	0.000..27.625 ms	23.533 ms
✓	Coil Curr. Stability		---	---
✓	Electrode Integrity	mV	0.0..300.001 mV	62.144 mV

Legend of symbols

✓	✗	—	?	!
Passed	Failed	not tested	not testable	Attention

## FieldCheck: Parameters Transmitter

Customer	OCWA Kawartha	Plant	Fenlon Falls SPS
Order code	Fenlon Falls SPS Flow	Tag Name	*****
Device type	PROMAG 50 W DN200	K-Factor	1.0406 - 1.0406
Serial number	F5158619000	Zero point	-1
Software Version Transmitter	V2.04.00	Software Version I/O-Module	V1.04.10
Verification date	22.08.2023	Verification time	13:03

Curent Output	Assign	Current Range	Value 0_4mA	Value 20 mA		
Terminal 26/27	VOLUME FLOW	4-20 mA active	0.0 l/s	80.00 l/s		
Pulse Output	Assign	Pulse Value	Output signal	Pulse width		
Terminal 24/25	VOLUME FLOW	10.000 gal/P	Passive/Positive	100.01 ms		

Actual System Ident.

129.0

# Appendix IV

---

## Sludge/Biosolids Summary

Ontario Clean Water Agency  
Biosolids Quality Report  
**Solids and Nutrients**

Facility: FENELON FALLS WASTEWATER TREATMENT FACILITY  
Period: 01/01/2023 to 12/01/2023  
Facility Owner: Municipality: City of Kawartha Lakes  
Facility Classification: Class 2 Wastewater Treatment

Month	Total Sludge Hauled (m3)	Avg. Total Solids (mg/L)	Avg. Total Phosphorus (mg/L)	Ammonia (mg/L)	Nitrate (mg/L)	Nitrite (mg/L)	TKN (mg/L)	Ammonia + Nitrate (mg/L)	Potassium (mg/L)
Parameter Short Name	HauledVol	TS	TP	NH3p_NH4p_N	NO3-N	NO2-N	TKN	calculation in report - no T/S	K
T/s	IH Month.Total	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean		Lab Published Month Mean
Jan	0.000	--	--	--	--	--	--	--	--
Feb	236.420	20,750.000	400.000	54.800	0.300	1.150	1,419.000	27.550	62.000
Mar	116.400	46,700.000	1,100.000	101.000	0.300	0.900	2,740.000	50.650	130.000
Apr	0.000	--	--	--	--	--	--	--	--
May	494.700	18,000.000	421.500	35.300	0.300	0.650	937.000	17.800	77.000
Jun	222.750	18,200.000	437.000	85.700	3.000	3.000	934.000	44.350	60.000
Jul	174.600	17,700.000	500.000	90.800	3.000	3.000	1,390.000	46.900	59.000
Aug	465.600	15,300.000	386.000	75.650	3.000	3.000	980.000	39.325	41.500
Sep	203.700	13,600.000	336.000	11.500	3.000	3.000	730.000	7.250	38.000
Oct	179.960	21,700.000	576.000	14.700	3.000	3.000	1,190.000	8.850	49.000
Nov	154.500	16,900.000	452.000	9.600	4.000	3.000	1,010.000	6.800	49.000
Dec	140.870	19,800.000	500.000	6.000	3.000	3.000	946.000	4.500	60.000
Average	217.227	20,865.000	510.850	48.505	2.290	2.370	1,227.600	25.398	62.550
Total	2,389.500	208,650.000	5,108.500	485.050	22.900	23.700	12,276.000	253.975	625.500

Ontario Clean Water Agency  
Biosolids Quality Report  
**Metals and Criteria**

Facility: FENELON FALLS WASTEWATER TREATMENT FACILITY  
Period: 01/01/2023 to 12/01/2023  
Facility Owner: Municipality: City of Kawartha Lakes  
Facility Classification: Class 2 Wastewater Treatment

Month	Arsenic (mg/L)	Cadmium (mg/L)	Cobalt (mg/L)	Chromium (mg/L)	Copper (mg/L)	Mercury (mg/L)	Molybdenum (mg/L)	Nickel (mg/L)	Lead (mg/L)	Selenium (mg/L)	Zinc (mg/L)
Parameter Short Name	As	Cd	Co	Cr	Cu	Hg	Mo	Ni	Pb	Se	Zn
T/s	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean
Jan	--	--	--	--	--	--	--	--	--	--	--
Feb	0.100	0.009	0.020	0.185	3.700	0.003	0.075	0.190	0.150	0.100	4.000
Mar	0.100	0.021	0.060	0.480	11.000	0.013	0.210	0.540	0.500	0.200	13.000
Apr	--	--	--	--	--	--	--	--	--	--	--
May	0.100	0.009	0.025	0.195	4.050	0.005	0.080	0.205	0.250	0.100	6.000
Jun	0.100	0.008	0.030	0.210	4.200	0.005	0.070	0.210	0.200	0.100	5.000
Jul	0.100	0.008	0.030	0.250	4.800	0.009	0.080	0.220	0.300	0.100	6.000
Aug	0.100	0.009	0.025	0.180	4.250	0.006	0.070	0.175	0.300	0.100	6.500
Sep	0.100	0.008	0.020	0.140	3.600	0.015	0.060	0.140	0.200	0.100	6.000
Oct	0.100	0.012	0.030	0.230	5.500	0.009	0.120	0.230	0.300	0.100	10.000
Nov	0.100	0.010	0.020	0.170	4.000	0.008	0.090	0.180	0.300	0.100	7.000
Dec	0.100	0.012	0.030	0.200	4.700	0.006	0.100	0.210	0.200	0.100	7.000
Average	0.100	0.010	0.029	0.224	4.980	0.008	0.096	0.230	0.270	0.110	7.050
Max. Permissible Metal Concentrations (mg/kg of Solids)	170.000	34.000	340.000	2,800.000	1,700.000	11.000	94.000	420.000	1,100.000	34.000	4,200.000
Metal Concentrations in Sludge (mg/kg)	4.793	0.501	1.390	10.736	238.677	0.376	4.577	11.023	12.940	5.272	337.886



# **Appendix V**

---

## **Bypass and Overflow Event Reporting**



May 12, 2023

David Bradley, District Manager  
Peterborough District Office  
Ministry of Environment, Conservation and Parks  
300 Water Street South, 2nd Floor, South Tower  
Peterborough ON K9J 3C7

Dear David Bradley:

**Re: Fenelon Falls WPCP Q1 2023 Bypass and Overflow Event Reports**

Amended Environmental Compliance Approval #3688-BW3RGB Conditions 4 and 5 issued January 15, 2021, for the Fenelon Falls WCPC require Bypass and Overflow quarterly reports be submitted to the District Manager. These reports are to be submitted no later than February 15, May 15, August 15, and November 15 each year for Events that occurred during the preceding quarter.

There was one partial Bypass of the Post-Secondary Sand Filters that started in the fourth quarter of 2022 and continued into the first quarter of 2023 (December 31, 2022-January 6, 2023). All information regarding this bypass was included in the 2022 fourth quarterly Bypass and Overflow event report. No other Bypass or Overflow Events occurred at the Fenelon Falls WPCP during the first quarter of 2023 – reports are attached.

Please contact me if you have any questions or comments.

Best regards,

Christine Craig  
Process & Compliance Technician  
Ontario Clean Water Agency  
Kawartha-Trent Region  
(705) 731-9579

Attachments

cc: J. Manning, Sr. Operations Manager, OCWA Kawartha-Trent Regional Hub  
A. Hayter, Supervisor Water & Wastewater, CKL  
W. Henneberry, Safety, Process & Compliance Manager, OCWA Kawartha-Trent  
G. Redden, General Manager, OCWA Kawartha-Trent Regional Hub  
K. Lorente, Regional Hub Manager, OCWA Kawartha-Trent Regional Hub  
C. Johnston, Water Inspector, MECP – Peterborough District Office

Fenelon Falls WPCP - Quarterly Bypass Report  
 Environmental Compliance Approval #3688-BW3RGB  
 Year: 2023  
 Q1 = January, February, March

Did a Bypass occur during this quarter:  
 Yes ☐ No ☒

Condition 4. Bypasses		Event
4.3	a. the type of the Bypass (emergency or planned)	
	b. the date and time of the beginning of the Bypass	
	c. the treatment process(es) gone through prior to the Bypass and the treatment process(es) bypassed;	
	d. the effort(s) done to maximize the flow through the downstream treatment process(es) and the reason(s) why the Bypass was not avoided.	
4.4	a. the date and time of the end of the Bypass;	
	b. the estimated or measured volume of Bypass.	
4.5	For any Bypass Event, the Owner shall collect daily sample(s) of the Final Effluent, inclusive of the Event and analyze for all effluent parameters outlined in Compliance Limits condition that require composite samples following the same protocol specified in the Monitoring and Recording condition for the regular samples. The sample(s) shall be in addition to the regular Final Effluent samples required under the monitoring and recording condition. If the Event occurs on a scheduled monitoring day, the regular sampling requirements prevail. If representative sample for the effluent parameter(s) that require grab sample cannot be obtained, they shall be collected after the Event at the earliest time when situation returns to normal.	
4.6	. . . .The summary reports shall contain, at a minimum, the types of information set out in Paragraphs (3), (4) and (5) and either a statement of compliance or a summary of the non-compliance notifications submitted as required under Paragraph 1 of Condition 11. If there is no Bypass Event during a quarter, a statement of no occurrence of Bypass is deemed sufficient.	No occurrence of Bypass

Fenelon Falls WPCP - Quarterly Overflow Report  
 Environmental Compliance Approval #3688-BW3RGB  
 Year: 2023  
 Q1 = January, February and March

Did an Overflow occur during this quarter:  
 Yes ☐ No ☒

Condition 5. Overflow		Event
5.3	a. the type of the Overflow (emergency or planned)	
	b. the date and time of the beginning of the Overflow	
	c. the point of the Overflow from the Works, the treatment process(es) gone through prior to the Overflow, the disinfection status of the Overflow and whether the Overflow is discharged through the effluent disposal facilities or an alternate location;	
	d. the effort(s) done to maximize the flow through the downstream treatment process(es) and Bypasses and the reason(s) why the Overflow was not avoided.	
5.4	a. the date and time of the end of the Overflow;	
	b. the estimated or measured volume of Overflow.	
5.5	a. Overflow event in Sewage Treatment Plant, grab sample(s) of the Overflow, one near the beginning of the Event and one every eight (8) hours for the duration of the Event, and have them analyzed at least for CBOD5, total suspended solids, total phosphorus, total ammonia nitrogen, nitrate as N, nitrite as N, total Kjeldahl nitrogen, E. coli. , except that raw sewage and primary treated effluent Overflow shall be analyzed for BOD5, total suspended solids, total phosphorus and total Kjeldahl nitrogen only.	
	b. at a sewage pumping station in the collection system, at least one (1) grab sample representative of the Overflow Event and have it analyzed for BOD5, total suspended solids, total phosphorus and total Kjeldahl nitrogen.	
5.6	...The summary report shall contain, at a minimum, the types of information set out in Paragraphs (3), (4) and (5). If there is no Overflow Event during a quarter, a statement of no occurrence of Overflow is deemed sufficient.	No Occurrence of Overflow.



August 02, 2023

David Bradley, District Manager  
Peterborough District Office  
Ministry of Environment, Conservation and Parks  
300 Water Street South, 2nd Floor, South Tower  
Peterborough ON K9J 3C7

Dear David Bradley:

**Re: Fenelon Falls WPCP Q2 2023 Bypass and Overflow Event Reports**

Amended Environmental Compliance Approval #3688-BW3RGB Conditions 4 and 5 issued January 15, 2021, for the Fenelon Falls WPCP require Bypass and Overflow quarterly reports be submitted to the District Manager. These reports are to be submitted no later than February 15, May 15, August 15, and November 15 each year for Events that occurred during the preceding quarter.

There was one partial Bypass of the Post-Secondary Sand Filters that occurred in the second quarter of 2023 (April, May, June). Details of this Event are attached.

There was no occurrence of Overflow at the Fenelon Falls WPCP during the second quarter of 2023 (April, May and June). There was one occurrence of a collection system Overflow at the Colborne Street Sewage Pumping Station which was reported as required by the CLI-ECA 141-W601. Although not required as per CLI-ECA 141-W601, the information from the Overflow event at the Colborne Street Sewage Pumping Station has been included as an attachment for reference. Please reach out if you require more details on the Overflow event that occurred at the Colborne Street Pumping Station.

Please contact me if you have any questions or comments.

Best regards,

Christine Craig  
Process & Compliance Technician  
Ontario Clean Water Agency  
Kawartha-Trent Region  
(705) 731-9579

**Attachments**

cc: J. Manning, Sr. Operations Manager, OCWA Kawartha-Trent Regional Hub  
A. Hayter, Supervisor Water & Wastewater, CKL  
J. Mulligan, Safety, Process & Compliance Manager (A), OCWA Kawartha Hub  
G. Redden, General Manager, OCWA Kawartha-Trent Regional Hub  
W. Henneberry, Regional Hub Manager (A), OCWA Kawartha-Trent Regional Hub  
C. Johnston, Water Inspector, MECP – Peterborough District Office

Fenelon Falls WPCP - Quarterly Bypass Report  
Environmental Compliance Approval #3688-BW3RGB  
Year: 2023  
Q2 = April, May, June

Did a Bypass occur during this quarter:  
Yes ☒ No ☐

Condition 4. Bypasses		Event
4.3	a. the type of the Bypass (emergency or planned)	SAC # 1-34X4L0 - emergency partial sand filter bypass due to weather
	b. the date and time of the beginning of the Bypass	April 5, 2023 at 20:45
	c. the treatment process(es) gone through prior to the Bypass and the treatment process(es) bypassed;	Primary, Secondary, majority of effluent through Post-Secondary sand filters while a portion of the effluent bypassed the Post Secondary sand filters; all effluent through UV disinfection.
	d. the effort(s) done to maximize the flow through the downstream treatment process(es) and the reason(s) why the Bypass was not avoided.	Flows & process monitored throughout the event, utilized detention tank; - Shepherds Environmental onsite hauling from Francis St. SPS to the sewage treatment plant; - Composite samples collected over the duration of the event
4.4	a. the date and time of the end of the Bypass;	April 11, 2023 at 07:34
	b. the estimated or measured volume of Bypass.	2, 417 m <sup>3</sup> estimate
4.5	For any Bypass Event, the Owner shall collect daily sample(s) of the Final Effluent, inclusive of the Event and analyze for all effluent parameters outlined in Compliance Limits condition that require composite samples following the same protocol specified in the Monitoring and Recording condition for the regular samples. The sample(s) shall be in addition to the regular Final Effluent samples required under the monitoring and recording condition. If the Event occurs on a scheduled monitoring day, the regular sampling requirements prevail. If representative sample for the effluent parameter(s) that require grab sample cannot be obtained, they shall be collected after the Event at the earliest time when situation returns to normal.	24 hour composite samples collected - sampler started April 5, 2023 at 20:45 with last sample finishing at 20:45 on April 11, 2023 to cover duration of event. Operations Event Form Summary attached, and lab results with summary.
4.6	...The summary reports shall contain, at a minimum, the types of information set out in Paragraphs (3), (4) and (5) and either a statement of compliance or a summary of the non-compliance notifications submitted as required under Paragraph 1 of Condition 11. If there is no Bypass Event during a quarter, a statement of no occurrence of Bypass is deemed sufficient.	Compliant with ECA - monthly limits met for April 2023. See attached Performance Report for April 2023.



### Operations Event Form

**Project:** Fenelon Falls WPCP  
**Location:** 216 Ellice St., Fenelon Falls, ON  
**Date:** April 5- April 11, 2023

**Nature of Event:** Emergency Partial Sand Filter Bypass

**Details of Event:** A heavy rain event (approx. 30mm of rain plus snow melt) in Fenelon Falls, resulted in high flows which caused the plant to become hydraulically overloaded - secondary treatment and disinfection provided; however, sand filters hydraulically overloaded and required partial bypassing. Fenelon River is the receiving body of water.

---

**Call SAC: 1-800-268-6060**

**Time SAC notified:** April 5, 2023 @ 22:20

**SAC Incident Number:** 1-34X4L0

**Name of Person at SAC:** Brenda

**District Health Unit Notified (time):** April 5, 2023 @ 22:31 - Left Message

**Name of Person at Health Unit:** Neha Gandhi, PHI, returned call April 5, 2023 @ 22:37. PHI requested a media release be posted by the City of Kawartha Lakes (CKL) to notify residents of the partial sand filter bypass (notice attached).

**Other Contacts (Managers, Client, MECP, MOH):**

J. Manning Sr. Ops. Mgr., ORO OCWA, C. Craig PCT OCWA, R. Rohrbasser Operator OCWA CKL, and OCWA: W. Henneberry SPC Mgr, G. Redden General Manager, K. Lorente Regional Mgr, & R. Junkin VP Operations

**Volume of Partial Sand Filter Bypass:** Estimated volume based upon flow meter readings and bypass valve opening: ~2, 417 m<sup>3</sup>

**Start:** April 5, 2023 @ 20:45 **Finish:** April 11, 2023 @ 07:34 **Duration:** 130 hours, 49 minutes

MOH called on April 11, 2023 @ 09:40 to report partial bypass stopped- Left message. PHI, Neha Gandhi called back at 10:50, provided estimated volume and duration of event. Requested CKL to update media release to inform residents the partial sand filter bypass has concluded. This was completed.

SAC contacted at end of event on April 11, 2023 @ 09:43 spoke with Justin Chin - provided estimated volume and duration of event

**Samples:** Final Effluent - CBOD, TSS, Total Phosphorus, Total Ammonia Nitrogen, composite samples collected over the duration of the event.

**Corrective Action Taken:**

- Monitored flows, additional staff called to assist, the detention tank at the Ellice St. SPS was fully utilized, Shepherds Environmental contacted to haul sewage from Francis St SPS to the sewage treatment plant.
- Composite samples collected over the duration of the event.

**Prepared By:** C. Craig

---

### Fenelon Falls Wastewater System currently bypassing

Kawartha Lakes – Beginning at approximately 10pm on Wednesday April 5, 2023, the Fenelon Falls Wastewater System – Colborne St. Sewage Pumping Station is currently bypassing, releasing raw sewage into the Fenelon River. In addition, the sewage treatment plant is partially bypassing the sand filtration process (tertiary treatment), however effluent is still receiving UV disinfection prior to outlet into the Fenelon River.

The Fenelon Falls Wastewater System is currently receiving higher than normal sewage flows due to extreme wet weather, and the amount of wastewater entering the sewer system has exceeded the capacity of the system. The impact of the spill on water quality will be minimal given dilution due to significant rainfall, however residents drawing water downstream from the Colborne St. Sewage Pumping Station (bottom side of Fenelon locks) should take precautions.

The Haliburton Kawartha Pine Ridge District (HKPR) Health Unit advises residents who draw their water from the Fenelon River to use a proper filtration and disinfection system before consuming the water. Surface water can be contaminated by viruses, bacteria or parasites that can cause illness. Although extra precaution should be taken during the bypass event, it is always important to ensure that surface water is properly treated before drinking or using to be sure it is safe.

**Homes and businesses connected to municipal water from the Fenelon Falls Drinking Water System are not affected and their water continues to be safe to drink.**

Residents will be advised when the bypass event has ended

- 30 -

[Media Inquiries](#)



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 110001612**Project :** PO#017018

19-April-2023

**OCWA-Kawartha (Fenelon Falls WWTF)**

Attn : Christine Craig

PO Box 279, Boyd St. E  
Bobcaygeon, ON  
K0M 1A0, Canada

Phone: 705-887-3596

Fax:

**Date Rec. :** 11 April 2023**LR Report:** CA12425-APR23**Copy:** #1

## CERTIFICATE OF ANALYSIS

### Final Report

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Completed Date	4: Analysis Completed Time	5: TeBy TeBy-Final Effluent-Comp
Sample Date & Time					06-Apr-23 20:45
Temperature Upon Receipt [°C]	---	---	---	---	10.0
Field pH [no unit]	---	---	---	---	7.32
Field Temperature [celcius]	---	---	---	---	7.5
Carbonaceous Biochemical Oxygen Demand [(CBOD5) mg/L]	11-Apr-23	16:37	17-Apr-23	13:08	< 4
Total Suspended Solids [mg/L]	12-Apr-23	11:27	13-Apr-23	14:26	5
Phosphorus (total) [mg/L]	18-Apr-23	15:23	19-Apr-23	12:49	0.07
Ammonia+Ammonium (N) [as N mg/L]	13-Apr-23	15:47	14-Apr-23	10:58	< 0.1

Carrie Greenlaw  
Project Specialist,  
Environment, Health & Safety

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 110001612**Project :** PO#017018

19-April-2023

**OCWA-Kawartha (Fenelon Falls WWTF)**

Attn : Christine Craig

PO Box 279, Boyd St. E  
Bobcaygeon, ON  
K0M 1A0, Canada

Phone: 705-887-3596

Fax:

**Date Rec. :** 11 April 2023**LR Report:** CA12426-APR23**Copy:** #1

## CERTIFICATE OF ANALYSIS

### Final Report

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Completed Date	4: Analysis Completed Time	5: TeBy TeBy-Final Effluent-Comp
Sample Date & Time					07-Apr-23 20:45
Temperature Upon Receipt [°C]	---	---	---	---	10.0
Field pH [no unit]	---	---	---	---	7.03
Field Temperature [celcius]	---	---	---	---	7.7
Carbonaceous Biochemical Oxygen Demand [(CBOD5) mg/L]	12-Apr-23	17:20	17-Apr-23	15:58	< 4
Total Suspended Solids [mg/L]	13-Apr-23	07:53	14-Apr-23	09:55	7
Phosphorus (total) [mg/L]	18-Apr-23	15:23	19-Apr-23	12:49	0.08
Ammonia+Ammonium (N) [as N mg/L]	13-Apr-23	15:47	14-Apr-23	10:58	< 0.1

Carrie Greenlaw  
Project Specialist,  
Environment, Health & Safety

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 110001612**Project :** PO#017018

18-April-2023

**OCWA-Kawartha (Fenelon Falls WWTF)**

Attn : Christine Craig

PO Box 279, Boyd St. E  
Bobcaygeon, ON  
K0M 1A0, Canada

Phone: 705-887-3596

Fax:

**Date Rec. :** 11 April 2023**LR Report:** CA12427-APR23**Copy:** #1

## CERTIFICATE OF ANALYSIS

### Final Report

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Completed Date	4: Analysis Completed Time	5: TeBy TeBy-Final Effluent-Comp
Sample Date & Time					08-Apr-23 20:45
Temperature Upon Receipt [°C]	---	---	---	---	10.0
Field pH [no unit]	---	---	---	---	7.01
Field Temperature [celcius]	---	---	---	---	7.9
Carbonaceous Biochemical Oxygen Demand [(CBOD5) mg/L]	12-Apr-23	17:20	17-Apr-23	15:58	< 4
Total Suspended Solids [mg/L]	12-Apr-23	13:52	14-Apr-23	09:50	5
Phosphorus (total) [mg/L]	12-Apr-23	15:01	13-Apr-23	12:54	0.09
Ammonia+Ammonium (N) [as N mg/L]	13-Apr-23	15:47	14-Apr-23	10:59	0.1

*Hawley Anderson, Hon.B.Sc*  
*Project Specialist,*  
*Environment, Health & Safety*

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 110001612**Project :** PO#017018

19-April-2023

**OCWA-Kawartha (Fenelon Falls WWTF)****Attn :** Christine Craig

PO Box 279, Boyd St. E  
Bobcaygeon, ON  
K0M 1A0, Canada

**Phone:** 705-887-3596**Fax:****Date Rec. :** 11 April 2023**LR Report:** CA12423-APR23**Copy:** #1

## CERTIFICATE OF ANALYSIS

### Final Report

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Completed Date	4: Analysis Completed Time	5: TeBy TeBy-Final Effluent-Comp
Sample Date & Time					09-Apr-23 20:45
Temperature Upon Receipt [°C]	---	---	---	---	10.0
Field pH [no unit]	---	---	---	---	6.96
Field Temperature [celcius]	---	---	---	---	8.2
Carbonaceous Biochemical Oxygen Demand [(CBOD5) mg/L]	12-Apr-23	17:20	17-Apr-23	15:57	2
Total Suspended Solids [mg/L]	13-Apr-23	07:53	14-Apr-23	09:55	5
Phosphorus (total) [mg/L]	18-Apr-23	15:23	19-Apr-23	12:49	0.06
Ammonia+Ammonium (N) [as N mg/L]	13-Apr-23	15:47	14-Apr-23	10:58	0.1

Carrie Greenlaw  
Project Specialist,  
Environment, Health & Safety

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 110001612**Project :** PO#017018

18-April-2023

**OCWA-Kawartha (Fenelon Falls WWTF)**

Attn : Christine Craig

PO Box 279, Boyd St. E  
Bobcaygeon, ON  
K0M 1A0, Canada

Phone: 705-887-3596

Fax:

**Date Rec. :** 11 April 2023**LR Report:** CA12424-APR23**Copy:** #1

## CERTIFICATE OF ANALYSIS

### Final Report

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Completed Date	4: Analysis Completed Time	5: TeBy TeBy-Final Effluent-Comp
Sample Date & Time					10-Apr-23 20:45
Temperature Upon Receipt [°C]	---	---	---	---	10.0
Field pH [no unit]	---	---	---	---	6.96
Field Temperature [celcius]	---	---	---	---	9.0
Carbonaceous Biochemical Oxygen Demand [(CBOD5) mg/L]	12-Apr-23	17:20	17-Apr-23	15:57	< 4
Total Suspended Solids [mg/L]	13-Apr-23	07:53	14-Apr-23	09:55	5
Phosphorus (total) [mg/L]	13-Apr-23	14:40	14-Apr-23	11:46	0.12
Ammonia+Ammonium (N) [as N mg/L]	13-Apr-23	15:47	14-Apr-23	10:58	< 0.1

*Hawley Anderson, Hon.B.Sc*  
*Project Specialist,*  
*Environment, Health & Safety*

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 110001612**Project :** PO#017018

25-April-2023

**OCWA-Kawartha (Fenelon Falls WWTF)****Attn :** Christine Craig

PO Box 279, Boyd St. E  
Bobcaygeon, ON  
K0M 1A0, Canada

**Phone:** 705-887-3596**Fax:****Date Rec. :** 12 April 2023**LR Report:** CA13343-APR23**Copy:** #2

## CERTIFICATE OF ANALYSIS

### Final Report - Revised

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Completed Date	4: Analysis Completed Time	5: TeBy TeBy-Final Effluent-Comp
Sample Date & Time					11-Apr-23 07:50
Temperature Upon Receipt [°C]	---	---	---	---	9.0
Field pH [no unit]	---	---	---	---	7.14
Field Temperature [celcius]	---	---	---	---	8.4
Carbonaceous Biochemical Oxygen Demand [(CBOD5) mg/L]	13-Apr-23	16:45	18-Apr-23	15:46	< 2
Total Suspended Solids [mg/L]	14-Apr-23	10:28	17-Apr-23	14:08	3
Phosphorus (total) [mg/L]	13-Apr-23	14:40	14-Apr-23	11:54	0.06
Ammonia+Ammonium (N) [as N mg/L]	13-Apr-23	17:41	14-Apr-23	09:13	0.4

\*Report revised - sampling date corrected.

*Hawley Anderson, Hon.B.Sc*  
**Project Specialist,**  
**Environment, Health & Safety**

**5886 FENELON FALLS WASTEWATER TREATMENT FACILITY 110001612**
**4 / 2023**
**Monthly Limit**
**Flows**

Raw Flow: Total - Raw m³/d		49,555.00		
Raw Flow: Avg - Raw m³/d		1,651.83		
Raw Flow: Max - Raw m³/d		3,397.00		
Raw Flow: Count - Raw m³/d		30.00		
Eff. Flow: Total - Eff m³/d		49,555.00		
Eff. Flow: Avg - Eff m³/d		1,651.83		
Eff. Flow: Max - Eff m³/d		3,397.00		
Eff Flow: Count - Eff m³/d		30.00		

**Carbonaceous Biochemical Oxygen Demand: CBOD**

Eff: Avg cBOD5 - Final Effluent including Bypass mg/L	<	3.00		
Eff: # of samples of cBOD5 - Final Effluent including Bypass mg/L		10.00		
Loading: cBOD5 - Final Effluent including Bypass kg/d	<	4.956		

**Total Suspended Solids: TSS**

Eff: Avg TSS - Final Effluent including Bypass mg/L	<	5.30		
Eff: # of samples of TSS - Final Effluent including Bypass mg/L		10.00		
Loading: TSS - Final Effluent including Bypass kg/d	<	8.755		

**Total Phosphorus: TP**

Raw: Avg TP - Raw mg/L		2.26		
Raw: # of samples of TP - Raw mg/L		1.00		
Eff: Avg TP - Final Effluent including Bypass mg/L		0.08		0.50
Eff: # of samples of TP - Final Effluent including Bypass mg/L		10.00		
Loading: TP - Final Effluent including Bypass kg/d		0.132		0.9

**Nitrogen Series**

Raw: Avg TKN - Raw mg/L		21.10		
Raw: # of samples of TKN - Raw mg/L		1.00		
Eff: Avg TAN - Final Effluent including Bypass mg/L	<	0.92		3.5
Eff: # of samples of TAN - Final Effluent including Bypass mg/L		10.00		
Loading: TAN - Final Effluent including Bypass kg/d	<	1.520		6.3
Eff: Avg NO3-N - Eff mg/L		4.59		
Eff: # of samples of NO3-N - Eff mg/L		4.00		
Eff: Avg NO2-N - Eff mg/L		0.18		
Eff: # of samples of NO2-N - Eff mg/L		4.00		

**Disinfection**

Eff: GMD E. Coli - Eff cfu/100mL		4.43		200.00
Eff: # of samples of E. Coli - Eff cfu/100mL		4.00		

**Eff/pH-every sample result to meet limits**

Max IH		7.31		9.5
Min IH		6.84		6.0

Fenelon Falls WPCP - Quarterly Overflow Report  
Environmental Compliance Approval #3688-BW3RGB  
Year: 2023  
Q2 = April, May and June

Did an Overflow occur during this quarter:

Yes ☒ No ☐

*\*\*Although not required as per CLI-ECA 141-W601, the information from the Overflow event at the Colborne Street Sewage Pumping Station has been included for reference.\*\**

Condition 5. Overflow		Event
5.3	a. the type of the Overflow (emergency or planned)	SAC # 1-34X4Mo - emergency overflow due to heavy rain event - Operations Event Form Summary attached.
	b. the date and time of the beginning of the Overflow	April 5, 2023 @ 21:50
	c. the point of the Overflow from the Works, the treatment process(es) gone through prior to the Overflow, the disinfection status of the Overflow and whether the Overflow is discharged through the effluent disposal facilities or an alternate location;	Overflow at Colborne St. Sewage Pumping Station - raw sewage, no treatment.
	d. the effort(s) done to maximize the flow through the downstream treatment process(es) and Bypasses and the reason(s) why the Overflow was not avoided.	Monitor flows, owner posted notice on social media site. Utilized detention tank. Shepherds Environmental contacted to haul sewage from Francis St SPS to the sewage treatment plant.
5.4	a. the date and time of the end of the Overflow;	April 6, 2023 @ 09:30
	b. the estimated or measured volume of Overflow.	2,220 m <sup>3</sup> estimate based on duration and flow rate
5.5	a. Overflow event in Sewage Treatment Plant, grab sample(s) of the Overflow, one near the beginning of the Event and one every eight (8) hours for the duration of the Event, and have them analyzed at least for CBOD5, total suspended solids, total phosphorus, total ammonia nitrogen, nitrate as N, nitrite as N, total Kjeldahl nitrogen, E. coli. , except that raw sewage and primary treated effluent Overflow shall be analyzed for BOD5, total suspended solids, total phosphorus and total Kjeldahl nitrogen only.	N/A
	b. at a sewage pumping station in the collection system, at least one (1) grab sample representative of the Overflow Event and have it analyzed for BOD5, total suspended solids, total phosphorus and total Kjeldahl nitrogen	Grab samples collected and lab reports attached.
5.6	...The summary report shall contain, at a minimum, the types of information set out in Paragraphs (3), (4) and (5). If there is no Overflow Event during a quarter, a statement of no occurrence of Overflow is deemed sufficient.	



**Fenelon Falls Collection System Overflow Event Form - EMERGENCY**

**Location:**

<b>Column 1 Asset ID</b>	<b>Column 2 Asset Name</b>	<b>Column 3 Overflow Location (Latitude and Longitude)</b>	<b>Column 4 Point of Entry to Receiver (Latitude and Longitude)</b>
N/A	Fenelon Falls Sewage Pumping Station 2- Colborne St. Overflow	44.535925, -78.736196	Fenelon River 44.535925, -78.736196

**Date(s):** April 5- April 6, 2023

**Nature of Event:** Raw sewage overflow at the Fenelon Falls Sewage Pumping Station 2- Colborne St. SPS

**Details of Event:** Heavy rain event (approx. 30mm of rain plus snow melt) caused high flows resulting in raw sewage being overflowed to the Fenelon River.

**Call SAC: 1-800-268-6060 Time SAC notified:** 22:20 on April 5, 2023      **SAC Incident #:** 1-34X4Mo

**Name of Person at SAC:** Brenda

**Contact HKPRDHU: Mon – Fri 8:30 -16:30 at 1-866-888-4577 ext. 5006**  
**or after hours: 1-888-255-7839**

**Time HKPRDHU notified:** Message left 22:31 on April 5, 2023

**Name of Person at Health Unit:** Neha Gandhi, PHI returned call at 22:37. Information provided for: downstream DWS- Southview Estates municipal drinking water system- located 10 km downstream on Sturgeon Lake, OCWA operating authority. It was recommended to review the Southview Estates DWS and complete regular operational checks to ensure there are no impacts related to this overflow incident.

PHI requested a media release be posted by the City of Kawartha Lakes (CKL) to notify residents (notice attached).

**All Other Notifications (Managers, PCT, Client, MECP):**

J. Manning Sr. Ops. Mgr., ORO OCWA, C. Craig PCT OCWA, R. Rohrbasser Operator OCWA  
 CKL, and OCWA: W. Henneberry SPC Mgr, G. Redden General Manager, K. Lorente Regional Mgr, &  
 R. Junkin VP Operations

---

**Volume of Overflow:** ~2, 220 m<sup>3</sup> (calculated based on peak flow rate around the time of the start of the overflow)

**Start (date & time):** April 5, 2023 @ 21:50      **Finish (date & time):** April 6, 2023 @ 09:30

SAC updated on April 6, 2023 @ 12:19 spoke with Peter-provided estimated volume and duration of the event.

MOH contacted on April 06, 2023 @ 12:18-message left. PHI, Bernie Mayer called back at 13:40 provided total estimated volumes and duration of event.

**Samples Collected (indicate dates and times):** BOD5, TSS, Total Phos, TKN and E. Coli

**Corrective Action Taken:**

- Monitored flows, additional staff called to assist, the detention tank at the Ellice St. SPS was fully utilized, Shepherd Environmental contacted to haul sewage from Francis St SPS to the sewage treatment plant to help reduce volume.
- Samples collected every each day of the overflow.

**Prepared By:** C. Craig

---

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 110001612**Project :** PO#017018

14-April-2023

**OCWA-Kawartha (Fenelon Falls WWTF)****Attn :** Christine Craig

PO Box 279, Boyd St. E  
Bobcaygeon, ON  
K0M 1A0, Canada

**Phone:** 705-887-3596**Fax:****Date Rec. :** 06 April 2023**LR Report:** CA12243-APR23**Copy:** #2

## CERTIFICATE OF ANALYSIS

### Final Report - Revised

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Completed Date	4: Analysis Completed Time	5: SSO SSO-Colborne SPS Overflow @ 20:25
Sample Date & Time					05-Apr-23 22:25
Temperature Upon Receipt [°C]	---	---	---	---	7.0
Biochemical Oxygen Demand (BOD5) [mg/L]	06-Apr-23	19:55	12-Apr-23	12:33	29
Total Suspended Solids [mg/L]	12-Apr-23	11:27	13-Apr-23	14:26	21
Phosphorus (total) [mg/L]	11-Apr-23	14:23	13-Apr-23	07:32	0.66
Total Kjeldahl Nitrogen [as N mg/L]	12-Apr-23	07:59	13-Apr-23	08:25	5.1
E. Coli [cfu/100mL]	06-Apr-23	15:54	10-Apr-23	12:27	NDOGEC

NDOGEC - No Data: Overgrown with E. coli

\*Report revised - Sampling date/time revised as requested.



Carrie Greenlaw  
Project Specialist,  
Environment, Health & Safety

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 110001612**Project :** PO#017018

13-April-2023

**OCWA-Kawartha (Fenelon Falls WWTF)****Attn :** Christine Craig**Date Rec. :** 06 April 2023**LR Report:** CA12242-APR23

PO Box 279, Boyd St. E  
Bobcaygeon, ON  
K0M 1A0, Canada

**Copy:** #2**Phone:** 705-887-3596**Fax:**

## CERTIFICATE OF ANALYSIS

### Final Report

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Completed Date	4: Analysis Completed Time	5: SSO SSO-Colborne SPS Overflow
Sample Date & Time					06-Apr-23 09:25
Temperature Upon Receipt [°C]	---	---	---	---	7.0
Biochemical Oxygen Demand (BOD5) [mg/L]	06-Apr-23	19:55	12-Apr-23	12:33	26
Total Suspended Solids [mg/L]	12-Apr-23	11:27	13-Apr-23	14:26	36
Phosphorus (total) [mg/L]	11-Apr-23	14:23	13-Apr-23	07:32	1.04
Total Kjeldahl Nitrogen [as N mg/L]	12-Apr-23	07:59	13-Apr-23	08:25	8.7
E. Coli [cfu/100mL]	06-Apr-23	16:26	10-Apr-23	12:43	NDOGEC

NDOGEC - No Data: Overgrown with E. coli

*Hawley Anderson, Hon.B.Sc*  
**Project Specialist,  
Environment, Health & Safety**



November 06, 2023

David Bradley, District Manager  
Peterborough District Office  
Ministry of Environment, Conservation and Parks  
300 Water Street South, 2nd Floor, South Tower  
Peterborough ON K9J 3C7

Dear David Bradley:

**Re: Fenelon Falls WPCP Q3 2023 Bypass and Overflow Event Reports**

Amended Environmental Compliance Approval #3688-BW3RGB Conditions 4 and 5 issued January 15, 2021, for the Fenelon Falls WPCP require Bypass and Overflow quarterly reports be submitted to the District Manager. These reports are to be submitted no later than February 15, May 15, August 15, and November 15 each year for Events that occurred during the preceding quarter.

No Bypass or Overflow Events occurred at the Fenelon Falls WPCP during the third quarter of 2023 – reports are attached.

Please contact me if you have any questions or comments.

Best regards,

Christine Craig  
Process & Compliance Technician  
Ontario Clean Water Agency  
Kawartha-Trent Region  
(705) 731-9579

Attachments

cc: J. Manning, Sr. Operations Manager, OCWA Kawartha-Trent Regional Hub  
A. Hayter, Supervisor Water & Wastewater, CKL  
J. Mulligan, Safety, Process & Compliance Manager (A), OCWA Kawartha Hub  
G. Redden, General Manager, OCWA Kawartha-Trent Regional Hub  
W. Henneberry, Regional Hub Manager (A), OCWA Kawartha-Trent Regional Hub  
B. Jackson, Water Inspector, MECP – Peterborough District Office

Fenelon Falls WPCP - Quarterly Bypass Report  
 Environmental Compliance Approval #3688-BW3RGB  
 Year: 2023  
 Q3 = July, August, September

Did a Bypass occur during this quarter:  
 Yes ☐ No ☒

Condition 4. Bypasses		Event
4.3	a. the type of the Bypass (emergency or planned)	
	b. the date and time of the beginning of the Bypass	
	c. the treatment process(es) gone through prior to the Bypass and the treatment process(es) bypassed;	
	d. the effort(s) done to maximize the flow through the downstream treatment process(es) and the reason(s) why the Bypass was not avoided.	
4.4	a. the date and time of the end of the Bypass;	
	b. the estimated or measured volume of Bypass.	
4.5	For any Bypass Event, the Owner shall collect daily sample(s) of the Final Effluent, inclusive of the Event and analyze for all effluent parameters outlined in Compliance Limits condition that require composite samples following the same protocol specified in the Monitoring and Recording condition for the regular samples. The sample(s) shall be in addition to the regular Final Effluent samples required under the monitoring and recording condition. If the Event occurs on a scheduled monitoring day, the regular sampling requirements prevail. If representative sample for the effluent parameter(s) that require grab sample cannot be obtained, they shall be collected after the Event at the earliest time when situation returns to normal.	
4.6	. . . .The summary reports shall contain, at a minimum, the types of information set out in Paragraphs (3), (4) and (5) and either a statement of compliance or a summary of the non-compliance notifications submitted as required under Paragraph 1 of Condition 11. If there is no Bypass Event during a quarter, a statement of no occurrence of Bypass is deemed sufficient.	No occurrence of Bypass

Fenelon Falls WPCP - Quarterly Overflow Report  
 Environmental Compliance Approval #3688-BW3RGB  
 Year: 2023  
 Q3 = July, August, September

Did an Overflow occur during this quarter:  
 Yes ☐ No ☒

Condition 5. Overflow		Event
5.3	a. the type of the Overflow (emergency or planned)	
	b. the date and time of the beginning of the Overflow	
	c. the point of the Overflow from the Works, the treatment process(es) gone through prior to the Overflow, the disinfection status of the Overflow and whether the Overflow is discharged through the effluent disposal facilities or an alternate location;	
	d. the effort(s) done to maximize the flow through the downstream treatment process(es) and Bypasses and the reason(s) why the Overflow was not avoided.	
5.4	a. the date and time of the end of the Overflow;	
	b. the estimated or measured volume of Overflow.	
5.5	a. Overflow event in Sewage Treatment Plant, grab sample(s) of the Overflow, one near the beginning of the Event and one every eight (8) hours for the duration of the Event, and have them analyzed at least for CBOD5, total suspended solids, total phosphorus, total ammonia nitrogen, nitrate as N, nitrite as N, total Kjeldahl nitrogen, E. coli. , except that raw sewage and primary treated effluent Overflow shall be analyzed for BOD5, total suspended solids, total phosphorus and total Kjeldahl nitrogen only.	
	b. at a sewage pumping station in the collection system, at least one (1) grab sample representative of the Overflow Event and have it analyzed for BOD5, total suspended solids, total phosphorus and total Kjeldahl nitrogen.	
5.6	...The summary report shall contain, at a minimum, the types of information set out in Paragraphs (3), (4) and (5). If there is no Overflow Event during a quarter, a statement of no occurrence of Overflow is deemed sufficient.	No Occurrence of Overflow.



January 15, 2024

David Bradley, District Manager  
Peterborough District Office  
Ministry of Environment, Conservation and Parks  
300 Water Street South, 2nd Floor, South Tower  
Peterborough ON K9J 3C7

Dear David Bradley:

**Re: Fenelon Falls WPCP Q4 2023 Bypass and Overflow Event Reports**

Amended Environmental Compliance Approval #3688-BW3RGB Conditions 4 and 5 issued January 15, 2021, for the Fenelon Falls WPCP require Bypass and Overflow quarterly reports be submitted to the District Manager. These reports are to be submitted no later than February 15, May 15, August 15, and November 15 each year for Events that occurred during the preceding quarter.

No Bypass or Overflow Events occurred at the Fenelon Falls WPCP during the fourth quarter of 2023 – reports are attached.

Please contact me if you have any questions or comments.

Best regards,

Christine Craig  
Process & Compliance Technician  
Ontario Clean Water Agency  
Kawartha-Trent Region  
(705) 731-9579

**Attachments**

cc: J. Manning, Sr. Operations Manager, OCWA Kawartha-Trent Regional Hub  
A. Hayter, Supervisor Water & Wastewater, CKL  
J. Mulligan, Safety, Process & Compliance Manager (A), OCWA Kawartha Hub  
G. Redden, General Manager, OCWA Kawartha-Trent Regional Hub  
W. Henneberry, Regional Hub Manager (A), OCWA Kawartha-Trent Regional Hub  
B. Jackson, Water Inspector, MECP – Peterborough District Office



Fenelon Falls WPCP - Quarterly Bypass Report  
 Environmental Compliance Approval #3688-BW3RGB  
 Year: 2023  
 Q4 = October, November, December

Did a Bypass occur during this quarter:  
 Yes ☐ No ☒

Condition 4. Bypasses		Event
4.3	a. the type of the Bypass (emergency or planned)	
	b. the date and time of the beginning of the Bypass	
	c. the treatment process(es) gone through prior to the Bypass and the treatment process(es) bypassed;	
	d. the effort(s) done to maximize the flow through the downstream treatment process(es) and the reason(s) why the Bypass was not avoided.	
4.4	a. the date and time of the end of the Bypass;	
	b. the estimated or measured volume of Bypass.	
4.5	For any Bypass Event, the Owner shall collect daily sample(s) of the Final Effluent, inclusive of the Event and analyze for all effluent parameters outlined in Compliance Limits condition that require composite samples following the same protocol specified in the Monitoring and Recording condition for the regular samples. The sample(s) shall be in addition to the regular Final Effluent samples required under the monitoring and recording condition. If the Event occurs on a scheduled monitoring day, the regular sampling requirements prevail. If representative sample for the effluent parameter(s) that require grab sample cannot be obtained, they shall be collected after the Event at the earliest time when situation returns to normal.	
4.6	. . . .The summary reports shall contain, at a minimum, the types of information set out in Paragraphs (3), (4) and (5) and either a statement of compliance or a summary of the non-compliance notifications submitted as required under Paragraph 1 of Condition 11. If there is no Bypass Event during a quarter, a statement of no occurrence of Bypass is deemed sufficient.	No occurrence of Bypass

Fenelon Falls WPCP - Quarterly Overflow Report  
Environmental Compliance Approval #3688-BW3RGB  
Year: 2023  
Q4= October, November, December

Did an Overflow occur during this quarter:  
Yes ☐ No ☒

Condition 5. Overflow		Event
5.3	a. the type of the Overflow (emergency or planned)	
	b. the date and time of the beginning of the Overflow	
	c. the point of the Overflow from the Works, the treatment process(es) gone through prior to the Overflow, the disinfection status of the Overflow and whether the Overflow is discharged through the effluent disposal facilities or an alternate location;	
	d. the effort(s) done to maximize the flow through the downstream treatment process(es) and Bypasses and the reason(s) why the Overflow was not avoided.	
5.4	a. the date and time of the end of the Overflow;	
	b. the estimated or measured volume of Overflow.	
5.5	a. Overflow event in Sewage Treatment Plant, grab sample(s) of the Overflow, one near the beginning of the Event and one every eight (8) hours for the duration of the Event, and have them analyzed at least for CBOD5, total suspended solids, total phosphorus, total ammonia nitrogen, nitrate as N, nitrite as N, total Kjeldahl nitrogen, E. coli. , except that raw sewage and primary treated effluent Overflow shall be analyzed for BOD5, total suspended solids, total phosphorus and total Kjeldahl nitrogen only.	
	b. at a sewage pumping station in the collection system, at least one (1) grab sample representative of the Overflow Event and have it analyzed for BOD5, total suspended solids, total phosphorus and total Kjeldahl nitrogen.	
5.6	...The summary report shall contain, at a minimum, the types of information set out in Paragraphs (3), (4) and (5). If there is no Overflow Event during a quarter, a statement of no occurrence of Overflow is deemed sufficient.	No Occurrence of Overflow.

# Appendix VI

---

## Sampling Calendar



## Sample Calendar

### Fenelon Falls WPCP Org #5886 – Works #110001612

**Influent (Raw) and Effluent Samples must be collected on the day indicated on Calendar. If day has to be switched (i.e. composite sampler failed), the reason must be noted in the logbook and an email sent to the ORO, PCT & Sr. Ops Manager**

**Daily:** Record all operational parameters on daysheet/logbook.

Influent Monitoring (Raw)		
Parameters	Sample Type	Frequency
BOD5	Composite	Monthly
Total Suspended Solids	Composite	Monthly
Total Phosphorus	Composite	Monthly
Total Kjeldahl Nitrogen	Composite	Monthly

Biosolids Monitoring (when hauling)		
Parameters	Sample Type	Frequency
Total Solids	Grab	Once/month
Total Phosphorus	Grab	Once/month
Total Ammonia Nitrogen	Grab	Once/month
Metals Scan*	Grab	Once/month
E. Coli	Grab	Once/month

\* Arsenic, Cadmium, Cobalt, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Potassium, Selenium, Zinc

Final Effluent Monitoring		
Parameters	Sample Type	Frequency
CBOD5	Composite	Weekly
Total Suspended Solids	Composite	Weekly
Total Phosphorus	Composite	Weekly
Total Ammonia Nitrogen	Composite	Weekly
Total Kjeldahl Nitrogen	Composite	Weekly
Nitrate as Nitrogen	Composite	Weekly
Nitrite as Nitrogen	Composite	Weekly
E. coli	Grab	Weekly
Field pH	Grab	Weekly
Field Temperature	Grab	Weekly
Un-ionized Ammonia	calculated	Weekly

**OPERATOR SIGN-OFF:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

(all collection and submission complete as per ECA, etc. + any special requirements)

# January 2024

Sun	Mon	Tue	Wed	Thu	Fri	Sat
	1 New Year's Day Stat	2	3 <input type="checkbox"/> Weekly <input type="checkbox"/> Monthly	4	5	6
7	8	9	10 <input type="checkbox"/> Weekly	11	12	13
14	15	16	17 <input type="checkbox"/> Weekly	18	19	20
21	22	23	24 <input type="checkbox"/> Weekly	25	26	27
28	29	30	31 <input type="checkbox"/> Weekly		Sample Collection Time Frames (Days)	Weekly >5 & <10 Monthly >20 & <40



## Sample Calendar

### Fenelon Falls WPCP Org #5886 – Works #110001612

**Influent (Raw) and Effluent Samples must be collected on the day indicated on Calendar. If day has to be switched (i.e. composite sampler failed), the reason must be noted in the logbook and an email sent to the ORO, PCT & Sr. Ops Manager**

**Daily:** Record all operational parameters on daysheet/logbook.

Influent Monitoring (Raw)		
Parameters	Sample Type	Frequency
BOD5	Composite	Monthly
Total Suspended Solids	Composite	Monthly
Total Phosphorus	Composite	Monthly
Total Kjeldahl Nitrogen	Composite	Monthly

Biosolids Monitoring (when hauling)		
Parameters	Sample Type	Frequency
Total Solids	Grab	Once/month
Total Phosphorus	Grab	Once/month
Total Ammonia Nitrogen	Grab	Once/month
Metals Scan*	Grab	Once/month
E. Coli	Grab	Once/month

\* Arsenic, Cadmium, Cobalt, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Potassium, Selenium, Zinc

Final Effluent Monitoring		
Parameters	Sample Type	Frequency
CBOD5	Composite	Weekly
Total Suspended Solids	Composite	Weekly
Total Phosphorus	Composite	Weekly
Total Ammonia Nitrogen	Composite	Weekly
Total Kjeldahl Nitrogen	Composite	Weekly
Nitrate as Nitrogen	Composite	Weekly
Nitrite as Nitrogen	Composite	Weekly
E. coli	Grab	Weekly
Field pH	Grab	Weekly
Field Temperature	Grab	Weekly
Un-ionized Ammonia	calculated	Weekly

**OPERATOR SIGN-OFF:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

(all collection and submission complete as per ECA, etc. + any special requirements)

# February 2024

Sun	Mon	Tue	Wed	Thu	Fri	Sat
Sample Collection Time Frames (Days)	Weekly >5 & <10 Monthly >20 & <40			1	2	3
4	5	6	7 <input type="checkbox"/> Weekly <input type="checkbox"/> Monthly	8	9	10
11	12	13	14 <input type="checkbox"/> Weekly	15	16	17
18	19 Family Day Stat	20	21 <input type="checkbox"/> Weekly	22	23	24
25	26	27	28 <input type="checkbox"/> Weekly	29		



## Sample Calendar

### Fenelon Falls WPCP Org #5886 – Works #110001612

**Influent (Raw) and Effluent Samples must be collected on the day indicated on Calendar. If day has to be switched (i.e. composite sampler failed), the reason must be noted in the logbook and an email sent to the ORO, PCT & Sr. Ops Manager**

**Daily:** Record all operational parameters on daysheet/logbook.

Influent Monitoring (Raw)		
Parameters	Sample Type	Frequency
BOD5	Composite	Monthly
Total Suspended Solids	Composite	Monthly
Total Phosphorus	Composite	Monthly
Total Kjeldahl Nitrogen	Composite	Monthly

Biosolids Monitoring (when hauling)		
Parameters	Sample Type	Frequency
Total Solids	Grab	Once/month
Total Phosphorus	Grab	Once/month
Total Ammonia Nitrogen	Grab	Once/month
Metals Scan*	Grab	Once/month
E. Coli	Grab	Once/month

\* Arsenic, Cadmium, Cobalt, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Potassium, Selenium, Zinc

Final Effluent Monitoring		
Parameters	Sample Type	Frequency
CBOD5	Composite	Weekly
Total Suspended Solids	Composite	Weekly
Total Phosphorus	Composite	Weekly
Total Ammonia Nitrogen	Composite	Weekly
Total Kjeldahl Nitrogen	Composite	Weekly
Nitrate as Nitrogen	Composite	Weekly
Nitrite as Nitrogen	Composite	Weekly
E. coli	Grab	Weekly
Field pH	Grab	Weekly
Field Temperature	Grab	Weekly
Un-ionized Ammonia	calculated	Weekly

**OPERATOR SIGN-OFF:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

(all collection and submission complete as per ECA, etc. + any special requirements)

# March 2024

Sun	Mon	Tue	Wed	Thu	Fri	Sat
Sample Collection Time Frames (Days)	Weekly >5 & <10 Monthly >20 & <40				1	2
3	4	5	6 <input type="checkbox"/> Weekly <input type="checkbox"/> Monthly	7	8	9
10	11	12	13 <input type="checkbox"/> Weekly	14	15	16
17	18	19	20 <input type="checkbox"/> Weekly	21	22	23
24	25	26	27 <input type="checkbox"/> Weekly	28	29 Good Friday Stat	30
31						



## Sample Calendar

### Fenelon Falls WPCP Org #5886 – Works #110001612

**Influent (Raw) and Effluent Samples must be collected on the day indicated on Calendar. If day has to be switched (i.e. composite sampler failed), the reason must be noted in the logbook and an email sent to the ORO, PCT & Sr. Ops Manager**

**Daily:** Record all operational parameters on daysheet/logbook.

Influent Monitoring (Raw)		
Parameters	Sample Type	Frequency
BOD5	Composite	Monthly
Total Suspended Solids	Composite	Monthly
Total Phosphorus	Composite	Monthly
Total Kjeldahl Nitrogen	Composite	Monthly

Biosolids Monitoring (when hauling)		
Parameters	Sample Type	Frequency
Total Solids	Grab	Once/month
Total Phosphorus	Grab	Once/month
Total Ammonia Nitrogen	Grab	Once/month
Metals Scan*	Grab	Once/month
E. Coli	Grab	Once/month

\* Arsenic, Cadmium, Cobalt, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Potassium, Selenium, Zinc

Final Effluent Monitoring		
Parameters	Sample Type	Frequency
CBOD5	Composite	Weekly
Total Suspended Solids	Composite	Weekly
Total Phosphorus	Composite	Weekly
Total Ammonia Nitrogen	Composite	Weekly
Total Kjeldahl Nitrogen	Composite	Weekly
Nitrate as Nitrogen	Composite	Weekly
Nitrite as Nitrogen	Composite	Weekly
E. coli	Grab	Weekly
Field pH	Grab	Weekly
Field Temperature	Grab	Weekly
Un-ionized Ammonia	calculated	Weekly

**OPERATOR SIGN-OFF:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

# April 2024

Sun	Mon	Tue	Wed	Thu	Fri	Sat
	1 Easter Monday Stat	2	3 <input type="checkbox"/> Weekly <input type="checkbox"/> Monthly	4	5	6
7	8	9	10 <input type="checkbox"/> Weekly	11	12	13
14	15	16	17 <input type="checkbox"/> Weekly	18	19	20
21	22	23	24 <input type="checkbox"/> Weekly	25	26	27
28	29	30		Sample Collection Time Frames (Days)	Weekly >5 & <10 Monthly >20 & <40	



Ontario Clean Water Agency  
Agence Ontarienne Des Eaux

## Sample Calendar

### Fenelon Falls WPCP Org #5886 – Works #110001612

**Influent (Raw) and Effluent Samples must be collected on the day indicated on Calendar. If day has to be switched (i.e. composite sampler failed), the reason must be noted in the logbook and an email sent to the ORO, PCT & Sr. Ops Manager**

**Daily:** Record all operational parameters on daysheet/logbook.

Influent Monitoring (Raw)		
Parameters	Sample Type	Frequency
BOD5	Composite	Monthly
Total Suspended Solids	Composite	Monthly
Total Phosphorus	Composite	Monthly
Total Kjeldahl Nitrogen	Composite	Monthly

Biosolids Monitoring (when hauling)		
Parameters	Sample Type	Frequency
Total Solids	Grab	Once/month
Total Phosphorus	Grab	Once/month
Total Ammonia Nitrogen	Grab	Once/month
Metals Scan*	Grab	Once/month
E. Coli	Grab	Once/month

\* Arsenic, Cadmium, Cobalt, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Potassium, Selenium, Zinc

Final Effluent Monitoring		
Parameters	Sample Type	Frequency
CBOD5	Composite	Weekly
Total Suspended Solids	Composite	Weekly
Total Phosphorus	Composite	Weekly
Total Ammonia Nitrogen	Composite	Weekly
Total Kjeldahl Nitrogen	Composite	Weekly
Nitrate as Nitrogen	Composite	Weekly
Nitrite as Nitrogen	Composite	Weekly
E. coli	Grab	Weekly
Field pH	Grab	Weekly
Field Temperature	Grab	Weekly
Un-ionized Ammonia	calculated	Weekly

**OPERATOR SIGN-OFF:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

(all collection and submission complete as per ECA, etc. + any special requirements)

# May 2024

Sun	Mon	Tue	Wed	Thu	Fri	Sat
<b>Sample Collection Time Frames (Days)</b> Weekly >5 & <10 Monthly >20 & <40			1 <input type="checkbox"/> Weekly <input type="checkbox"/> Monthly	2	3	4
5	6	7	8 <input type="checkbox"/> Weekly	9	10	11
12	13	14	15 <input type="checkbox"/> Weekly	16	17	18
19	20 Victoria Day Stat	21	22 <input type="checkbox"/> Weekly	23	24	25
26	27	28	29 <input type="checkbox"/> Weekly	30	31	





## Sample Calendar

### Fenelon Falls WPCP Org #5886 – Works #110001612

**Influent (Raw) and Effluent Samples must be collected on the day indicated on Calendar. If day has to be switched (i.e. composite sampler failed), the reason must be noted in the logbook and an email sent to the ORO, PCT & Sr. Ops Manager**

**Daily:** Record all operational parameters on daysheet/logbook.

Influent Monitoring (Raw)		
Parameters	Sample Type	Frequency
BOD5	Composite	Monthly
Total Suspended Solids	Composite	Monthly
Total Phosphorus	Composite	Monthly
Total Kjeldahl Nitrogen	Composite	Monthly

Biosolids Monitoring (when hauling)		
Parameters	Sample Type	Frequency
Total Solids	Grab	Once/month
Total Phosphorus	Grab	Once/month
Total Ammonia Nitrogen	Grab	Once/month
Metals Scan*	Grab	Once/month
E. Coli	Grab	Once/month

\* Arsenic, Cadmium, Cobalt, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Potassium, Selenium, Zinc

Final Effluent Monitoring		
Parameters	Sample Type	Frequency
CBOD5	Composite	Weekly
Total Suspended Solids	Composite	Weekly
Total Phosphorus	Composite	Weekly
Total Ammonia Nitrogen	Composite	Weekly
Total Kjeldahl Nitrogen	Composite	Weekly
Nitrate as Nitrogen	Composite	Weekly
Nitrite as Nitrogen	Composite	Weekly
E. coli	Grab	Weekly
Field pH	Grab	Weekly
Field Temperature	Grab	Weekly
Un-ionized Ammonia	calculated	Weekly

**OPERATOR SIGN-OFF:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

(all collection and submission complete as per ECA, etc. + any special requirements)

# June 2024

Sun	Mon	Tue	Wed	Thu	Fri	Sat
						1
2	3	4	5 <input type="checkbox"/> Weekly <input type="checkbox"/> Monthly	6	7	8
9	10	11	12 <input type="checkbox"/> Weekly	13	14	15
16	17	18	19 <input type="checkbox"/> Weekly	20	21	22
23	24	25	26 <input type="checkbox"/> Weekly	27	28	29
30				Sample Collection Time Frames (Days)	Weekly >5 & <10 Monthly >20 & <40	



## Sample Calendar

### Fenelon Falls WPCP Org #5886 – Works #110001612

**Influent (Raw) and Effluent Samples must be collected on the day indicated on Calendar. If day has to be switched (i.e. composite sampler failed), the reason must be noted in the logbook and an email sent to the ORO, PCT & Sr. Ops Manager**

**Daily:** Record all operational parameters on daysheet/logbook.

Influent Monitoring (Raw)		
Parameters	Sample Type	Frequency
BOD5	Composite	Monthly
Total Suspended Solids	Composite	Monthly
Total Phosphorus	Composite	Monthly
Total Kjeldahl Nitrogen	Composite	Monthly

Biosolids Monitoring (when hauling)		
Parameters	Sample Type	Frequency
Total Solids	Grab	Once/month
Total Phosphorus	Grab	Once/month
Total Ammonia Nitrogen	Grab	Once/month
Metals Scan*	Grab	Once/month
E. Coli	Grab	Once/month

\* Arsenic, Cadmium, Cobalt, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Potassium, Selenium, Zinc

Final Effluent Monitoring		
Parameters	Sample Type	Frequency
CBOD5	Composite	Weekly
Total Suspended Solids	Composite	Weekly
Total Phosphorus	Composite	Weekly
Total Ammonia Nitrogen	Composite	Weekly
Total Kjeldahl Nitrogen	Composite	Weekly
Nitrate as Nitrogen	Composite	Weekly
Nitrite as Nitrogen	Composite	Weekly
E. coli	Grab	Weekly
Field pH	Grab	Weekly
Field Temperature	Grab	Weekly
Un-ionized Ammonia	calculated	Weekly

**OPERATOR SIGN-OFF:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

(all collection and submission complete as per ECA, etc. + any special requirements)

# July 2024

Sun	Mon	Tue	Wed	Thu	Fri	Sat
	1 Canada Day Stat	2	3 <input type="checkbox"/> Weekly <input type="checkbox"/> Monthly	4	5	6
7	8	9	10 <input type="checkbox"/> Weekly	11	12	13
14	15	16	17 <input type="checkbox"/> Weekly	18	19	20
21	22	23	24 <input type="checkbox"/> Weekly	25	26	27
28	29	30	31 <input type="checkbox"/> Weekly	Sample Collection Time Frames (Days)	Weekly >5 & <10 Monthly >20 & <40	



## Sample Calendar

### Fenelon Falls WPCP Org #5886 – Works #110001612

**Influent (Raw) and Effluent Samples must be collected on the day indicated on Calendar. If day has to be switched (i.e. composite sampler failed), the reason must be noted in the logbook and an email sent to the ORO, PCT & Sr. Ops Manager**

**Daily:** Record all operational parameters on daysheet/logbook.

Influent Monitoring (Raw)		
Parameters	Sample Type	Frequency
BOD5	Composite	Monthly
Total Suspended Solids	Composite	Monthly
Total Phosphorus	Composite	Monthly
Total Kjeldahl Nitrogen	Composite	Monthly

Biosolids Monitoring (when hauling)		
Parameters	Sample Type	Frequency
Total Solids	Grab	Once/month
Total Phosphorus	Grab	Once/month
Total Ammonia Nitrogen	Grab	Once/month
Metals Scan*	Grab	Once/month
E. Coli	Grab	Once/month

\* Arsenic, Cadmium, Cobalt, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Potassium, Selenium, Zinc

Final Effluent Monitoring		
Parameters	Sample Type	Frequency
CBOD5	Composite	Weekly
Total Suspended Solids	Composite	Weekly
Total Phosphorus	Composite	Weekly
Total Ammonia Nitrogen	Composite	Weekly
Total Kjeldahl Nitrogen	Composite	Weekly
Nitrate as Nitrogen	Composite	Weekly
Nitrite as Nitrogen	Composite	Weekly
E. coli	Grab	Weekly
Field pH	Grab	Weekly
Field Temperature	Grab	Weekly
Un-ionized Ammonia	calculated	Weekly

**OPERATOR SIGN-OFF:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

(all collection and submission complete as per ECA, etc. + any special requirements)

# August 2024

<i>Sun</i>	<i>Mon</i>	<i>Tue</i>	<i>Wed</i>	<i>Thu</i>	<i>Fri</i>	<i>Sat</i>
	Sample Collection Time Frames (Days)	Weekly >5 & <10 Monthly >20 & <40		1	2	3
4	5 Civic Holiday Stat	6	7 <input type="checkbox"/> Weekly <input type="checkbox"/> Monthly	8	9	10
11	12	13	14 <input type="checkbox"/> Weekly	15	16	17
18	19	20	21 <input type="checkbox"/> Weekly	22	23	24
25	26	27	28 <input type="checkbox"/> Weekly	29	30	31



## Sample Calendar

### Fenelon Falls WPCP Org #5886 – Works #110001612

**Influent (Raw) and Effluent Samples must be collected on the day indicated on Calendar. If day has to be switched (i.e. composite sampler failed), the reason must be noted in the logbook and an email sent to the ORO, PCT & Sr. Ops Manager**

**Daily:** Record all operational parameters on daysheet/logbook.

Influent Monitoring (Raw)		
Parameters	Sample Type	Frequency
BOD5	Composite	Monthly
Total Suspended Solids	Composite	Monthly
Total Phosphorus	Composite	Monthly
Total Kjeldahl Nitrogen	Composite	Monthly

Biosolids Monitoring (when hauling)		
Parameters	Sample Type	Frequency
Total Solids	Grab	Once/month
Total Phosphorus	Grab	Once/month
Total Ammonia Nitrogen	Grab	Once/month
Metals Scan*	Grab	Once/month
E. Coli	Grab	Once/month

\* Arsenic, Cadmium, Cobalt, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Potassium, Selenium, Zinc

Final Effluent Monitoring		
Parameters	Sample Type	Frequency
CBOD5	Composite	Weekly
Total Suspended Solids	Composite	Weekly
Total Phosphorus	Composite	Weekly
Total Ammonia Nitrogen	Composite	Weekly
Total Kjeldahl Nitrogen	Composite	Weekly
Nitrate as Nitrogen	Composite	Weekly
Nitrite as Nitrogen	Composite	Weekly
E. coli	Grab	Weekly
Field pH	Grab	Weekly
Field Temperature	Grab	Weekly
Un-ionized Ammonia	calculated	Weekly

**OPERATOR SIGN-OFF:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

(all collection and submission complete as per ECA, etc. + any special requirements)

# September 2024

Sun	Mon	Tue	Wed	Thu	Fri	Sat
1	2 Labour Day Stat	3	4 <input type="checkbox"/> Weekly <input type="checkbox"/> Monthly	5	6	7
8	9	10	11 <input type="checkbox"/> Weekly	12	13	14
15	16	17	18 <input type="checkbox"/> Weekly	19	20	21
22	23	24	25 <input type="checkbox"/> Weekly	26	27	28
29	30 National Day for Truth & Reconciliation Stat				Sample Collection Time Frames (Days)	Weekly >5 & <10 Monthly >20 & <40



## Sample Calendar

### Fenelon Falls WPCP Org #5886 – Works #110001612

**Influent (Raw) and Effluent Samples must be collected on the day indicated on Calendar. If day has to be switched (i.e. composite sampler failed), the reason must be noted in the logbook and an email sent to the ORO, PCT & Sr. Ops Manager**

**Daily:** Record all operational parameters on daysheet/logbook.

Influent Monitoring (Raw)		
Parameters	Sample Type	Frequency
BOD5	Composite	Monthly
Total Suspended Solids	Composite	Monthly
Total Phosphorus	Composite	Monthly
Total Kjeldahl Nitrogen	Composite	Monthly

Biosolids Monitoring (when hauling)		
Parameters	Sample Type	Frequency
Total Solids	Grab	Once/month
Total Phosphorus	Grab	Once/month
Total Ammonia Nitrogen	Grab	Once/month
Metals Scan*	Grab	Once/month
E. Coli	Grab	Once/month

\* Arsenic, Cadmium, Cobalt, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Potassium, Selenium, Zinc

Final Effluent Monitoring		
Parameters	Sample Type	Frequency
CBOD5	Composite	Weekly
Total Suspended Solids	Composite	Weekly
Total Phosphorus	Composite	Weekly
Total Ammonia Nitrogen	Composite	Weekly
Total Kjeldahl Nitrogen	Composite	Weekly
Nitrate as Nitrogen	Composite	Weekly
Nitrite as Nitrogen	Composite	Weekly
E. coli	Grab	Weekly
Field pH	Grab	Weekly
Field Temperature	Grab	Weekly
Un-ionized Ammonia	calculated	Weekly

**OPERATOR SIGN-OFF:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

# October 2024

<i>Sun</i>	<i>Mon</i>	<i>Tue</i>	<i>Wed</i>	<i>Thu</i>	<i>Fri</i>	<i>Sat</i>
<b>Sample Collection</b> <b>Time Frames</b> <b>(Days)</b>	Weekly >5 & <10 Monthly >20 & <40	1	2 <input type="checkbox"/> Weekly <input type="checkbox"/> Monthly	3	4	5
6	7	8	9 <input type="checkbox"/> Weekly	10	11	12
13	14 Thanksgiving Day Stat	15	16 <input type="checkbox"/> Weekly	17	18	19
20	21	22	23 <input type="checkbox"/> Weekly	24	25	26
27	28	29	30 <input type="checkbox"/> Weekly	31		



## Sample Calendar

### Fenelon Falls WPCP Org #5886 – Works #110001612

**Influent (Raw) and Effluent Samples must be collected on the day indicated on Calendar. If day has to be switched (i.e. composite sampler failed), the reason must be noted in the logbook and an email sent to the ORO, PCT & Sr. Ops Manager**

**Daily:** Record all operational parameters on daysheet/logbook.

Influent Monitoring (Raw)		
Parameters	Sample Type	Frequency
BOD5	Composite	Monthly
Total Suspended Solids	Composite	Monthly
Total Phosphorus	Composite	Monthly
Total Kjeldahl Nitrogen	Composite	Monthly

Biosolids Monitoring (when hauling)		
Parameters	Sample Type	Frequency
Total Solids	Grab	Once/month
Total Phosphorus	Grab	Once/month
Total Ammonia Nitrogen	Grab	Once/month
Metals Scan*	Grab	Once/month
E. Coli	Grab	Once/month

\* Arsenic, Cadmium, Cobalt, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Potassium, Selenium, Zinc

Final Effluent Monitoring		
Parameters	Sample Type	Frequency
CBOD5	Composite	Weekly
Total Suspended Solids	Composite	Weekly
Total Phosphorus	Composite	Weekly
Total Ammonia Nitrogen	Composite	Weekly
Total Kjeldahl Nitrogen	Composite	Weekly
Nitrate as Nitrogen	Composite	Weekly
Nitrite as Nitrogen	Composite	Weekly
E. coli	Grab	Weekly
Field pH	Grab	Weekly
Field Temperature	Grab	Weekly
Un-ionized Ammonia	calculated	Weekly

**OPERATOR SIGN-OFF:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

(all collection and submission complete as per ECA, etc. + any special requirements)

# November 2024

Sun	Mon	Tue	Wed	Thu	Fri	Sat
Sample Collection Time Frames (Days)	Weekly >5 & <10 Monthly >20 & <40				1	2
3	4	5	6 <input type="checkbox"/> Weekly <input type="checkbox"/> Monthly	7	8	9
10	11 Remembrance Day Stat	12	13 <input type="checkbox"/> Weekly	14	15	16
17	18	19	20 <input type="checkbox"/> Weekly	21	22	23
24	25	26	27 <input type="checkbox"/> Weekly	28	29	30



## Sample Calendar

### Fenelon Falls WPCP Org #5886 – Works #110001612

**Influent (Raw) and Effluent Samples must be collected on the day indicated on Calendar. If day has to be switched (i.e. composite sampler failed), the reason must be noted in the logbook and an email sent to the ORO, PCT & Sr. Ops Manager**

**Daily:** Record all operational parameters on daysheet/logbook.

Influent Monitoring (Raw)		
Parameters	Sample Type	Frequency
BOD5	Composite	Monthly
Total Suspended Solids	Composite	Monthly
Total Phosphorus	Composite	Monthly
Total Kjeldahl Nitrogen	Composite	Monthly

Biosolids Monitoring (when hauling)		
Parameters	Sample Type	Frequency
Total Solids	Grab	Once/month
Total Phosphorus	Grab	Once/month
Total Ammonia Nitrogen	Grab	Once/month
Metals Scan*	Grab	Once/month
E. Coli	Grab	Once/month

\* Arsenic, Cadmium, Cobalt, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Potassium, Selenium, Zinc

Final Effluent Monitoring		
Parameters	Sample Type	Frequency
CBOD5	Composite	Weekly
Total Suspended Solids	Composite	Weekly
Total Phosphorus	Composite	Weekly
Total Ammonia Nitrogen	Composite	Weekly
Total Kjeldahl Nitrogen	Composite	Weekly
Nitrate as Nitrogen	Composite	Weekly
Nitrite as Nitrogen	Composite	Weekly
E. coli	Grab	Weekly
Field pH	Grab	Weekly
Field Temperature	Grab	Weekly
Un-ionized Ammonia	calculated	Weekly

**OPERATOR SIGN-OFF:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

# December 2024

<i>Sun</i>	<i>Mon</i>	<i>Tue</i>	<i>Wed</i>	<i>Thu</i>	<i>Fri</i>	<i>Sat</i>
1	2	3	4 <input type="checkbox"/> Weekly <input type="checkbox"/> Monthly	5	6	7
8	9	10	11 <input type="checkbox"/> Weekly	12	13	14
15	16	17	18 <input type="checkbox"/> Weekly	19	20	21
22 *Please review SGS's Holiday schedule prior to sampling	23	24 <input type="checkbox"/> Weekly	25 Christmas Day Stat	26 Boxing Day Stat	27	28
29	30	31			Sample Collection Time Frames (Days)	Weekly >5 & <10 Monthly >20 & <40