

- 1. YARD HYDRANTS TO CONFORM TO APPROVED "MANUFACTUERS LIST" OF LEAD FREE YARD HYDRANTS.
- 2. YARD HYDRANTS ARE TO BE INSTALLED WITH A MINIMUM 1.0m CLEARANCE TO ALL INFRASTRUCTURE INCLUDING SIDEWALK AND DRIVEWAYS.

K AWARTHA LAKES				CKL-109
				SCALE: NOT TO SCALE
				DATE: AUGUST 2017
ENGINEERING & CORPORATE ASSETS	CHECKED: JN	APPROVED: CS	APPROVED DATE: AUGUST 2017	REVISION No. 1