



NOTES:

1. GRANULAR THRUST BLOCKS SHALL BE FULLY EXTENDED TO AND COMPACTED AGAINST TRENCH WALLS. IF TRENCH WALLS ARE SATURATED OR DISTURBED, SPECIAL DESIGN DETAILS OF THRUST RESTRAINT SHALL BE PROVIDED BY THE ENGINEER .
2. MINIMUM RESTRAINING LENGTH (L) AS PER CKL-104.
3. 50mm BLOW OFF REQUIRED AT MECHANICAL JOINT CAP-REFER TO CKL-103.

 <p>Kawartha Lakes</p>	<p>SUPPORT FOR MECHANICAL JOINTS FOR PVC WATERMAINS VALVES & DEAD ENDS</p>			<p>CKL-105</p> <p>SCALE: NOT TO SCALE</p> <p>DATE: AUGUST 2017</p>
ENGINEERING & CORPORATE ASSETS	CHECKED: JN	APPROVED: CS	APPROVED DATE: AUGUST 2017	
				REVISION No. 1