



**NOTE:**

1. S.P.M.D.D. = STANDARD PROCTOR MAXIMUM DRY DENSITY
2. ALL VALVE BOXES LOCATED IN THE TRAVELED PORTION OF THE ROADWAY SHALL BE SCREW TYPE.

## GATE VALVE AND VALVE BOX ON PVC WATERMAINS

CITY OF KAWARTHA LAKES  
ENGINEERING AND CORPORATE  
ASSETS

322 KENT ST. W, Box 9000, LINDSAY ON. K9V 4T7, (705) 324-9411		
DRAWN BY: JN	CHECKED BY:	DATE: 2017/08
APPROVED BY: CS		DATE: 2017/08



CONTRACT NO:
SCALE:
1:25
PAGE 1 OF 1
DRAWING NO.
CKL - 101